

Test Report for the Qualification Testing of the ORNL-SFC-W-1 Special Form Capsule



A. I. Adeniyi

O. A. Martinez, PhD

February 2020

Approved for public release.
Distribution is unlimited.

DOCUMENT AVAILABILITY

Reports produced after January 1, 1996, are generally available free via US Department of Energy (DOE) SciTech Connect.

Website <http://www.osti.gov>

Reports produced before January 1, 1996, may be purchased by members of the public from the following source:

National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
Telephone 703-605-6000 (1-800-553-6847)
TDD 703-487-4639
Fax 703-605-6900
E-mail info@ntis.gov
Website <http://classic.ntis.gov/>

Reports are available to DOE employees, DOE contractors, Energy Technology Data Exchange representatives, and International Nuclear Information System representatives from the following source:

Office of Scientific and Technical Information
PO Box 62
Oak Ridge, TN 37831
Telephone 865-576-8401
Fax 865-576-5728
E-mail reports@osti.gov
Website <http://www.osti.gov/contact.html>

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Reactor and Nuclear Systems Division

**TEST REPORT FOR THE QUALIFICATION TESTING OF THE ORNL-SFC-W-1
SPECIAL FORM CAPSULE**

A. I. Adeniyi
O. A. Martinez, PhD

February 2020

Prepared by
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, TN 37831-6285
managed by
UT-BATTELLE, LLC
for the
OAK RIDGE NATIONAL LABORATORY
Nuclear Security and Isotope Technology Division
US DEPARTMENT OF ENERGY
under contract DE-AC05-00OR22725 Mod 877

REVISION LOG

Revision #	Issue Date	Pages affected	Comments
Revision 0	February 2020	All	Original Issue. Please note that the capsule named “Mark 42 Pu” in the test records was renamed “ORNL-SFC-W-1” at the time of report writing.

TEST REPORT FOR THE SPECIAL FORM QUALIFICATION TESTING OF THE ORNL-SFC-W-1 SPECIAL FORM CAPSULE

Prepared for
Oak Ridge National Laboratory
Nuclear Security and Isotope Technology Division

Prepared by
A. I. Adeniyi
O. A. Martinez, PhD

Oak Ridge National Laboratory
Reactor and Nuclear Systems Division
Used Fuel Systems Group
at the
National Transportation Research Center

APPROVALS

Name	Position	Date
A. I. Adeniyi	ORNL Package Testing Program	
O A. Martinez, PhD	ORNL Package Testing Program	
Michael Houston	ORNL Package Testing Quality Representative	
Rose Montgomery	Used Fuel Systems Group Leader	

CONTENTS

REVISION LOG.....	iii
APPROVALS	v
FIGURES.....	viii
TABLES	ix
ACRONYMS AND ABBREVIATIONS	x
ABSTRACT.....	11
1. INTRODUCTION	11
1.1 DESCRIPTION OF QUALITY ASSURANCE ACTIVITIES	14
1.2 ORNL-SFC-W-1 SFC TEST MATRIX	15
1.3 TEST DATA RECORDS.....	16
1.4 DEVIATIONS FROM THE TEST PLAN	16
2. PRE-TEST ACTIVITIES	16
3. SPECIAL FORM TESTS.....	16
3.1 9 m (30 ft) IMPACT TEST.....	17
3.2 HEAT TEST	19
3.3 LEAK RATE TESTING.....	22
3.3.1 Evacuated Envelope (with Back Pressurization)	22
3.3.2 Gas Bubble Techniques	23
4. CONCLUSION.....	25
APPENDIX A. ORNL-SFC-W-1 SPECIAL FORM CAPSULE DRAWINGS.....	A-1
APPENDIX B. TEST FORMS FOR ORNL-SFC-W-1 SPECIAL FORM CAPSULE	B-1
APPENDIX C. WELD INSPECTION REPORT	C-1
APPENDIX D. LEAK TEST NDT EXAMINER TECHNICIAN CERTIFICATION	D-1
APPENDIX E. LEAK TESTING PROCEDURE	E-1
APPENDIX F. CALIBRATION RECORDS	F-1

FIGURES

Figure 1-1. Top view of the ORNL-SFC-W-1 SFC.....	12
Figure 1-2. Side assembly view.	14
Figure 1-3. ORNL-SFC-W-1 SFC test unit.	14
Figure 3-1. TU-1 9 m (30 ft) impact test.....	18
Figure 3-2. Percussion test setup.....	18
Figure 3-3. Before and after percussion test of TU-1 (note billet impact point above letter “T”)......	19
Figure 3-4. The RAD-O-GLOW furnace used for ORNL-SFC-W-1 capsules thermal test.....	19
Figure 3-5. ORNL cDAQ system.	20
Figure 3-6. TUs were carefully loaded into the furnace.	20
Figure 3-7. Pre-heat and heat test temperature profile.....	21
Figure 3-8. TU-2 and TU-3 post-heat test results.	21
Figure 3-9. Diagram of helium back pressurization test.	23
Figure 3-10. Diagram of helium leak testing system.	23
Figure 3-11. Vacuum bubble test.....	24
Figure A.4-1. ORNL-SFC-W-1 special form capsule engineering drawing.....	A-3

TABLES

Table 1.1. Sequence of tests and processes for the ORNL-SFC-W-1 SFC TU-1	15
Table 1.2. Sequence of tests and processes for the ORNL-SFC-W-1 SFC TU-2 and TU-3	15
Table 3.1. Leak rate test variables and results for TU-1, TU-2 and TU-3	24
Table 3.2. Bubble test results for TU-1, TU-2 and TU-3.....	24

ACRONYMS AND ABBREVIATIONS

ANSI	American National Standards Institute
ASNT	American Society for Nondestructive Testing
ASTM	American Society for Testing and Materials
cDAQ	Compact Data Acquisition
CFR	US Code of Federal Regulations
IAEA	International Atomic Energy Agency
IBR	incorporated by reference
ISO	International Standards Organization
NDT	nondestructive testing
NSC	Y-12 National Security Complex
ORNL	Oak Ridge National Laboratory
PTP	Package Testing Program
QA	quality assurance
QAPD	quality assurance program description
REDC	Radiochemical Engineering Development Center
RHACS	Research Hazard Assessment and Control System
RSS	research safety summary
SBMS	Standards Based Management System
SFC	special form capsule
TC	thermocouple
TIG	tungsten inert gas
TU	test unit

ABSTRACT

Three prototypes the ORNL-SFC-W-1 special form capsules (SFCs) of the same design were evaluated to determine if the requirements of Title 49, Code of Federal Regulations (CFR), Part 173.469, *Tests for Special Form Class 7 (Radioactive) Materials*, were met. The results of the special form tests are documented in this test report.

This report describes the special form testing activities performed on the three ORNL-SFC-W-1 capsules. The test units were designated as TU-1, TU-2 and TU-3. TU-1 was subjected to leak testing, impact testing and percussion testing. TU-1 was leak tested using the leak rate test specified in 49 CFR 173.469(a)(4)(i). The impact test was conducted according to the requirements in 49 CFR 173.469 (b)(1). The percussion test that was carried out on TU-1 was conducted in accordance with 49 CFR 173.469 (b)(2). Both TU-2 and TU-3 were subjected to a leak rate test as specified in 173.469(a)(4)(i) and a heat test as specified in 49 CFR 173.469(b)(4). Each test unit was leak tested before and after these respective tests.

The leak rate tests performed were helium back-pressure tests and bubble tests as specified in American National Standards Institute (ANSI) N14.5-2014. The measured leak rates were converted to standard condition leak rates as specified in American Society for Testing and Measurement (ASTM) E 493. The determined standardized leak rates obtained from the test and the calculations for all the test units met the requirements for special form certification.

The testing was performed under the direction of the Oak Ridge National Laboratory (ORNL) Package Testing Program (PTP).

1. INTRODUCTION

This test report describes the special form testing activities for the ORNL-SFC-W-1 special form capsules (SFCs) tested to demonstrate compliance with the requirements of Title 49, Code of Federal Regulations (CFR), Part 173.469, *Tests for Special Form Class 7 (radioactive) materials*.

All testing was performed under the Oak Ridge National Laboratory (ORNL) Package Testing Program (PTP) quality assurance plan outlined in NTRC-PRF-QAP-001, Rev. 3, "Quality Assurance Plan for the Package Testing Program."

The empty weight of the sealed capsule is 0.42 kg. (0.92 lb), and the volume of the metal of the empty capsule is 51.6 cm³ (3.15 in³). The interior volume of the empty capsule is 102.0 cm³ (6.20 in³).

Figure 1-1 illustrates the ORNL-SFC-W-1 SFC. The test specimens, which are designated as TU-1, TU-2 and TU-3, were fabricated for testing purposes. One specimen (TU-1) had a stainless steel round bar 1-inch in diameter and 2 inches long as a surrogate inner container (content) for percussive testing. This bar is a conservative representation of the mass for the inner containers of all three specimens. The bar weighs 0.21 kg (0.46 lb). The total weight of TU-1, with surrogate inner container included, is 1.38 lb (0.63 kg). The volume of the TU-1 surrogate is 25.7 cm³ (1.57 in³). The internal void volume of TU-1, with surrogate, is 75.9 cm³ (4.63 in³). The other two specimens will each encapsulate an inner container having nonradioactive surrogate solid material within, which will be used to simulate Class 7 radioactive material. TU-2 has a nonradioactive surrogate (ZrO(NO₃)₂) for thorium oxide inside a stainless-steel inner container. TU-3 has a nonradioactive surrogate (La(NO₃)₃) for actinium nitrate inside a Zircalloy container. The internal void volume of TU-2 and TU-3, with the inner container, is 81.1 cm³ (4.95 in³).




Figure 1-1. Top view of the ORNL-SFC-W-1 SFC.

All test units were tested for leak tightness (leak test) before and after each test outlined in the test plan, “*Test Plan for the Special Form Qualification Testing of the Mark 42 Pu Powder Special Form Capsule*” (ORNL/NTRC-084). The testing requirements for each test unit are described below.

Specimen TU-1 was subjected to leak testing, impact testing, and percussion testing. After each specified test, a leak test of the specimen was performed. See Table 1.1 for the TU-1 test sequence.

Leak Test - 49 CFR 173.469 (a)(4)(i): The leak test performed was to demonstrate a leak tightness of 10^{-4} torr¹/s (1.3×10^{-4} atm-cm³/s) based on air at 25°C (77°F) and one atmosphere differential for solid radioactive content.

Impact Test - 49 CFR 173.469 (b)(1): The specimen was dropped onto a target from a height of 9 m (30 ft) or greater. This target met the requirement specified in Sec. 173.465(c)(5). According to 49 CFR 173.469 (a)(2), the specimen may not break or shatter when subjected to the impact test.

Percussion Test - 49 CFR 173.469 (b)(2)(i). *The specimen was placed on a sheet of lead that was supported by a smooth solid surface and was struck by the flat face of a steel billet so as to produce an impact equivalent to that resulting from a free drop of 1.4 kg (3 lb) through 1 m (3.3 ft).*

- (ii) The flat face of the billet was 2.5 cm (1 in.) in diameter, with the edges rounded off to a radius of 3 mm \pm 0.3 mm (0.12 in. \pm 0.012 in.).
- (iii) The lead had a hardness number with values within the range of 3.5 to 4.5 on the Vickers scale and a thickness of 2.5 cm (1 in.) or greater, and it covered an area greater than that covered by the specimen.
- (iv) The specimen was placed on a fresh surface of lead for the impact test.
- (v) The billet struck the specimen so as to cause maximum damage.

49 CFR 173.469 (a)(2) specifies that the specimen may not break or shatter when subjected to the percussion test.

Specimens TU-2 and TU-3 were subjected to leak testing and heat testing. Leak tests of TU-2 and TU-3 were performed before and after the heat tests per the criteria described in 49 CFR 173.469 (b)(4). See Table 1.1 and Table 1.2 for the TU-2 and TU-3 test sequences.

The ORNL-SFC-W-1 SFC was fabricated from an ASTM A511/A269 stainless-steel liner (body) – a right cylinder with an outside diameter of 2 in. and wall thickness of 0.065 in. welded at the top and bottom to plugs made from 304L/304 stainless-steel bar. Details of the dimensions can be found in APPENDIX A, Figure 1-1, and Figure 1-2. The isometric view of the test unit is shown in Figure 1-3 with sample identification markings.




Figure 1-2. Side assembly view.



Figure 1-3. ORNL-SFC-W-1 SFC test unit.

1.1 DESCRIPTION OF QUALITY ASSURANCE ACTIVITIES

The ORNL Quality Assurance Program Description (QAPD) addresses the criteria requirements identified in DOE Order 414.1D, *Quality Assurance*, and 10 CFR 830.122, *Quality Assurance Criteria*. Quality principles and methodologies are integrated and flowed down by management systems within the ORNL Standards Based Management System (SBMS).

ORNL's PTP Quality Assurance Program is under the direction of the Reactor and Nuclear Systems Division. All testing performed by the PTP is conducted under the PTP Quality Assurance Program Plan, PTP-QA-001/NTRC-PRF-QAP-001, Rev. 3., Integrated Document Management System ID 018050.

49 CFR 173.469, "Special Form Performance Testing," is documented by ORNL's test plan, *Test Plan for the Special Form Qualification Testing of the Mark 42 Pu Powder Special Form Capsule* (ORNL/NTRC-084, Rev.0, available upon request).

The safety aspects of the activities described in this test plan are controlled by ORNL's Research Hazard Assessment and Control (RHAC) Research Safety Summary (RSS), *General Use and Package Testing Activities Conducted in the NTRC Packaging Research Facility* (1082).

1.2 ORNL-SFC-W-1 SFC TEST MATRIX

All three specimens were tested following the sequence listed in Table 1.1 and Table 1.2.

Table 1.1. Sequence of tests and processes for the ORNL-SFC-W-1 SFC TU-1

Sequence	Test title	Reference / Acceptance	Procedures or test forms(s)	Comments
1	Leak test	49 CFR 173.469(a)(4)(i)	NDE-70 Rev.7	10^{-4} torr ⁻¹ /s (1.3×10^{-4} atm-cm ³ /s) based on air at 25°C (77°F) and one atmosphere differential pressure for solid radioactive content.
2	Impact test	49 CFR 173.469 (b)(1)	PTP-PRF-10, Rev. 5 <i>Procedure Checklist</i> and PTP-PRF-10, Rev. 5 <i>Data Sheet</i>	Drop from a height of 9 m (30 ft) or greater. Vertical top down.
3	Leak test	49 CFR 173.469(a)(4)(i)	NDE-70 Rev.7	10^{-4} torr ⁻¹ /s (1.3×10^{-4} atm-cm ³ /s) based on air at 25°C (77°F) and one atmosphere differential pressure for solid radioactive content.
4	Percussion test	49 CFR 173.469 (b)(2)	NTRC/ORNL-084 Rev. 0 Test Form 1	Free drop of 1.4 kg (3 pounds) through 1 m (3.3 ft). Vertical top up.
5	Leak test	49 CFR 173.469(a)(4)(i)	NDE-70 Rev.7	10^{-4} torr ⁻¹ /s (1.3×10^{-4} atm-cm ³ /s) based on air at 25°C (77°F) and one atmosphere differential pressure for solid radioactive content.

Table 1.2. Sequence of tests and processes for the ORNL-SFC-W-1 SFC TU-2 and TU-3

Sequence	Test title	Reference	Procedures or test forms(s)	Comments
1	Leak test	49 CFR 173.469(a)(4)(i)	NDE-70 Rev.7	10^{-4} torr ⁻¹ /s (1.3×10^{-4} atm-cm ³ /s) based on air at 25°C (77°F) and one atmosphere differential pressure for solid radioactive content.
2	Heat test	49 CFR 469(b)(4)	NTRC/ORNL-084 Rev. 0 Test Form 2 Test Form 3 Test Form 4	ORNL-SFC-W-1 SFC held above 825°C (1517 °F) for 10 min See Figure 3-6
3	Leak test	49 CFR 173.469(a)(4)(i)	NDE-70 Rev.7	See APPENDIX B 10^{-4} torr ⁻¹ /s (1.3×10^{-4} atm-cm ³ /s) based on air at 25°C (77°F) and one atmosphere differential pressure for solid radioactive content.

1.3 TEST DATA RECORDS

This report documents the tests performed and measurements observed from the ORNL-SFC-W-1 SFC testing. The general data types for these tests are (1) manually derived measurements and observations, (2) digital still photography, and (3) video recording of the drop and percussion tests.

The primary recording media for each of the general types of data are (1) procedure checklists, data sheets and test forms for data, measurements, and observations; (2) computer files (JPG format) of the digital photography; and (3) computer files (MPG format) of the video recordings.

The completed data sheets and procedure checklists have been scanned into a digital format and are available upon request. Photographs are presented in the main body of this document as appropriate.

1.4 DEVIATIONS FROM THE TEST PLAN

Per the test plan (ORNL/NTRC-084), 3 test units were subjected to the pre-testing leak test. TU-1 was later tested as originally specified in the test plan (see Table 1.1). TU-2 and TU-3 were tested as specified in the original test plan (see **Table 1.2**). There was no deviation from the original test plan.

2. PRE-TEST ACTIVITIES

The test units were delivered in a ready-to-test condition, so there were no specific pretest activities.

3. SPECIAL FORM TESTS

Calibrated equipment was used when required. Calibration controls were per PTP-QA-13, Control of Measuring and Test Equipment. The test equipment calibration IDs and calibration due dates were recorded on the test data sheets as applicable.

Test Equipment:

Drop pad: The-outdoor drop pad facility located at the NTRC was used for the impact test. This drop pad facility consists of a massive steel plate set on top of rebar and concrete. The mass of the outdoor drop pad has a steel impact surface and mass in excess of 140 tons. The documentation of the pad construction and suitability for use is provided in *Design and Certification of Targets for Drop Testing at the NTRC Package Research Facility Rev. 0*, May 2003 (ORNL/NTRC-001).

Billet: The billet for the percussion test is made of 1-inch diameter steel according to the requirements stated in 49 CFR 173.469(b)(2). The diameter and weight of the billet were verified and recorded in the test record forms (see Appendix B) before testing using a calibrated caliper and scale. The billet has a threaded hole at one end into which a screw-eye is attached for rigging purposes.

Platform scale: A Mettler-Toledo scale (property number A000593, model number XP32001LDR, serial number 1129350702) was used to measure the mass of the percussion billet.

30 ft plumb bob: The 9 m (30 ft) measurement wire was used to establish the height of the test unit for the impact test. Its length was verified to be in excess of 30 ft before the tests using a calibrated tape measure.

1 m aluminum rod: The 1 m aluminum rod (property number A001146) was used to verify the minimum height of the test unit above the impact surface (lead sheet) prior to the percussion test. This rod's calibration is current until 6/30/2021.

Rigging: All standard rigging used includes a current inspection sticker.

Helium leak test: Helium leak test and pressure test equipment were provided by the ORNL Level III leak test and ORNL Facilities and Operations personnel. Calibrated leaks were used to calibrate leak test equipment as part of the leak test procedure.

Furnace: The furnace used for the heat test was located in the ORNL High Bay Core Facility, Room 131, Bldg. 4508. The furnace used was a RAD-O-GLOW Global Furnace (Model #RG-3010G-2, Serial No. R2-717, ORNL property number X183717), as shown in Figure 3-4. The furnace controller thermocouple was calibrated prior to testing. The calibration record was recorded in the test form.

Thermocouple data system: The thermal data system used was the PTP Compact Data Acquisition (cDAQ) system (property number M303131). Furnace temperature readings were automatically recorded every 5 seconds. The calibration records of the cDAQ thermal data system and thermocouples were recorded on the test forms, and copies are included in the APPENDIX F.

3.1 9 m (30 ft) IMPACT TEST

The impact test was performed using the outdoor drop pad at the NTRC north parking lot next to L110. This test was performed according to Procedure PTP-PRF-10, Rev. 6, dated 1-31-19.

TU-1 was raised to a minimum height of 9m (30ft) using a man lift. A drop test fixture was used to set the drop orientation of the capsule (see Figure 3-1). The drop orientation of TU-1 was vertical top down, as stated in the test plan. Engineering judgement was used to choose the vertical top down orientation, which will cause direct damage to the threaded joint between the lid and body of the test unit. This joint is the most vulnerable feature of the design for the impact test. This orientation ensures that the impact causes maximum damage to the test unit. The test unit was released and allowed to free fall and impact onto the outdoor NTRC drop pad. The impact resulted in minor scuff marks on the impact area of the capsule. The capsule met the acceptance criteria of not shattering or breaking as a result of the impact.


After the 30-ft impact test, TU-1 was subjected to a leak test using 49 CFR 173.469 (a)(4)(i). Results of this leak test are documented in the leak rate test procedure in Section 3.3.

After a successful leak rate test, TU-1 was subjected to a percussion test per the test plan. This test was performed on the indoor drop pad at the NTRC, room L110. The procedure (ORNL/NTRC-084) for the percussion test can be found in the approved test plan. The setup was as shown in Figure 3-2.




Man-lift at 30 ft height determined using the plum bob

Drop apparatus set up, horizontal level within 2°




TU-1 impact point and imprint on pad

Figure 3-1. TU-1 9 m (30 ft) impact test.



(a)



(b)

Figure 3-2. Percussion test setup.

When released, the billet impacted TU-1 squarely on the top surface of the capsule. There was no discernible deformation or damage to the capsule as a result of the percussion test, though there was an impact scuff mark. Figure 3-3 photos show TU-1 before and after the percussion test.



Figure 3-3. Before and after percussion test of TU-1 (note billet impact point above letter “T”).

After the percussion test, TU-1 was subjected to a leak test according to the test plan using 49 CFR 173.469 (a)(4)(i). Results of this leakage test are documented in the leak rate test procedure in Section 3.3.

3.2 HEAT TEST

The 49 CFR 173.469(b)(4) heat test was performed on TU-2 and TU-3. This heat test was performed in ORNL Bldg. 4508 in accordance with the test procedure detailed in the test plan (ORNL/NTRC-084 Rev. 0). The results are recorded on Test Forms 2, 3, and 4 in Appendix B of this test report.

The safety aspects of activities for this heat test are controlled by ORNL Research Hazard Analysis and Control System (RHACS) RSS 336.22, *Materials Processing/Refining at Bldg. 4508*. The furnace used was a RAD-O-GLOW Global Furnace (Model #RG-3010G-2, Serial No. R2-717, ORNL property number X183717), as shown in Figure 3-4.

The furnace has a temperature range of 648.89 – 1537.78 °C (1,200 - 2,800 °F). The furnace has two calibrated controllers: over-temp and temp control. Two calibrated (calibration date: 11-12-2018) Type K thermocouples (TCs) (ID: Delta M. Corp Type K) were inserted into the furnace—one at the top of the furnace to the center, and the other through the front of the furnace. These thermocouples were then connected to an ORNL-developed thermal data acquisition system (cDAQ model # M303131 calibration due date: 11-12-2019) shown in Figure 3-5.



Figure 3-4. The RAD-O-GLOW furnace used for ORNL-SFC-W-1 capsules thermal test.

The PTP computer-based thermal monitoring system was used to monitor the furnace environment during the test. This system provides 48 data channels that can be continuously logged to a data file (Figure 3-5);

only two of these channels were used as specified in the test plan. The TCs were then connected to the PTP DAQ, which transferred temperature data to the laptop via an ethernet cable. During the test runs, the system was set to log data every 5 seconds from each data channel. The TCs used for TU-2 and TU-3 thermal testing were calibrated 0.062-inch diameter Type K TCs that were 50 ft in length. These lightweight TCs provided a very rapid response to changes in temperature, which in turn provided a very accurate picture of the furnace and test unit thermal behavior.




Figure 3-5. ORNL cDAQ system.

The furnace was preheated to a temperature above 850°C (1562 °F) for three hours. After a three-hour heat soaking period at a constant temperature above 850°C (1562 °F), the furnace door was opened, and TU-2 was inserted into the furnace cavity. The furnace door was closed, and when both TCs reached a furnace reading above 825°C (1517 °F), the 10-minute thermal test was started (Figure 3-6). TC1 was at the center of the furnace, and TC2 was near the front door. The DAQ system provided continuous monitoring of the temperature profile, as shown in Figure 3-6. The temperature profile represents four distinct activities: (1) the furnace pre-heat period, (2) the TU-2 heating period, (3) another pre-heat period between TU-2 extraction and TU-3 insertion, and (4) the TU-3 insertion period. After a 10-minute period, the door was opened, and TU-2 was removed from the furnace and allowed to cool naturally. TU-3 was inserted into the furnace after the furnace temperature had been allowed to reach a temperature greater 825°C (1517 °F). The furnace door was closed, and when both TCs reached a furnace reading above 825°C (1517 °F), the 10-minute thermal test for TU-3 was started. Figure 3-7 and Figure 3-8 show the units before and after the heat tests. After the thermal tests, the test units were subjected to the helium leak test and the bubble test.



Figure 3-6. TUs were carefully loaded into the furnace.




Figure 3-7. Pre-heat and heat test temperature profile.



Figure 3-8. TU-2 and TU-3 post-heat test results.

3.3 LEAK RATE TESTING

3.3.1 Evacuated Envelope (with Back Pressurization)

Leak rate tests that met the test requirements of 49 CFR 173.469 (a)(4)(i) were performed individually on each test unit before and after each special form test. The leak rate tests were performed according to ANSI N14.5-2014 *American National Standard for Radioactive Materials – Leakage Tests on Packages for Shipment*, Table A.1, Test Description A.5.5, “Evacuated Envelope (with back pressurization)” and Test Description A.5.6 “Gas bubble techniques.” The ANSI document states that the back-pressure method

“... is ideal for welded capsules from very small sizes up to the sizes limited by the dimensions of the pressurizing chamber,” and that the “nominal test sensitivity = 10^{-3} - 10^{-8} ref-cm/s” and the bubble test method are used for hermetically sealed test specimens.

Section A.5.5 of ANSI N14.5-1997, *Evacuated Envelope with Helium Back Pressure* references ASTM E 493, *Standard Test Methods for Leaks Using the Mass Spectrometer Leak Detector in the Inside-Out Testing Mode*. This standard provides the method for converting a measured leak rate using the evacuated envelope with the helium back-pressure method into the standardized leak rate that must be compared to the pass/fail criteria specified in 49 CFR 173.469(a)(4)(i), which is 10^{-4} torr-l/s (1.3×10^{-4} atm-cm³/s).

The equation provided in Section 11.1.9 of ASTM E493 is as follows:

$$S_l = (P_e/P_a) \times (1 - e^{(-3600 \cdot a \cdot T)}) * (e^{(-a \cdot t)}) \times L \quad (1)$$

where:

- S_l = indicated (measured) leak rate (cc/s),
- P_e = bombing pressure of helium (absolute),
- P_a = atmospheric pressure (absolute),
- T = bombing time (hours),
- t = waiting time between bombing and testing (s),
- L = actual (standardized) leak rate (atm-cc/s),
- a = L/V (where V = internal volume), and
- e = 2.71 (natural logarithm).

Since S_l is being measured and the objective is to solve for L , an iterative solver is required to find the solution. The equation was solved using Microsoft Excel. Note that the ASTM standard uses the term *bombing*, while the ANSI standard uses the term *back-pressure*. These terms are synonymous and are used interchangeably in this report.

TU-1, TU-2, and TU-3 were leak tested at ORNL by certified American Society for Nondestructive Testing (ASNT) Level II and Level III nondestructive testing (NDT) leak testing personnel using the NDE-70 R.7 procedure. See Appendixes D and E for documentation of leak tester certifications and the leak testing procedure. The test units were leak tested before and after each special form test. The test apparatuses used for these tests employed a spectrometer tuned to detect helium, a calibrated helium leak to calibrate the system, and two separate vessels—one vessel for helium back pressurization, and another vessel for the subsequent helium leakage rate testing under vacuum conditions. Figure 3-9 provides a schematic of the system used for helium back pressurization, and Figure 3-10 shows a schematic of the system used for the helium leakage rate test. Leak rate test variables and results for TU-1, TU-2 and TU-3 are shown in Table 3.1. A temperature correlation was performed to determine the measured leak rate at

25°C (77 °F), and per the requirement, the standardized leak test result was less than the 1.0×10^{-4} requirement for all the test units.




Figure 3-9. Diagram of helium back pressurization test.




Figure 3-10. Diagram of helium leak testing system.

3.3.2 Gas Bubble Techniques

The gas bubble test was performed using the methods described in ANSI N14.5-2014, *American National Standard for Radioactive Materials – Leakage Tests on Packages for Shipment*, Table A.1, Test Description A.5.6 (b), “Vacuum Bubble.” The method involves immersing the test unit in a liquid and then producing a vacuum above the liquid (e.g., water/glycol or isopropyl alcohol) in which the test item is submerged (see Figure 3-11). A leak is indicated by a stream of bubbles. This method applies to welded

capsules. The nominal test sensitivity is 10^{-3} ref-cm³/s (10^{-4} Pa-m³/s). Test units TU-1, TU-2 and TU-3 were bubble tested, and the results are presented in Table 3.2. See Appendixes D and E for documentation of leak tester certification and the leak testing procedure. While the sensitivity of the bubble test does not meet the minimum leak rate per 49 CFR 173.469 4(i), this test is needed because it is possible that a leak area is large enough that the helium inside the component may have evacuated out before the test unit is placed in the vacuum chamber for helium detection.




Figure 3-11. Vacuum bubble test.

Table 3.1. Leak rate test variables and results for TU-1, TU-2 and TU-3

Parameter	Test unit						
	TU-1			TU-2		TU-3	
	Test 1	Test 2	Test 3	Test 1	Test 2	Test 1	Test 2
Void space – V (cc)	75.9	75.9	75.9	81.2	81.1	81.2	81.1
Bombing pressure – P _b (psig)	30	30	30	30	30	30	30
Atmospheric pressure – P _a (psia)	14.69	14.69	14.69	14.69	14.69	14.69	14.69
Bombing time – T (hr)	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Time between bombing and testing – t (s)	<3,600	<3,600	<3,600	<3,600	<3,600	<3,600	<3,600
Measured leak rate (cc/s) – S _i (atm-cc He/s)	<5.0×10 ⁻⁷	<5.0×10 ⁻⁷	<5.0×10 ⁻⁷	<5.0×10 ⁻⁷	<5.0×10 ⁻⁷	<5.0×10 ⁻⁷	<5.0×10 ⁻⁷
a = L/V (s ⁻¹)	1.56×10 ⁻⁶	1.56×10 ⁻⁶	1.56×10 ⁻⁶	1.50×10 ⁻⁶	1.50×10 ⁻⁶	1.50×10 ⁻⁶	1.50×10 ⁻⁶
Standardized leak rate – L (atm-cc He/s)	<1.18×10 ⁻⁴	<1.18×10 ⁻⁴	<1.18×10 ⁻⁴	<1.22×10 ⁻⁴	<1.22×10 ⁻⁴	<1.22×10 ⁻⁴	<1.22×10 ⁻⁴
Allowable leak rate – (atm-cc He/s)	<1.3×10 ⁻⁴	<1.3×10 ⁻⁴	<1.3×10 ⁻⁴	<1.3×10 ⁻⁴	<1.3×10 ⁻⁴	<1.3×10 ⁻⁴	<1.3×10 ⁻⁴

Table 3.2. Bubble test results for TU-1, TU-2 and TU-3

Parameter	Test unit						
	TU-1			TU-2		TU-3	
	Test 1	Test 2	Test 3	Test 1	Test 2	Test 1	Test 2
Bubble test pass/fail	pass	pass	pass	pass	pass	pass	pass


4. CONCLUSION

Three prototype ORNL-SFC-W-1 SFCs were subjected to the tests specified in 49 CFR 173.469. All the units were subjected to a pretest leak test. One unit was subjected to the impact test followed by a leak rate test and a percussion test, followed by another leak test. The other two units were subjected to the heat test followed by a leak rate test. Each unit met the leak rate criteria of 1.3×10^{-4} atm-cm³/s following each test. None of the test specimens broke or were shattered when subjected to the impact and percussion tests, and the specimens did not melt or disperse when subjected to the heat test. This testing process has shown that the design of the ORNL-SFC-W-1 SFC meets special form criteria per 49 CFR 173.469 and International Atomic Energy Agency (IAEA) special form requirements.

The ORNL-SFC-W-1 capsules welds (see APPENDIX C) were also examined after the completion of series of tests described above.

APPENDIX A. ORNL-SFC-W-1 SPECIAL FORM CAPSULE DRAWINGS

Please note that the capsule named “Mark 42 Pu” in the test records was renamed “ORNL-SFC-W-1” at the time of report writing.



SPECIAL FORM-POWDER SHIPPING CAN. C-RD-3095		REF: SK-83A, B3B, B3C (SIMILAR TO DETAILS SHOWN HERE)	
REFERENCE DRAWINGS		NUMBER	
<p align="center">Oak Ridge National Laboratory OPERATED BY Union Carbide Corporation OAK RIDGE, TENNESSEE</p>			
TRANSURANIUM PROCESSING PLANT BLDG. 7920 NO.			
SPECIAL FORM			
POWDER SHIPPING CONTAINER			
AND ACCESSORIES			
SUBMITTED		ACCEPTED	
S. O. Lewis		J. H. O'Neil	
DATE		DATE	
4/10/81		4/10/81	
APPROVED		APPROVED	
M. J. Lewis		C. P. 813	
DATE		DATE	
4/10/81		4/10/81	
REV.		REV.	
1		1	

Figure A.4-1. ORNL-SFC-W-1 special form capsule engineering drawing.

APPENDIX B. TEST FORMS FOR ORNL-SFC-W-1 SPECIAL FORM CAPSULE

Please note that the capsule named “Mark 42 Pu” in the test records was renamed “ORNL-SFC-W-1” at the time of report writing.



LEAK TEST REPORT

Test Requested by: D. SHARPE	Allowable Leak Rate: $< 1.3 \times 10^{-4}$	Std-Atm-cc/s
Date Requested: 7/15/19	Date Required: -	
Work Order Number: 3730855	Test Pressure Req. Across Boundary: - 1 ATM	
Item Tested: 3EA. MK 42 SFC	Customer: NTRC	
Specification: 49 CFR 173.469(a)(1)(i)	NDE 70, Rev: 7	Technique Used: INSIDE-OUT
	Rev: 0	<input checked="" type="checkbox"/> Inside - Out <input type="checkbox"/> Outside - In

EQUIPMENT

LEAK DETECTOR		STANDARD LEAK	
Make and Model: ADIXEN ASM 182 TD+	Manufacturer: VEECO	Tracer Gas: He	
Serial Number: HEB 0860905	Model: SL-4	Serial Number: 18091	
	Leak Rate: 2.55×10^{-8} Atm-cc/s @ - 1 atm @ 23.2 °C		
TEST GAUGES		Correlation Formula: [1 - (T _{cal} - T _{surf}) C _T] LR	Temp Coefficient: 3.0 % / °C
Temp Gauges: A001952	Due: 9/6/19	Correlated LR: 2.28×10^{-8} Atm-cc/s @ - 1 atm @ 19.7 °C	
Pressure Gauges: MTE 767	Due: CAL: 8/28/18	Calibration Due Date: 9/25/19	

RESULTS

☒ Quantitative ☐ Semi - Quantitative

MACHINE CALIBRATION		SYSTEM TEST CONDITIONS	
System Pressure: 1.3×10^{-2} mb		System Temperature: 19.7 °C	<input checked="" type="checkbox"/> Surface <input type="checkbox"/> Internal Gas
Background: $< 1.0 \times 10^{-9}$	Atm-cc/s	delta P Test Boundary: - 1 ATM	
Leak Response: 2.3×10^{-8}	Atm-cc/s	Tracer Gas: He	% Concentration: CALC
Minimum Detectable Leak: 1.0×10^{-9}	Atm-cc/s	System Response Time: ~ 1 MIN	
System Sensitivity: 2.0×10^{-9}	Atm-cc/s	System Response: $< 2.0 \times 10^{-7}$	Atm-cc/s
Response Time: ~ 3 s		Duration of Test: ~ 2 MIN EA.	

Aux. Equipment:

<input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT <input checked="" type="checkbox"/> SKETCH / DATA ATTACHED	System Leak Rate: w/ stated tracer gas $< 1.3 \times 10^{-4}$ Atm-cc/s @ - 1 atm @ 25 °C
---	--

COMMENTS:

TU-1, TU-2, TU-3 LEAK TEST #1 PER ORNL/NTRC-084

FINE LT

Test Conducted By: E. VIOAL	Level: III	Date: 7/19/19	Time: 1:30
------------------------------------	-------------------	----------------------	-------------------



BOMBING TEST REPORT (Supplement)

Leak Test Report Number: 7/19/19-1 Allowable Leak Rate: $< 1.3 \times 10^{-4}$ Atm-cc/s

Item(s) Tested: MK-42 SFC TU-1, TU-2, TU-3

TRACER GAS BOMBING AND LEAK TEST

Bombing Pressure (psig): <u>30</u>	Tracer Gas: <u>He</u>	Bombing Time: <u>15 MIN</u>
Waiting Time (Sec): <u>< 3600</u>	Internal Volume (cc): <u>75.9 (TU-1) 81.1 (TU-2, TU-3)</u>	
Measured Leak Rate: <u>$< 5.0 \times 10^{-7}$</u> Atm cc/s	Calculated Leak Rate: <u>$< 1.3 \times 10^{-4}$ Atm cc/s into vac. @ <u>25</u> °C</u>	
Test Results: <input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT <input checked="" type="checkbox"/> CALCULATIONS / DATA ATTACHED		

COMMENTS:

Test Conducted By: E. VIDAL [Signature] Level: III Date: 7/19/19

ASNT Formula		ASTM/CFR Formula	
R	5.00E-07 scc/s		
Pe	44.696 psia		
Po	14.696 psia		
Ma	28.7 g/mol		
M	4 g/mol		
T1	900 sec		
T2	3600 sec		
V	75.9 cc		
L	4.397E-05 scc/s	1.178E-04 scc/s	Equivalent air leak rate
Part 1	3.582E-04		
Part 2	1.396E-03		
Part 3	9.944E-01		
Lcf	2.9532E-05 scc/s	7.90536E-05 scc/s	Corrected for tracer gas

RESULTS

L (ASNT/MIL)	4.40E-05 scc/s air	1.18E-04 scc/s He
L (ASTM/CFR)	4.40E-05 scc/s air	1.18E-04 scc/s He

Calculator Version 3/2/18



Certificate Number 4121.0
Note: formula is modified for uniformity; a = L/V and 3600 converts hours to seconds

$$R = \left[\frac{LP_e}{P_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right] \times \left[1 - e^{-\left[\frac{LT_1}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]} \right] \times e^{-\left[\frac{LT_2}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]}$$

$$R = \frac{LP_e}{P_o} \left[1 - e^{-\left(\frac{L}{V} \right) T_1} \right] \times \left[e^{-\left(\frac{L}{V} \right) T_2} \right]$$

No 3730855 TU-1

E-VIOL 21042018 7/19/19

ASNT Formula		ASTM/CFR Formula	
R	5.00E-07 scc/s Measured helium leak rate (Q)		
Pe	44.696 psia Bomb Chamber Pressure		
Po	14.696 psia Atmospheric pressure		
Ma	28.7 g/mol MW of air		
M	4 g/mol MW Helium		
T1	900 sec Time of exposure (bomb time)		
T2	3600 sec Dwell time (from bomb chamber to test start)		
V	81.1 cc Internal volume		
L	4.548E-05 scc/s Equivalent air leak rate (estimate value for calc to work)	1.218E-04 scc/s Equivalent air leak rate	
Part 1	3.705E-04 Converts true air leak to helium leak rate		
Part 2	1.351E-03 Calc amount of helium entering package during bomb		
Part 3	9.946E-01 Amount of helium at the end of the dwell		
Lcf	3.0526E-05 scc/s Corrected for tracer concentration	8.17679E-05 scc/s Corrected for tracer gas	

RESULTS

L (ASNT/MIL)	4.55E-05 scc/s air	1.22E-04 scc/s He
L (ASTM/CFR)	4.55E-05 scc/s air	1.22E-04 scc/s He

Calculator Version 3/2/18



Certificate Number 4121.0
Note: formula is modified for uniformity; a = L/V and 3600 converts hours to seconds

$$R = \left[\frac{LP_e}{P_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right] \times \left\{ 1 - e^{-\left[\frac{LT_1}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]} \right\} \times e^{-\left[\frac{LT_2}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]}$$

$$R = \frac{LP_e}{P_o} \left[1 - e^{-\left(\frac{L}{V} \right) T_1} \right] \times \left[e^{-\left(\frac{L}{V} \right) T_2} \right]$$

NO: 3730855 TU-2, TU-3

E-V10A *[Signature]* 7/19/14



ORNL Surveillance and Inspection Organization / Certificate #4121.01 /
Scope of Accreditation to ISO/IEC 17020:2012

Report Number: 7/19/19-2

LEAK TEST REPORT - BUBBLE TEST

Test Requested by: S. SHARPE	Customer: NTRC
Date Requested: 7/15/19	Date Required: -
Work Order Number: 3730855	NDE 70, Rev: 7 Tech, NDE 70 - BT Rev: 0
Item Tested: 3 EA. MK-42 SFC	Test Pressure Required: 15" H ₂ O
Specification: 49 CFR 173.469(a)(4)(i)	Inspection Criteria: NO INDICATIONS @ 2 MIN
Technique Used: VAC BOX	Liquid Media Used: CIM 200 @ 20% SOLN.
Test Gas Used: VAC	Liquid Applicator Type: IMMERSION
Inspection Light Intensity: > 100 FC	Post Cleaning Method: DI H ₂ O RINSE
Other Apparatus Used: FLASHLIGHT	

Direct Pressure Technique ☐

Vacuum Pressure Technique ☒

Component Limits of Test:

TU-1, TU-2, TU-3 LEAK TEST #1 PER ORNL/NTRC-084

Component Test Site 5500				Component Installation Site -			
Gauges				Test Pressure		Temperature	
Mfg	ID No	Calibration Date	Range	Beginning	End	Beginning	End
-	A002124	10/4/18	0-30" H ₂ O	15" H ₂ O	20" H ₂ O	14.7°C	19.7°C

Temperature Measuring Device

Mfg. OMEGA	Model HH804	Range K-TYPE	I.D. Number A001952
------------	-------------	--------------	---------------------

RESULTS

☒ ACCEPT

☐ REJECT

POST CLEANING PERFORMED: ☒ Y ☐ N

Comments:

GROSS LT

Test Conducted By:

E. YIOAL

Level: III

Insp. Date: 7/19/19

Form NDE-70-Bubble Rev. 1 CN02

IDMS: 10960

767

PRESSURE GAGE CALIBRATION DATA SHEET

DUT M&TE # <u>767</u>	Range 0-100 psig	Manufacturer <u>WIKI</u>
Calibration Frequency <u>AFTER USE</u>	Scale Subdivisions <u>0.1 psig</u>	Accuracy (%Span $\frac{1}{4}$ - $\frac{1}{2}$ - $\frac{1}{4}$) <u>Grade B: 3 - 2 - 3</u>
Calibrator Used <u>BEAMEX MTE 564</u>		Calibration Date <u>10-11-17</u>
Calibrator Pressure Module <u>N/A</u>		Calibration Date <u>N/A</u>

Visual Inspection:

☒ Accept☐ Reject

	DUT		Standard Gage	Allowed Error
	Scale	Reading		
UP	0%	0	0	3.0
	25%	25	24.7	2.0
	50%	50	49.7	2.0
	75%	75	75	2.0
	100%	100	99.5	3.0
Down	100%	100	100	3.0
	75%	75	74.7	2.0
	50%	50	49.7	2.0
	25%	25	24.7	2.0
	0%	0	0	3.0

Circle any non-conforming readings

Note: all readings in PSIG

Disposition:

☒ Accept☐ Reject☐ If Rejected was tag applied

Adjustment Necessary:

☐ Yes☒ No

Decal Applied:

☒ Yes☐ No

Inspector:

B. Brown

Date:

8-28-17

ORNL PACKAGE TESTING PROGRAM OAK RIDGE NATIONAL LABORATORY OAK RIDGE, TENNESSEE 37831 <small>The OFFICIAL COPY of this document is the on-line version. Before using a printed copy, verify that it is the most current version by checking the Revision ID against the on-line version.</small>	Operating Procedures for HAC Drop Test - Testing of Radioactive Material Packages	Test Procedure:	
		PTP-PRF-10	
		Page:	Rev.
		1 / 7	6
		Issue Date:	2-1-19
		Revision Date:	1-31-19
		Review By Date:	1-31-22
Written By: Richard Michelhaugh		Reviewed By: Matt Feldman	
		Approved By: John Scaglione	

John M. Scaglione Digitally signed by John M. Scaglione
Date: 2019.07.31 09:36:10 -0400

1. Scope

This procedure describes the process that the Package Testing Program (PTP) uses in the performance of Hypothetical Accident Conditions (HAC) drop tests, using a release mechanism, rigging, and a crane/hoist. Drop tests are performed during the package testing sequence to demonstrate compliance with the performance requirements embodied within the radioactive materials packaging requirements.

2. Safety Precautions

It is the responsibility of PTP personnel to remain alert to potential hazards and take the necessary precautions to ensure a safe working environment. Personnel Protective Equipment required for conducting drop tests: **safety glasses w/side shields, hardhat, gloves and safety shoes. Observers** of drop tests are required to wear **safety glasses w/side shields and hard hats**. All persons (workers and observers) should be familiar with the hazards associated with drop tests, which involve the release (drop) of heavy objects from specified heights, as well as manipulating heavy objects in preparation for such tests. All persons shall remain sufficiently clear of test specimens during any lifting operation to eliminate the possibility of injury from an accidental release. Release mechanisms are used to initiate the controlled release of the test specimen. Release mechanisms shall not be used for general hoisting operations - a release mechanism shall only be used to lift the test specimen in preparation for the actual drop test. Other test specimen lifts shall be accomplished with proper and approved rigging attached to the crane hook. Release mechanisms shall remain disconnected from actuating power sources until the test specimen is in final position and ready to be released.

3. Equipment

- Release Mechanisms:

PTP Small Release Mechanism, IE 11631, (for test specimens with a gross mass less than 3000-lb). This is an electro-mechanical device in which an electrically actuated solenoid is used to open the release mechanism jaws, resulting in single-point release of the object suspended from the crane.

ORNL PACKAGE TESTING PROGRAM OAK RIDGE NATIONAL LABORATORY OAK RIDGE, TENNESSEE 37831 <small>The OFFICIAL COPY of this document is the on-line version. Before using a printed copy, verify that it is the most current version by checking the Revision ID against the on-line version.</small>	Operating Procedures for HAC Drop Test - Testing of Radioactive Material Packages		Test Procedure:	Rev.
			PTP-PRF-10	6
	Page:		2 / 7	Issue Date:
	Revision Date:		1-31-19	Review By Date:
				2-1-19
				1-31-22

OR

PTP "Big Red" Release Mechanism, IE 12437, (for test specimens with a gross mass up to 20,000-lb). This is a larger version of the PTP Small Release Mechanism, enabling a drop capacity up to 20,000-lb. For these larger packages, it will be necessary to use the outside drop pad, a mobile crane, release mechanism, and appropriate rigging to conduct this drop test.

OR

Explosive Cable Cutters and Bolts. For some drop tests (especially those that exceed the capacity of the available release mechanisms, the use of alternative releasing methods (such as explosive cable cutters or explosive nut/bolts) is required. For these devices, an explosive charge is used to cause the release of the test specimen.

- **Drop Pad:**
The drop pad that may be used for this test are documented in *Design and Certification of Targets for Drop Testing at the NTRC Package Research Facility Rev. 0*, May 2003, ORNL/NTRC-001. The document addresses dimensions, surface description, construction details, and the suitability of each drop pad as a flat, essentially unyielding surface for impact (target) pads. The outside drop pad has a steel impact surface and mass in excess of 140 tons.

NTRC Large Drop Pad. This drop pad is located adjacent to the NTRC PEF, and is embedded in the parking lot outside NTRC Room L110. The Large Drop Pad is certified as "essentially unyielding" for 9-m (30-ft) drops of test specimens weighing up to approximately 28,000-lb.

- **Plumb bob cable.** A commercial measuring tape or other suitable measuring device is to be used to verify the length of the plumb bob cable.
- **Digital Camera, Video Camera and Photographer's Clapboard.**
- **Rigging suitable for lifting the package as required.** Rigging includes items such as straps, wire rope chokers, shackles, etc.

ORNL PACKAGE TESTING PROGRAM OAK RIDGE NATIONAL LABORATORY OAK RIDGE, TENNESSEE 37831 <small>The OFFICIAL COPY of this document is the on-line version. Before using a printed copy, verify that it is the most current version by checking the Revision ID against the on-line version.</small>	Operating Procedures for HAC Drop Test - Testing of Radioactive Material Packages	Test Procedure: PTP-PRF-10		Rev. 6
		Page: 3 / 7	Issue Date: 2-1-19	
		Revision Date: 1-31-19	Review By Date: 1-31-22	

- A thermometer for measuring the ambient temperature. Any commercial thermometer may be used, and calibration is not required. The PTP Fluke Thermocouple Thermometer is sufficient for this purpose.
- Test Specimen(s) (i.e., packaging test units)

4. Test Procedure

- 4.1. Ensure that Measuring & Test Equipment (M&TE) meets the requirements of PTP-QA-013, "Procedure on Control of Measuring and Test Equipment". Record any M&TE on the Procedure Data Sheet.
- 4.2. Initiate a unique **Procedure Checklist** form and **Data Sheet** form for each Test Specimen. Record the **Test Plan** identifier and Test Unit identifier on each form. Record completion of each step and other required information at appropriate locations on **Procedure Checklist** and **Data Sheet**, as referenced by the following procedure steps.
- 4.3. The drop orientation is specified in the specific **Test Plan** for each package. Record the orientation.
- 4.4. Prepare photographer's clipboard with package name and test specimen identification information.
- 4.5. Rig the test specimen in the required orientation using the selected release mechanism and measure and record the attitude. The tolerance for rigging the angle of a test specimen's attitude is $\pm 2.0^\circ$ unless otherwise specified in the **Test Plan**. As a general rule, the testing team will rig the package to a tolerance of $\pm 1.0^\circ$, if possible, given the attachment points and rigging available for a particular package. Take photograph of rigged and raised specimen. Take photograph of angle measurement.
- 4.6. Attach the PTP plumb bob cable to the lowest point of the test specimen with tape. The package will be properly blocked while attaching the cable to keep the operator safe in the event that the package is released prematurely.

ORNL PACKAGE TESTING PROGRAM OAK RIDGE NATIONAL LABORATORY OAK RIDGE, TENNESSEE 37831 <small>The OFFICIAL COPY of this document is the on-line version. Before using a printed copy, verify that it is the most current version by checking the Revision ID against the on-line version.</small>	Operating Procedures for HAC Drop Test - Testing of Radioactive Material Packages		Test Procedure:	Rev.
			PTP-PRF-10	6
			Page:	Issue Date:
			4 / 7	2-1-19
			Revision Date:	Review By Date:
			1-31-19	1-31-22

- 4.7. Raise the test specimen to the specified drop height. Take photograph of height measurement. Pull the cable removal string and remove the 9-m plumb bob and cable from the drop pad.
- 4.8. Confirm that video cameras are rolling. Plug release mechanism into power. Countdown. Trigger release mechanism. Disconnect power from release mechanism.
- 4.9. Stop video cameras.
- 4.10. Record Date and time of test and record the ambient temperature at the test time.
- 4.11. Photograph damaged test specimen as it lies from drop. Turn test specimen to reveal any damage and photograph the damage. When inspection is complete, move the test unit from the drop pad.
- 4.12. The Test Engineer shall sign and date the completed **Procedure Checklist** and **Data Sheet**. A Quality Representative shall check each of these test forms for accuracy and completeness and sign and date each checked test form

ORNL PACKAGE TESTING PROGRAM OAK RIDGE NATIONAL LABORATORY OAK RIDGE, TENNESSEE 37831 <small>This OFFICIAL COPY of this document is the on-line version. Before using a printed copy, verify that it is the most current version by checking the Revision ID against the on-line version.</small>	Operating Procedures for HAC Drop Test - Testing of Radioactive Material Packages	Test Procedure: PTP-PRF-10		Rev. 6
		Page: 5 / 7	Issue Date: 2-1-19	
		Revision Date: 1-31-19	Review By Date: 1-31-22	

5. Review and Revision History

- **1-30-04** - Original Issue
- **5-27-04** - Expanded step 4.7 to explicitly require removal of the plumb bob before proceeding to next step. Added verification step to checklist.
- **12-01-06** - Triennial Review. Editorial changes. Modified Signoff responsibilities for Checklist and Data Sheet.
- **1-31-10** - Reviewed, no changes made
- **1-31-13** - Reviewed, added ambient temperature recording to the end of the checklist. Also added attitude description in Section 7.
- **1-19-16** - Triennial review, removed TTG reference. Approved by changed to current UFS group leader. – Oscar Martinez
- **1-20-19** - Triennial review. Checked by must be performed by a QR if applicable. Included a step to ensure all equipment has been calibrated per the PTP-QA-013 procedure. Oscar Martinez

ORNL PACKAGE TESTING PROGRAM OAK RIDGE NATIONAL LABORATORY OAK RIDGE, TENNESSEE 37831 <small>The OFFICIAL COPY of this document is the on-line version. Before using a printed copy, verify that it is the most current version by checking the Revision ID against the on-line version.</small>	Operating Procedures for HAC Drop Test - Testing of Radioactive Material Packages		Test Procedure:	Rev.
			PTP-PRF-10	6
	Page:	7 / 7	Issue Date:	2-1-19
	Revision Date:	1-31-19	Review By Date:	1-31-22

7. Data Sheet

Test Plan:
ORNL/NTRC-084

Test Unit:
1

VERIFIED

TASK

Intended attitude of the test unit 0° Tolerance \pm 2° (§4.2)

Attitude Description: vertical top down (§4.2)

Measured attitude of the test unit 1.7° degrees. (§4.4)

Level number M212348 Calibration Exp. Date 7/30/2020 ^{OKM 8/2/2019} (§4.4)

Height above the drop pad 30 ft Measuring device A006327 (§4.6)

Date and Time of Drop Test: 8/2/2019 (§4.9)

N/A Ambient temperature: _____ °C (_____ °F)

Measuring device _____ (§4.9)

Testing Damage Observations:

Comments:

I certify that the above tasks have been performed and that the observations and comments are correct.

[Signature]
Test Engineer

08/02/2019
Date

Michael B. Houston
Checked by

08/02/2019
Date



LEAK TEST REPORT

Test Requested by: J. SHARPE	Allowable Leak Rate: $< 1.3 \times 10^{-4}$ Std-Atm-cc/s
Date Requested: 7/15/19	Date Required: -
Work Order Number: 3730855	Test Pressure Req. Across Boundary: -1 atm
Item Tested: MK 42 SFL TU-1	Customer: NTRC
Specification: 49 CFR 173.469(a)(4)(i) NDE 70, Rev: 7	Technique Used: INSIDE-OUT Rev: 0 <input checked="" type="checkbox"/> Inside - Out <input type="checkbox"/> Outside - In

EQUIPMENT

LEAK DETECTOR		STANDARD LEAK	
Make and Model: ADKIN ASM 340	Manufacturer: VTI VEECO	Tracer Gas: He	
Serial Number: HLD-1601393	Model: GPPT-7-He-118T	Serial Number: TP5150	
		Leak Rate: 3.97×10^{-7} Atm-cc/s @ -1 atm @ 23 °C	
TEST GAUGES		Correlation Formula: $[1 - (T_{cal} - T_{sur}) C_T] LR$	Temp Coefficient: 2.0 %/°C
Temp Gauges: A001952	Due: 9/6/19	Correlated LR: 3.72×10^{-7} Atm-cc/s @ -1 atm @ 19.9 °C	
Pressure Gauges: MTE-767	Due: CAL: 8/28/18	Calibration Due Date: 01/17/20	

RESULTS

☒ Quantitative ☐ Semi - Quantitative

MACHINE CALIBRATION		SYSTEM TEST CONDITIONS	
System Pressure: 1.9×10^{-2} mb		System Temperature: 19.9 °C <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Internal Gas	
Background: $< 5.0 \times 10^{-10}$ Atm-cc/s		delta P Test Boundary: -1 atm	
Leak Response: 3.7×10^{-7} Atm-cc/s		Tracer Gas: He	% Concentration: CALC
Minimum Detectable Leak: 1.0×10^{-8} Atm-cc/s		System Response Time: ~ 1 min	
System Sensitivity: 2.0×10^{-8} Atm-cc/s		System Response: $< 1.0 \times 10^{-7}$ Atm-cc/s	
Response Time: ~ 3 s		Duration of Test: ~ 2 min	

Aux. Equipment:

<input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT <input checked="" type="checkbox"/> SKETCH / DATA ATTACHED	System Leak Rate: $< 1.3 \times 10^{-4}$ Atm-cc/s @ -1 atm @ 25 °C <small>if stated tracer gas</small>
---	---

COMMENTS:

TU-1 LEAK TEST #2 PER ORNL/NTRC-084 (TEST #3 - POST-IMPACT)

FINE LT

Test Conducted By: E. VIDAL <i>E. Vidal</i>	Level: III	Date: 8/8/19	Time: 10:30
---	------------	--------------	-------------

Form NDE 70-MS, Rev. 1 CN02

IDMS: 21077



BOMBING TEST REPORT (Supplement)

Leak Test Report Number: 8/8/19-1 Allowable Leak Rate: $< 1.3 \times 10^{-4}$ Atm cc/s

Item(s) Tested: MK-42 SFC TU-1

TRACER GAS BOMBING AND LEAK TEST

Bombing Pressure (psig): <u>30</u>	Tracer Gas: <u>He</u>	Bombing Time: <u>15 min</u>
Waiting Time (Sec): <u>< 3600</u>	Internal Volume (cc): <u>75.9</u>	
Measured Leak Rate: <u>$< 5.0 \times 10^{-7}$</u> Atm cc/s	Calculated Leak Rate: <u>$< 1.3 \times 10^{-4}$</u> Atm cc/s into vac. @ <u>25</u> °C	
Test Results: <input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT <input checked="" type="checkbox"/> CALCULATIONS / DATA ATTACHED		

COMMENTS:

Test Conducted By: E-Viora [Signature] Level: III Date: 8/8/19

ASNT Formula		ASTM/CFR Formula	
R	5.00E-07 scc/s		
Pe	44.696 psia		
Po	14.696 psia		
Ma	28.7 g/mol		
M	4 g/mol		
T1	900 sec		
T2	3600 sec		
V	75.9 cc		
L	4.397E-05 scc/s	1.178E-04 scc/s	Equivalent air leak rate
Part 1	3.582E-04		
Part 2	1.396E-03		
Part 3	9.944E-01		
Lcf	2.9512E-05 scc/s	7.90516E-05 scc/s	Corrected for tracer gas

RESULTS

L (ASNT/MIL)	4.40E-05 scc/s air	1.18E-04 scc/s He
L (ASTM/CFR)	4.40E-05 scc/s air	1.18E-04 scc/s He

Calculator Version 3/2/18



Certificate Number: 4121.0
Note: formula is modified for uniformity; a = L/V and 3600 converts hours to seconds

$$R = \left[\frac{LP_e}{P_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right] \times \left\{ 1 - e^{-\left[\frac{LT_1}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]} \right\} \times e^{-\left[\frac{LT_2}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]}$$

$$R = \frac{LP_e}{P_o} \left[1 - e^{-\left(\frac{L}{V} \right) T_1} \right] \times e^{-\left(\frac{L}{V} \right) T_2}$$

NO 37308SS TU-1

E-VIOL 210620 7/19/19

767

PRESSURE GAGE CALIBRATION DATA SHEET

DUT M&TE # <u>767</u>	Range 0-100 psig	Manufacturer <u>WIKI</u>
Calibration Frequency <u>AFTER USE</u>	Scale Subdivisions <u>0.1 psig</u>	Accuracy (%Span $\frac{1}{4}$ - $\frac{1}{2}$ - $\frac{1}{4}$) Grade B: 3 - 2 - 3
Calibrator Used <u>BEAMEX MTE 564</u>		Calibration Date <u>10-11-17</u>
Calibrator Pressure Module <u>N/A</u>		Calibration Date <u>N/A</u>

Visual Inspection:

☒ Accept☐ Reject

	DUT		Standard Gage	Allowed Error
	Scale	Reading		
UP	0%	0	0	3.0
	25%	25	24.7	2.0
	50%	50	49.7	2.0
	75%	75	75	2.0
	100%	100	99.5	3.0
Down	100%	100	100	3.0
	75%	75	74.7	2.0
	50%	50	49.7	2.0
	25%	25	24.7	2.0
	0%	0	0	3.0

Circle any non-conforming readings

Note: all readings in PSIG

Disposition:

☒ Accept☐ Reject☐ If Rejected was tag applied

Adjustment Necessary:

☐ Yes☒ No

Decal Applied:

☒ Yes☐ No

Inspector:

B. Brown

Date:

8-28-17



ORNL Surveillance and Inspection Organization / Certificate #4121.01 /
Scope of Accreditation to ISO/IEC 17020:2012

Report Number: 8/8/19-2

LEAK TEST REPORT - BUBBLE TEST

Test Requested by: D. SHARPE	Customer: RNSO
Date Requested: 7/15/19	Date Required: -
Work Order Number: 3730855	NDE 70, Rev: 7 Tech, NDE 70 - BT Rev: 0
Item Tested: MK-42 SFC TU-1	Test Pressure Required: 15" Hg
Specification: 49 CFR 173.469(a)(4)(i)	Inspection Criteria: NO INDICATIONS @ 2 MIN
Technique Used: VAC BOX	Liquid Media Used: IMMERSIT CIM 200 @ 20% SOLN
Test Gas Used: VAC	Liquid Applicator Type: IMMERSION
Inspection Light Intensity: >100 FC	Post Cleaning Method: DI RINSE / WIPE DRY
Other Apparatus Used: FLASHLIGHT	

Direct Pressure Technique ☐

Vacuum Pressure Technique ☒

Component Limits of Test:

TEST SEQUENCE #3, LEAK TEST #2 - POST-IMPACT
PER ORNL/NTRC-084

Component Test Site 5500

Component Installation Site -

Gauges				Test Pressure		Temperature	
Mfg	ID No	Calibration Date	Range	Beginning	End	Beginning	End
	AB02124	10/14/18	0-30" Hg	15" Hg	23" Hg	19.9°C	19.9°C

Temperature Measuring Device

Mfg. OMEGA	Model HH804	Range K-TYPE	I.D. Number A001952
------------	-------------	--------------	---------------------

RESULTS

☒ ACCEPT

☐ REJECT

POST CLEANING PERFORMED: ☒ Y ☐ N

Comments:

GROSS LT

Test Conducted By:

E. VIOGA

Level: TIT

Insp. Date: 8/8/19

TEST FORM 1 – Percussion Test Form

Test Plan

ORNL/NTRC-084 Rev 0

Test Unit TU- 1

VERIFIED

TASK

The weight of the percussion billet has been measured and verified to be 3lbs or greater:

Measured weight of billet 1.4249 (lbs.)

Scale used for measurement: A000593 Calibration due: 7/25/2020

The calibration of the 1-m ruler has been verified:

1-m Ruler Equipment # A000853 Calibration due: 6/30/2021

The dimensions of the lead sheet have been measured by commercial tape measure:

Thickness 1" Length 12" Depth 12"

The lead sheet has been placed on the unyielding surface and a picture has been taken.

The test unit has been placed (centered) on the lead sheet and a picture has been taken.

The drop test release mechanism has been attached to the crane.

The percussion billet has been captured by the release mechanism.

The billet has been centered over the test unit and a picture has been taken.

The billet has been raised to height of 1 meter over the highest point of the test unit and a picture has been taken.

The billet was released and impacted the test unit.

All observable damage to the test unit caused by the percussion test has been recorded and pictures of the test unit after the percussion test have been taken.

Form has been signed and dated by the Quality Assurance Representative (QAR).

Comments:

I certify that the above tasks have been performed and that the observations and comments are correct.

[Signature]
Testing Technician

8/20/2019
Date

Michael B. Houston
Checked by (QAR)

08/20/2019
Date

All photographs will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed



LEAK TEST REPORT

Test Requested by: S. SHARPE	Allowable Leak Rate: $< 1.3 \times 10^{-4}$ Std-Atm-cc/s
Date Requested: 7/15/19	Date Required: -
Work Order Number: 3730855	Test Pressure Req. Across Boundary: -1 Atm
Item Tested: MK-42 SFC TU-1	Customer: NTRC
Specification: 49 CFR 173.469(a)(4)(i)	NDE 70, Rev: 7
Technique Used: INSIDE-OUT	Rev: 0 <input checked="" type="checkbox"/> Inside - Out <input type="checkbox"/> Outside - In

EQUIPMENT

LEAK DETECTOR		STANDARD LEAK	
Make and Model: ADIXEN ASM 340	Manufacturer: VT	Tracer Gas: He	
Serial Number: H20-1601393	Model: GPPT-7-He-118T	Serial Number: TP5750	
		Leak Rate: 3.97×10^{-7} Atm-cc/s @ -1 atm @ 23 °C	
TEST GAUGES		Correlation Formula: $[1 - (T_{cal} - T_{sur}) C_T] LR$	Temp Coefficient: 2.0 %/°C
Temp Gauges: ADO1952	Due: 9/6/19	Correlated LR: 3.72×10^{-7} Atm-cc/s @ -1 atm @ 19.9 °C	
Pressure Gauges: MTE-767	Due: CAL: 8/28/18	Calibration Due Date: 01/17/20	

RESULTS

☒ Quantitative ☐ Semi - Quantitative

MACHINE CALIBRATION		SYSTEM TEST CONDITIONS	
System Pressure: 1.9×10^{-2} mb		System Temperature: 19.9 °C <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Internal Gas	
Background: 5.0×10^{-10} Atm-cc/s		delta P Test Boundary: -1 Atm	
Leak Response: 3.7×10^{-7} Atm-cc/s		Tracer Gas: He	% Concentration: CALC
Minimum Detectable Leak: 1.0×10^{-8} Atm-cc/s		System Response Time: ~ 1 MIN	
System Sensitivity: 2.0×10^{-8} Atm-cc/s		System Response: $< 5.0 \times 10^{-8}$ Atm-cc/s	
Response Time: ~ 3 s		Duration of Test: ~ 2 MIN	

Aux. Equipment:

<input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT <input checked="" type="checkbox"/> SKETCH / DATA ATTACHED	System Leak Rate: $< 1.3 \times 10^{-4}$ Atm-cc/s @ -1 atm @ 25 °C w/ stated tracer gas
---	--

COMMENTS:

TU-1 LEAK TEST #3 PER ORNL/NTRC-084 (TEST #5 POST-PERCUSSION)

FINE LT

Test Conducted By: E. Viora	Level: III	Date: 8/20/19	Time: 2:15
-----------------------------	------------	---------------	------------

Form NDE 70-MS, Rev. 1 CNO2

IDMS: 21077



BOMBING TEST REPORT (Supplement)

Leak Test Report Number: 8/20/19-1 Allowable Leak Rate: $< 1.3 \times 10^{-4}$ atm·cc/s

Item(s) Tested: MK-42 SFC TU-1 POST-PERCUSSION

TRACER GAS BOMBING AND LEAK TEST

Bombing Pressure (psig): <u>30</u>	Tracer Gas: <u>He</u>	Bombing Time: <u>15 min</u>
Waiting Time (Sec): <u>< 3600</u>	Internal Volume (cc): <u>75.9</u>	
Measured Leak Rate: <u>$< 5.0 \times 10^{-7}$</u> atm cc/s	Calculated Leak Rate: <u>$< 1.3 \times 10^{-4}$</u> atm cc/s into vac. @ <u>25</u> °C	
Test Results: <input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT <input checked="" type="checkbox"/> CALCULATIONS / DATA ATTACHED		

COMMENTS:

Test Conducted By: E-VIA E. Val Level: III Date: 8/20/19

ASNT Formula		ASTM/CFR Formula	
R	5.00E-07 scc/s		
Pe	44.696 psia		
Po	14.696 psia		
Ma	28.7 g/mol		
M	4 g/mol		
T1	900 sec		
T2	3600 sec		
V	75.9 cc		
L	4.397E-05 scc/s	L	1.178E-04 scc/s
Part 1	3.582E-04		
Part 2	1.395E-03		
Part 3	9.944E-01		
Lcf	2.3512E-05 scc/s	Lcf	7.5053E-05 scc/s

RESULTS	
L (ASNT/MIL)	4.40E-05 scc/s air
L (ASTM/CFR)	4.40E-05 scc/s air



Note: formula is modified for uniformity; a = L/V and 3600 converts hours to seconds
Certificate Number 4121.0

Calculator Version 3/7/18

$$R = \left[\frac{LP_e}{P_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right] \times \left\{ 1 - e^{\left[-\frac{LT_1}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]} \right\} \times e^{\left[-\frac{LT_2}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]}$$

$$R = \frac{LP_e}{P_o} \left[1 - e^{\left(-\frac{L}{V} \right) T_1} \right] \times e^{\left(-\frac{L}{V} \right) T_2}$$

No 37308SS TU-1

E-Vior E-Max 7/19/19



ORNL Surveillance and Inspection Organization / Certificate #4121.01 /
Scope of Accreditation to ISO/IEC 17020:2012

Report Number: 8/20/19-2

LEAK TEST REPORT - BUBBLE TEST

Test Requested by: S. SHARPE	Customer: NTRC
Date Requested: 7/15/19	Date Required: -
Work Order Number: 3730855	NDE 70, Rev: 7 Tech, NDE 70 - BT Rev: 6
Item Tested: MK-42 SFC TV-1	Test Pressure Required: 15" Hg
Specification: 49 CFR 173.469(a)(4)(i)	Inspection Criteria: NO INDICATIONS @ 2 MIN
Technique Used: VAC BOX	Liquid Media Used: IMMERSIT C.M. 200 @ 20% SOLN
Test Gas Used: VAZ	Liquid Applicator Type: IMMERSION
Inspection Light Intensity: > 100 FC	Post Cleaning Method: DI RINSE / WIPE DRY
Other Apparatus Used: FLASHLIGHT	

Direct Pressure Technique ☐ Vacuum Pressure Technique ☒

Component Limits of Test:

TEST SEQUENCE #5, LT #3 - POST-PERCUSSION TEST
PER ORNL/NTRC-084

Component Test Site 5500 Component Installation Site -

Gauges				Test Pressure		Temperature	
Mfg	ID No	Calibration Date	Range	Beginning	End	Beginning	End
	A002124	10/14/18	0-30" Hg	-18" Hg	-18" Hg	19.9°C	19.9°C

Temperature Measuring Device

Mfg. OMEGA	Model HH804	Range K-TYPE	I.D. Number A251952
------------	-------------	--------------	---------------------

RESULTS ☒ ACCEPT ☐ REJECT POST CLEANING PERFORMED: ☒ Y ☐ N

Comments:

GROSS LT

Test Conducted By:

E-VIOR

Level: TIE

Insp. Date: 8/20/19

TEST FORM 2 – Heat Test Checklist

Test Plan ORNL/NTRC-084
Rev. 0

Test Unit 2

VERIFIED	TASK
<input checked="" type="checkbox"/>	The test unit tray has been placed in the furnace.
<input checked="" type="checkbox"/>	Two calibrated Type K thermocouples have been installed in the working area of the furnace and attached to the Fluke thermocouple reader.
<input checked="" type="checkbox"/>	Thermocouple calibration date: <u>11-12-18</u> Thermocouple ID: <u>Delta M. Corp Type K Thermocouples</u>
<input checked="" type="checkbox"/>	The furnace doors have been closed and the furnace has been turned on with a set point of 850° C.
<input checked="" type="checkbox"/>	Thermocouple readings have been made every 60 minutes for at least 3 hours with a calibrated thermocouple reader
<input checked="" type="checkbox"/>	Thermocouple reader model number <u>M303131</u> Calibration date: <u>11-12-18 → 11-12-19</u>
<input checked="" type="checkbox"/>	Any changes in the furnace set point during the three-hour preheat period have been recorded on TEST FORM 3.
<input checked="" type="checkbox"/>	Just prior to test unit insertion, a final preheat temperature recording was made.
<input checked="" type="checkbox"/>	Prior to opening the furnace ensure the operator has the proper PPE including gloves rated for work in 850 deg C atmosphere and a similarly rated face shield if required.
<input checked="" type="checkbox"/>	The furnace door has been opened, the test unit inserted, the furnace door closed, and the furnace activated with a set point of 850° C (1560° F) (or as adjusted during the preheat process).
<input checked="" type="checkbox"/>	When both thermocouple readings have reached 800° C (1475° F), the 10-minute thermal test was started.
<input checked="" type="checkbox"/>	Thermocouple readings were taken and recorded on TEST FORM 4 every 30 seconds for the duration of the 10-minute thermal test.
<input checked="" type="checkbox"/>	Adjustments were made to the furnace set point as directed by the test director.
<input checked="" type="checkbox"/>	When the 10-minute test period was finished, the furnace was turned off and furnace door was opened to the maximum extent possible.
<input checked="" type="checkbox"/>	As soon as conditions permitted, the test unit was removed from the furnace and allowed to cool naturally.
<input checked="" type="checkbox"/>	Any deformation or other unusual circumstances regarding the test or the test unit was recorded.
<input checked="" type="checkbox"/>	Form has been signed and dated by the Quality Assurance Representative (QAR).

Comments: Pictures were taken, no deformation observed.
Furnace was allowed to heat-backup after TU-2 removal.

I certify that the above tasks have been performed and that the observations and comments are correct.

Testing Technician [Signature] Date 09/27/2019 Checked by (QAR) Michael B. Houston Date 09/27/2019

*All photographs will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed

TEST FORM 3 – Heat Test Preheat Data Sheet

Test Plan ORNL/NTRC-084
Rev. 0

Test Unit 2

VERIFIED

TASK



Record the temperature in the furnace every thirty (30) minutes for the duration of the preheat (at least 3 hours):
Form has been signed and dated by the Quality Assurance Representative (QAR).

Time (min)	°C Thermocouple 1 (°F)	°C Thermocouple 2 (°F)
0	853.9 (1569.04)	853.7 (1568.7)
30	856.2 (1573.2)	854.1 (1569.3)
60	854.8 (1570.7)	853.9 (1569.2)
90	853.7 (1568.6)	850.7 (1563.4)
120	855.1 (1571.1)	850.4 (1562.7)
150	856.3 (1573.2)	852.8 (1567.2)
180	857.2 (1574.9)	852.6 (1566.8)

Comments:

I certify that the above tasks have been performed and that the observations and comments are correct.

Testing Technician

Date

Checked by (QAR)

Date

*All photographs/movies will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed

TEST FORM 4 – Heat Test Data Sheet

Test Plan ORNL/NTRC-084
Rev. 0

Test Unit 2

VERIFIED ☒

TASK

Record the temperature in the furnace every 30 seconds for the duration of the test:

Form has been signed and dated by the Quality Assurance Representative (QAR).

Time (min:sec)	Thermocouple 1 (Celsius)	Thermocouple 2 (Celsius)
00:00	822.2	831.8
00:30	820.9	833.9
01:00	825.4	833.7
01:30	825.8	836.2
02:00	824.2	841.7
02:30	826.4	837.9
03:00	826.2	844.5
03:30	829.9	843.3
04:00	833.6	843.2
04:30	833.4	841.8
05:00	832.3	844.4
05:30	831.9	848.6
06:00	832.3	845.1
06:30	835.6	848.9
07:00	832.3	847.2
07:30	834.3	850.0
08:00	832.9	849.9
08:30	832.9	852.9
09:00	840.4	850.6
09:30	835.1	850.3
10:00	829.1	849.8

Comments:

I certify that the above tasks have been performed and that the observations and comments are correct.


Testing Technician

09/27/2019
Date

Michael B. Houston
Checked by (QAR)

09/27/2019
Date

*All photographs/movies will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed

TEST FORM 2 – Heat Test Checklist

Test Plan ORNL/NTRC-084
Rev. 0

Test Unit 3

VERIFIED

TASK

- ☒ The test unit tray has been placed in the furnace.
- ☒ Two calibrated Type K thermocouples have been installed in the working area of the furnace and attached to the Fluke thermocouple reader. Delta M-Co P TYPE K
- ☒ Thermocouple calibration date: 11-12-18 Thermocouple ID: Thermocouples
- ☒ The furnace doors have been closed and the furnace has been turned on with a set point of 850° C.
- ☒ Thermocouple readings have been made every 60 minutes for at least 3 hours with a calibrated thermocouple reader
- ☒ Thermocouple reader model number M303131 Calibration date: 11-12-18 → 11-12-19
- ☒ Any changes in the furnace set point during the three-hour preheat period have been recorded on TEST FORM 3.
- ☒ Just prior to test unit insertion, a final preheat temperature recording was made.
- ☒ Prior to opening the furnace ensure the operator has the proper PPE including gloves rated for work in 850 deg C atmosphere and a similarly rated face shield if required.
- ☒ The furnace door has been opened, the test unit inserted, the furnace door closed, and the furnace activated with a set point of 850° C (1560° F) (or as adjusted during the preheat process).
- ☒ When both thermocouple readings have reached 800° C (1475° F), the 10-minute thermal test was started.
- ☒ Thermocouple readings were taken and recorded on TEST FORM 4 every 30 seconds for the duration of the 10-minute thermal test.
- ☒ Adjustments were made to the furnace set point as directed by the test director.
- ☒ When the 10-minute test period was finished, the furnace was turned off and furnace door was opened to the maximum extent possible.
- ☒ As soon as conditions permitted, the test unit was removed from the furnace and allowed to cool naturally.
- ☒ Any deformation or other unusual circumstances regarding the test or the test unit was recorded.
- ☐ Form has been signed and dated by the Quality Assurance Representative (QAR).

Comments:

No unusual deformation observed, pictures were taken.
After TU-2 removal, the furnace was allowed to heat-back-up
above test temp. range before TU-3 was inserted.

I certify that the above tasks have been performed and that the observations and comments are correct.


Testing Technician

09/27/2019
Date

Michael B. Houston
Checked by (QAR)

09/27/2019
Date

*All photographs will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed

TEST FORM 3 – Heat Test Preheat Data Sheet

Test Plan ORNL/NTRC-084
Rev. 0

Test Unit 3

VERIFIED



TASK

Record the temperature in the furnace every thirty (30) minutes for the duration of the preheat (at least 3 hours):
Form has been signed and dated by the Quality Assurance Representative (QAR).

Time (min)	°C Thermocouple 1 (°F)	°C Thermocouple 2 (°F)
0	853.9 (1569.04)	853.7 (1568.7)
30	856.2 (1573.2)	854.1 (1569.3)
60	854.8 (1570.7)	853.9 (1569.2)
90	853.7 (1568.6)	850.7 (1563.4)
120	855.1 (1571.1)	850.4 (1562.7)
150	856.3 (1573.2)	852.8 (1567.2)
180	857.2 (1574.9)	852.6 (1566.8)

Comments:

I certify that the above tasks have been performed and that the observations and comments are correct.

[Signature]
Testing Technician

09/27/2019
Date

Michael B. Houston
Checked by (QAR)

09/27/2019
Date

*All photographs/movies will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed

TEST FORM 4 – Heat Test Data Sheet

Test Plan ORNL/NTRC-084

Rev. 0

Test Unit 3

VERIFIED


TASK


Record the temperature in the furnace every 30 seconds for the duration of the test:

Form has been signed and dated by the Quality Assurance Representative (QAR).

Time (min:sec)	Thermocouple 1 (Celsius)	Thermocouple 2 (Celsius)
00:00	822.5	834.9
00:30	822.6	832.9
01:00	823.0	829.2
01:30	821.0	838.3
02:00	830.0	837.1
02:30	833.5	836.9
03:00	832.3	836.0
03:30	835.9	840.0
04:00	834.3	843.4
04:30	834.7	844.4
05:00	AA 86 836.3	846.9
05:30	841.4	847.9
06:00	839.7	850.5
06:30	843.3	844.7
07:00	839.8	848.1
07:30	843.6	849.7
08:00	840.6	851.2
08:30	845.4	850.3
09:00	845.1	853.8
09:30	844.3	856.6
10:00	847.3	853.5

Comments:

I certify that the above tasks have been performed and that the observations and comments are correct.


Testing Technician

09/27/2019
Date

Michael B. Houston
Checked by (QAR)

09/27/2019
Date

*All photographs/movies will be uniquely identified with test unit, date and time to ensure that the proper sequence can be reconstructed



LEAK TEST REPORT

Test Requested by: J. SHARPE	Allowable Leak Rate: $< 1.3 \times 10^{-4}$ Std-Atm-cc/s
Date Requested: 7/15/19	Date Required: -
Work Order Number: 3730855	Test Pressure Req. Across Boundary: -1 Atm
Item Tested: 20th MK 42 SFC	Customer: NTRC
Specification: 49 CFR 173.469(a)(4)(i) NDE 70, Rev: 7	Technique Used: INSIDE-OUT Rev: 0 <input checked="" type="checkbox"/> Inside - Out <input type="checkbox"/> Outside - In

EQUIPMENT

LEAK DETECTOR		STANDARD LEAK	
Make and Model: ADITEN ASM 340	Manufacturer: VTI	Tracer Gas: He	
Serial Number: HLB 1601393	Model: GPT-8-He-118T	Serial Number: TP5154	
		Leak Rate: 5.24×10^{-8} Atm-cc/s @ -1 atm @ 22.2 °C	
TEST GAUGES		Correlation Formula: $[1 - (T_{cal} - T_{surp}) C_T] LR$	Temp Coefficient: 2.0 %/°C
Temp Gauges: A005947	Due: 9/12/20	Correlated LR: 5.4×10^{-8} Atm-cc/s @ -1 atm @ 23.8 °C	
Pressure Gauges: A002110	Due: 8/13/20	Calibration Due Date: 01/18/20	

RESULTS

☒ Quantitative ☐ Semi - Quantitative

MACHINE CALIBRATION		SYSTEM TEST CONDITIONS	
System Pressure: 1.8×10^{-2} mA		System Temperature: 24 °C <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Internal Gas	
Background: $< 5.0 \times 10^{-10}$ Atm-cc/s		delta P Test Boundary: -1 Atm	
Leak Response: 5.4×10^{-8} Atm-cc/s		Tracer Gas: He	% Concentration: CALC
Minimum Detectable Leak: 1.0×10^{-9} Atm-cc/s		System Response Time: ~ 2 min	
System Sensitivity: 2.0×10^{-9} Atm-cc/s		System Response: 1.4×10^{-8} Atm-cc/s	
Response Time: ~ 3 s		Duration of Test: ~ 3 min	

Aux. Equipment:

☒ ACCEPT ☐ REJECT ☒ SKETCH / DATA ATTACHED

System Leak Rate: $< 1.3 \times 10^{-4}$ Atm-cc/s @ -1 atm @ 25 °C

COMMENTS:

TU-2, TU-3 POST-HEAT LEAK TEST

FINE-LT

Test Conducted By: E. Viora	Level: III	Date: 10/3/19	Time: 9:40
-----------------------------	------------	---------------	------------



BOMBING TEST REPORT (Supplement)

Leak Test Report Number: 10/3/19-1

Allowable Leak Rate: $\leq 1.3 \text{ E-}4$

Item(s) Tested: TU-2, TU-3 MK 42 SFC

TRACER GAS BOMBING AND LEAK TEST

Bombing Pressure (psig): 30

Tracer Gas: He

Bombing Time: 15 min

Waiting Time (Sec): < 3600

Internal Volume (cc): 81.1

Measured Leak Rate: < $5.0 \text{ E-}7$

Atm cc/s

Calculated Leak Rate: < $1.3 \text{ E-}4$ Atm cc/s into vac. @ 25 °C

Test Results: ☒ ACCEPT ☐ REJECT ☒ CALCULATIONS / DATA ATTACHED

COMMENTS:

POST-HEAT LEAK TEST

Test Conducted By:

E. VIOAR

Level: IIA

Date: 10/3/19

ASNT Formula		ASTM/CFR Formula	
R	5.00E-07 scc/s		
Pe	44.696 psia		
Po	14.696 psia		
Ma	28.7 g/mol		
M	4 g/mol		
T1	900 sec		
T2	3600 sec		
V	81.1 cc		
L	4.548E-05 scc/s	L	1.218E-04 scc/s
Part 1	3.705E-04		
Part 2	1.351E-03		
Part 3	9.946E-01		
Lcf	3.0526E-05 scc/s	Lcf	8.17639E-05 scc/s

RESULTS

L (ASNT/MIL)	4.55E-05 scc/s air	1.22E-04 scc/s He
L (ASTM/CFR)	4.55E-05 scc/s air	1.22E-04 scc/s He

Calculator Version 3/2/18



Certificate Number 4121.0
Note: formula is modified for uniformity; a = L/V and 3600 converts hours to seconds

$$R = \left[\frac{LP_e}{P_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right] \times \left[1 - e^{-\left[\frac{LT_1}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right]} - \left[\frac{LT_2}{VP_o} \left(\frac{M_A}{M} \right)^{\frac{1}{2}} \right] \right] \times e$$

$$R = \frac{LP_e}{P_o} \left[1 - e^{-\left(\frac{L}{V} \right) T_1} \right] \times \left[e^{-\left(\frac{L}{V} \right) T_2} \right]$$

NO: 3730855 TU-2, TU-3

E-VIOR *[Signature]* 7/19/19



LEAK TEST REPORT - BUBBLE TEST

Test Requested by: J. SHARPE	Customer: NTRC
Date Requested: 7/15/19	Date Required: —
Work Order Number: 3730855	NDE 70, Rev: 7 Tech, NDE 70 - BT Rev: 0
Item Tested: TU-2, TU-3 MK42 SFC	Test Pressure Required: -15" Hg
Specification: 49 CFR 173.469(a)(4)(i)	Inspection Criteria: NO BUBBLES @ 2 MIN
Technique Used: VAC BOX	Liquid Media Used: IMMERSION CIM 200 @ 20%
Test Gas Used: VAC	Liquid Applicator Type: IMMERSION
Inspection Light Intensity: >100 FC	Post Cleaning Method: RINSE
Other Apparatus Used: FLASHLIGHT	

Direct Pressure Technique <input type="checkbox"/>	Vacuum Pressure Technique <input checked="" type="checkbox"/>
--	---

Component Limits of Test:

TEST SEQUENCE #3 PER ORNL/NTRC-084

POST-HEAT LT

Component Test Site 5300				Component Installation Site			
Gauges				Test Pressure		Temperature	
Mfg	ID No	Calibration Date	Range	Beginning	End	Beginning	End
	A005124	10/4/18	0-30" Hg	15" Hg	18" Hg	23.8°C	23.8°C

Temperature Measuring Device

Mfg. OMEGA	Model H1804	Range K-TYPE	I.D. Number A005947
------------	-------------	--------------	---------------------

RESULTS	<input checked="" type="checkbox"/> ACCEPT <input type="checkbox"/> REJECT	POST CLEANING PERFORMED: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N
---------	--	---

Comments:

GROSS LT

Test Conducted By: R. VIDAL	Level: II	Insp. Date: 10/3/19
-----------------------------	-----------	---------------------

APPENDIX C. WELD INSPECTION REPORT

ORNL – Oak Ridge Sites Weld Examination Report

Job Title: SPECIAL FORM POWDER SHIPPING CONTAINER		Work Order: 3665AC63
Specification: SEE NDE-21-REV-3		Examination Procedures (Rev.): NDE-21-REV-3
Drawing No: M 12175 CP 813 E	Line No: N/A	Auxiliary Light Equipment: FLASHLIGHT
Sketch or Weld Map No./Other: SEE DRAWING		

Weld No.	Materials			WPS	Welder Stencil	Exams	Inspector/ Level	Time & Date of Inspection	Results	Comments
	Base A *Size and Heat	Base B *Size and Heat	Filler *Size and Heat							
W-1	bottom plug 304L HT-E181838	inner /tube 304L304L HT-11R648	ER308/308L .030" HT-DAFS	GT88-1[PP]	3V	1,6	Mark A Denton Digitally signed by Mark A Denton Date: 2019.06.16 06:40:55 -0400'	6-16-19	8 SAT	CAPSULE # 1
W-2	top plug 304L HT-E181838	inner /tube 304L304L HT-11R648	ER308/308L .030" HT-DAFS	GT88-1[PP]	3V	1,6	Mark A Denton Digitally signed by Mark A Denton Date: 2019.06.16 06:41:01 -0400'	6-16-19	8 SAT	CAPSULE # 1
-----	-----	[SURROGATE #	TH228TST]	-----	-----	-----	-----	-----	-----	-----
W-1	bottom plug 304L HT-E181838	inner /tube 304L304L HT-11R648	ER308/308L .030" HT-DAFS	GT88-1[PP]	3V	1,6	Mark A Denton Digitally signed by Mark A Denton Date: 2019.06.16 06:41:08 -0400'	6-16-19	8 SAT	CAPSULE # 2
W-2	top plug 304L HT-E181838	inner /tube 304L304L HT-11R648	ER308/308L .030" HT-DAFS	GT88-1[PP]	3V	1,6	Mark A Denton Digitally signed by Mark A Denton Date: 2019.06.16 06:41:14 -0400'	6-16-19	8 SAT	CAPSULE # 2
-----	-----	[SURROGATE #	AcB-014]	-----	-----	-----	-----	-----	-----	-----
W-1	bottom plug 304L HT-E181838	inner /tube 304L304L HT-11R648	ER308/308L .030" HT-DAFS	GT88-1[PP]	3V	1,6	Mark A Denton Digitally signed by Mark A Denton Date: 2019.06.16 06:41:21 -0400'	6-16-19	8 SAT	CAPSULE # 3
W-2	top plug 304L HT-E181838	inner /tube 304L304L HT-11R648	ER308/308L .030" HT-DAFS	GT88-1[PP]	3V	1,6	Mark A Denton Digitally signed by Mark A Denton Date: 2019.06.16 06:41:28 -0400'	6-16-19	8 SAT	CAPSULE # 3
-----	-----	[SURROGATE #	D1SFC]	-----	-----	-----	-----	-----	-----	-----

*Pipe Size or Plate Thickness				Penetrant Materials Batch No:	
1. Joint Preparation and Fit-Up	5. P.T. Final Pass	9. In Process per B31.3, paras. 341.4.1(b)(1) and 344.7, requires engineers' approval		SKL-SP2	N/A
2. Visual Root Pass	6. Final Pass Visual			SKC-S	N/A
3. P.T. Root Pass	7. Final R.T.			SKD-S2	N/A
4. Intermediate Visual	8. A.W.S. QC1 Final Acceptance	10. Other: _____			

Note: This form is for use with Type II Visible, Solvent Removable only. PT reject indications must record type, location and extent.

Certificate of Test

PRODEC QUALITY

Page: 1

HEAT E181838 ORDER 684829/ 04 BOL 0245602 * CERTIFICATION * 12/17/18

SHIP TO:
ROLLED ALLOYS BAR CENTER
711 PHOENIX LAKE AVENUE

STREAMWOOD 601070000

Job#57122-02

----- YOUR ORDER & DATE -----
0168505-STR 11/01/18 CUST# 0773001 CUST TAG#0009151

----- ITEM DESCRIPTION -----
GRADE 304L/304 PRODEC QUALITY Ship Condition CONDA
Size 304L RND CFA CONDA 2.2500 x 144.000 RL
Country of Mfg.: UNITED KINGDOM Country of Mfg.: UNITED STATES
No weld repair
Free of mercury contamination, Free of radiation contamination
No WEEE relevant substances; Meets RoHS-2011/65/EU and 2015/863

Total Bundles 1 Total Weight 2498 Approx. Hot Red. Ratio 8:1

WO 2091731 Bundles: 1A

----- SPECIFICATIONS -----
MFG TO FINISHED BAR IN THE USA FROM BILLETS IMPORTED UNITED KINGDOM
AMS 5639J, 5647K SAE AMS-QQ-S-763D
ASME BPVC.II.A-2017 SA-182 ASME SA-479 2017 Ed.
ASME SA-484 2017 Ed. ASME SA-320 B8 CL1, 2017 Ed.
ASME SA-193 B8 2017 Edition ASTM A182/A182M 18a
ASTM A262 15 Practice A/E ASTM A276/A276M 17
ASTM A314 15 ASTM A479/A479M 18
ASTM A484/A484M 18a ASTM A320 17a B8 Class 1
ASTM A193 16 B8 Solution Annealed Condition
NACE MR0175-09, ISO 15156:09 DFARS 252.225.7009 10/4/11
Federal Spec QQ-S-763F UNS S30400, AISI 304
UNS S30403, AISI 304L Free of Cont.carbide network
EN 10204 Type 3.1 Document RA-53 RAM 304L
Prodec Quality ASTM F899 12b
NACE MR0103-10 DFARS 225.7002-3(B)(1)
QTC is a prolongation of bar 1.4301 X2CrNi18-9 304
No WEEE relevant substances Sol Ann 1900F min/WQ
Bars are Eddy Current tested
Sol Anneal at 1900F min/ Water Quench

----- MECHANICAL & OTHER TESTS -----
Hardness as shipped 174 HB
Hardness as shipped (86 HRC)
Grain size 7.5 Tensile strength,KSI (MPa) 88.7 (612)
Micro OK 0.2% Yield Strngth,KSI(MPa) 38.3 (264)
Intergranular corrosion OK
Elongation % in 4D 54.4
Reduction of area % 76.0

-- Continued --



M.F. Marquis

5

WLPSSW089020

481122

m118459



MILL INSPECTION CERTIFICATE

EN 10204 3.1

CHANGSHU WALSH SPECIALTY STEEL CO., LTD.

CUSTOMER	TA CHEN STEEL SPECIALTY CO., LTD.	HEAT NO.	11840
DATE	2018/10/07	SPECIFICATION	ASTM A511-18WALSH SPECIALTY CHINA (CHINA) ASTM A511-18
COUNTRY	CHINA	CERTIFICATE NO.	20181072000331
DELIVERY CONDITION	COLD FINISHED SOLUTION ANNEALED AND PICKLED	GRADE	TP304L
CHEMICAL COMPOSITION (WT%)			

ELEMENTS	C	SI	Mn	P	S	Ni	Cr	Mo	N	Cu	Ti	Nb	Nb+Ta	Co	V	B	Al	Sn	Pb	As	Sb	Fe	Bi	Zr	Al+Ti	PREN	Ferrite content
	SPECIFICATION																										
	min	0.050	0.030	0.060	0.005	0.020	8.000	16.500	0.005		0.005																
	max	0.030	1.000	2.000	0.040	0.030	19.500	20.000	1.000		1.000																
RESULTS																											
	0.018	0.270	1.680	0.028	0.024	0.009	18.296	0.190		0.565																	

SIZE	BUNDLE NO.	PIECES	WEIGHT	TS	TS	ELONG	HARDNESS	FLATTENING	FLANGING	LC	REDUCTION	GRAN	LEN	INTROSTATIC	EDDY	ULTRASONIC
				MPa	MPa	%	HRB	TEST	TEST	TEST	%	SIZE	LEN	MPa	TEST	TEST
0017-1471-146mm	1423-31	1	22.14	63	391	335	55.5	61.5812.5	1	GOOD	GOOD	58	1	20180511-423	1	GOOD
211222091812-7315	1423-31	1	22.14	63	391	335	55.5	61.5812.5	1	GOOD	GOOD	58	1	20180511-423	1	GOOD
211412081812-7315	1423-44	8	102.41	483	601	372	55	60.66	1	GOOD	GOOD	80	1	20180716-483	1	GOOD
234105001812-7315	1423-48	2	45.13	258	356	283	56	75.5715.5	1	GOOD	GOOD	65	1	20180716-483	1	GOOD
2701081812-7315	1423-51	21	488.35	381	617	338	56.5	63.83	1	GOOD	GOOD	56	1	20180810-416	1	GOOD
230701081812-7315	1423-55	4	64.4	144	366	289	55	78.78	1	GOOD	GOOD	59	1	20180810-440	1	GOOD
TOTAL		31	789.84		1157											

AS PER PROFORMA INVOICE NO. 1714-1
NO REPAIR BY WELDING
MATERIAL FREE FROM MERCURY CONTAMINATION
MATERIAL COMPLIANT WITH ROHS DIRECTIVE 2002/95/EC
COUNTRY OF ORIGIN: CHINA
COUNTRY OF MANUFACTURE: CHINA
ET STANDARD PRACTICE: ASTM A511
THE UNTESTED ENDS ARE DISPOSED AFTER USE
ANNEALING TEMPERATURE: 1000°C WATER QUENCHED
CONFORMS TO CHEMICAL AND MECHANICAL REQUIREMENTS OF ASTM A511-18WALSH SPECIALTY CHINA (CHINA) ASTM A511-18
C TEST PER ASTM A511-18WALSH SPECIALTY CHINA (CHINA) ASTM A511-18

QUALITY MANAGER
Sum Bin

ADDRESS: 24 HANGANG ROAD, HANGU TOWN, CHANGSHU CITY, JIANGSU PROVINCE, CHINA 215119 TEL: +86-512-82596260 FAX: +86-512-82596267
Form No: WLS-01-001 (Rev. 0)

NOTES


1. WELD PLUG OPPOSITE GROOVED END IN PLACE PER ORNL WPS 307- INSPECT VISUALLY
2. LEAK TEST LINER BY METHOD SENSITIVE TO $< 1 \times 10^{-7}$ CC/SEC
3. ALL MACHINE SURFACES TO BE $32 \sqrt{}$ NOT NECESSARY TO MACHINE TUBING SURFACES
4. COLLET REFERENCE SK-89A
5. FUNNEL REFERENCE SK-85A

QA VERIFICATION REQUIREMENTS Mechanical & Structural (Applicable to UCONIS manufacture only)		
Ref: QA-L-2-107 QAA/QAP		
Documentation Required	Procedure No. When Required	Note 1
IDENTITY		X
MATERIAL IDENT. REPORT		
UCONIS MAT'L INSP. REPORT		
SHOP MFG & INSP. PLANS		
MAT'L & PARTS TRAVELERS		X
WELD & BRAZE INSP. REPORTS		X
HEAT TREAT REPT. (SCHEDULE)		
PRESSURE TEST REPORT		
LEAK TEST REPORT		X
CLEANING REPORT		
INSTALLATION & INSP. PLAN		
FUNCTIONAL TEST REPORT		
CERT. OF COMPLIANCE		
DEVIATION REQUESTS		X
NONCONFORMANCE REPORTS		X
DIMENSIONAL REPORT	QA-L-2-107	X
JAEA SPECIAL FORM TEST		X
SHOP PRINT TO FIELD ENGR		X

Note 1: Show an "X" in the item no. of items to which the document requirements are to be applied.

QA Coordinator *J. Lewis* Date *6-12-81*

UCON-NEHA (S 11-79)



SPECIAL FORM-POWDER SHIPPING CAN. C-RD-3095	
REF: SK-83A, 83B, 83C (SIMILAR TO DETAILS SHOWN HERE)	
REFERENCE DRAWINGS	NUMBER
OAK RIDGE NATIONAL LABORATORY OPERATED BY UNION CARBIDE CORPORATION OAK RIDGE, TENNESSEE	
TRANSURANIUM PROCESSING PLANT BLDG. 7920 NO.	
SPECIAL FORM POWDER SHIPPING CONTAINER AND ACCESSORIES	
SUBMITTED <i>S. O. Lewis</i>	ACCEPTED <i>J. Lewis</i> 7/1/81
APPROVED <i>J. Lewis</i> 6/12/81	REV.
M 12175	CP 813



TOLERANCES UNLESS OTHERWISE SPECIFIED:	NO.	REVISIONS				DATE	APPD	APPD
		DRAWN	DATE	SUBMITTED	DATE			
FRACTIONS $\pm \frac{1}{32}$								
DECIMALS \pm								
ANGLES $\pm 0^\circ 30'$								
SCALE: 1"=1"								

Fab File # or MWP #	Part Name	Drawing #	Rev.	Part #	Page
N/A	SPECIAL FORM POWDER SHIPPING CONTAINER AND ACCESSORIES	M12175CP813	1	N/A	1 of 2
Job Description: SPECIAL FORM POWDER SHIPPING CONTAINER AND ACCESSORIES Inspection # A007367					
P.O. Or Req. #		Material Type	Heat Number	Serial Number(s)	
N/A		N/A	N/A	AS LISTED	
Temperature		Relative Humidity	Initial Inspection or Re-inspection?		
20° C		45%	Initial inspection <input type="checkbox"/> Re-inspection No. <u>3</u>		
QC #*	Inspection Result	Drawing Requirement		Inspection Method	
		LINER 1			
1	SEE	Ø 2.000		OUTSIDE MICROMETER	
2	PAGE	.065 ± .002		POLY MICROMETER	
3	TWO	3 ± 1/32		TRIMOS HEIGHT GAGE	
4		1/2 ± 1/32		OPTICAL COMPARATOR	
5		GROOVE .010 x 90°		OPTICAL COMPARATOR	
REF.		TOP ID		INSIDE MICROMETER	
REF.		BOTTOM ID		INSIDE MICROMETER	
		BOTTOM PLUG 1			
6		.062		TRIMOS HEIGHT GAGE	
7		.062 ± .002		POLY MICROMETER	
8		.375		TRIMOS HEIGHT GAGE	
9		.0015 - .0025 INFERENCE FIT		CALCULATIONS	
10		1.870		OUTSIDE MICROMETER	
		TOP PLUG 1			
REF.		OD		OUTSIDE MICROMETER	
11		.0015 - .0025 INFERENCE FIT		CALCULATIONS	
12		10°		OPTICAL COMPARATOR	
13		.062 ± .002		POLY MICROMETER	
14		.062		TRIMOS HEIGHT GAGE	
15		.375		TRIMOS HEIGHT GAGE	
16		.125		OPTICAL COMPARATOR	
Inspection Results					
All inspection tools were verified for accuracy prior to and after their use		<input checked="" type="checkbox"/> Yes	Inspector: <i>Dean Freeman</i>		Date: <i>5/30/2019</i>
Meets Drawing Requirements		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Inspector Supervisor: <i>Michael J. Davis</i>		Date: <i>5/30/2019</i>

Fab File # or MWP #	Part Name	Drawing #	Rev.	Part #	Page
N/A	SPECIAL FORM POWDER SHIPPING CONTAINER AND ACCESSORIES	M12175CP813	1	N/A	2 of 2
Serial Number					
QC #*	1	2	3		
1	2.001	2.001	2.001		
2	.066	.066	.066		
3	3	3	3		
4	1/2	1/2	1/2		
5	OK	OK	OK		
REF	1.8692	1.8690	1.8689		
REF	1.8693	1.8689	1.8691		
6	.062	.062	.062		
7	.062	.062	.062		
8	.376	.376	.376		
9	.0025	.0025	.0023		
10	1.8718	1.8714	1.8712		
REF	1.8714	1.8712	1.8712		
11	.0022	.0022	.0023		
12	10	10	10		
13	.062	.062	.062		
14	.062	.062	.062		
15	.377	.376	.376		
16	.129	.130	.127		

*Supplemental inspections should be listed starting a new sequential series and adding the initials "SI" next to each entry

**APPENDIX D. LEAK TEST NDT EXAMINER TECHNICIAN
CERTIFICATION**



The American Society for Nondestructive Testing, Inc.

Be it known that


Eric Steven Vidal

has met the established and published Requirements for Certification by ASNT as

NDT Level III

in the following Nondestructive Testing Methods:

<u>Method</u>	<u>Issue Date</u>	<u>Expiration Date</u>
Leak Testing	7/17	7/22
Liquid Penetrant Testing	5/17	5/22



208178

Certificate Number

ASNT President

Certification Management Council Chair

This certificate is the property of ASNT, is not official without ASNT's raised gold seal and is subject to revocation prior to the listed expiration date.
This certificate should be verified on the ASNT website or by contacting the ASNT Technical Services Department.

APPENDIX E. LEAK TESTING PROCEDURE

ORNL Leak Test Procedure (NDE-70 R.7) IS not available for public release.

APPENDIX F. CALIBRATION RECORDS

FO-IC-157

ORNL Work Order: 3548806



COMPLETED

v2.11



* 3 5 4 8 8 0 6 *



* D A T A C Q - M 3 0 3 1 3 1 *



* M 3 5 4 8 8 0 6 *

Equipment: DATAQ-M303131 / Data acquisition-SCXI

Location/Add'l Loc: 5700~3~I309 /

Work Description:

CB-V-IC-4004-X Frequency: 1-Y

Service Org:

CB-V-IC-Calibration-G4-XF-1P-4H Variable Type

IC-RESCH/INST

Act	Trade	Task	Comment	Est. Hrs	Start Date	End Date	Comp.
10	INSTTECH	Calibration		4	11/13/18	12/12/18	

Sched Start/End: 11/13/2018 / 12/12/2018

Req. Start/End:

Importance:

Configuration ID:

WO Additional Information/Documents

 Status:
 Cycle Time:
 Custodian:
 Alternate ID:

 Ready To Work
 N
 00984677: Adeniyi, Abiodun Idowu

 Cost Code: 35304D81
 Surv Req:

 Grade: 4
 Priority: 7
 Type: CAL
 Filepoint: IC-A4

Equipment: Equipment Location: 5700~3~I309 Addl. Location:
 Parent ID: Description:
 Manufacturer: International Instruments Model: NI cDAQ-9184
 Company
 Serial Number: 01B68499 Fammis FLD:

Equipment Customs:

MTEW : Not Applicable

Input : Type K TC Range : 0-2400F

Contact	Name	Building	Room	Phone	Pager
Requested by:	Adeniyi, Abiodun Idowu	5700	I309	865-576-2750	
Assigned To:	Walker, Drew P	4500S	B048	865-574-5589	
Assigned by:	Mcbee, Anthony	2033	139	865-574-6293	
Fac Ops Manager:	Blackburn, Donald Lee	3500	004A	865-576-0502	

Safety Review:

(Grade 4 only) Answer the following for this job & work location. Any Yes answer - contact the Task Leader for further instructions before starting work.

- | | | | | | |
|----|-----|--------------------------|----|-------------------------------------|--|
| 1. | Yes | <input type="checkbox"/> | No | <input checked="" type="checkbox"/> | Will I be exposed to hazards at the work location that are not associated with the job? |
| 2. | Yes | <input type="checkbox"/> | No | <input checked="" type="checkbox"/> | Will I use chemicals or materials for which I do not understand the hazards? |
| 3. | Yes | <input type="checkbox"/> | No | <input checked="" type="checkbox"/> | Will the job require Personal Protective Equipment (PPE) that I do not normally use or have not been trained to use? |
| 4. | Yes | <input type="checkbox"/> | No | <input checked="" type="checkbox"/> | Will bystanders or passersby be exposed to job hazards? |
| 5. | Yes | <input type="checkbox"/> | No | <input checked="" type="checkbox"/> | Will any permits be required? |
| 6. | Yes | <input type="checkbox"/> | No | <input checked="" type="checkbox"/> | Is there any aspect of the work that I do not feel safe performing? |

HPI Pre-Check Questions: Each worker should confirm readiness to begin the work (regardless of the Work Grade) by asking these or similar questions.

- | | |
|--|---|
| • What am I (are we) doing? | • How are we going to respond in the event of a local, area or equipment alarm? |
| • What are the hazards? What PPE is required? | • What is the worst thing that can happen? How can I/we prevent it? What will I/we do if it does occur? |
| • Are there lessons learned that should be considered? | • What communication is needed during the task? How will we communicate? |

Calibration:

Seq	LABEL	INPUT	OUTPUT	TOLERANCE	ASFOUND	Pass / Fail / N/A	As Left	Pass / Fail / N/A
1	This captures diagnosis of calibration only. Refer to equipment documentation to see actual calibration data. 0-Pass 1-Pass w/Adj	0 *		0 to +1	*	0 P	0 P	

Nov 21, 2018 8:57:11 AM



* M 3 0 3 1 3 1 - M 3 5 4 8 8 0 6 *

1 of 2

ORNL Work Order: 3548806

v2.11



Seq	LABEL	INPUT	OUTPUT	TOLERANCE	ASFOUND	Pass / Fail / N/A	As Left	Pass / Fail / N/A
	2-Fail							

Set Name: Calibration Effective: 11-12-18 Calibration Status: Incomplete

Standards Used: A004172
A001277
A001278

PMT: As Found Reading: _____ As Left Reading: _____ N/A: /

Last Calibration
 No Data Available

Signatures:

Person Notified: _____ Date/Time: _____ N/A []

Accepted By: _____ Date: _____ N/A []

Reviewed by: [Signature] Date: 11/28/18 N/A []

Closing: Completed: ☒ Yes ☐ No Date Completed: 11-21-18

Comments: Performed calibrations of DAA and TC Batch.
TC certificate for manufacturer is included in attached.
11-21-18

Delay: _____ Est. Hours: _____ Date: _____

Time Sheet							
Act. #	Badge - Name	Date	Hours	Act. #	Badge - Name	Date	Hours

Booked Hours

Note: Only 10 time records will be displayed; See Total WO Booked Hours field for total hours.

Act. #	Badge - Name	Date	Hours
10	03026591 - Walker, Drew P	Nov 12, 2018	0.5
	03026591 - Walker, Drew P		3
Total Hours for Activity 10			3.5

Total Estimated Hours	Total Booked Hours
4	3.5

Nov 21, 2018 8:57:11 AM



2 of 2

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): 3026591 DATE: 11-12-18

WORK ORDER #: 3548806 ID#: M303131

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

STANDARDS:	
ID Number: A004172	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Page 1-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

STANDARDS:	
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 2-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 3-11



INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(s)/BADGE(s): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

UUT Make/Model/Range:										
Input Unit:	Expected Response		Channel # 13		Channel # 14		Channel # 15		Channel # 16	
	From	To	As-Found	As-Left	As-Found	As-Left	As-Found	As-Left	As-Found	As-Left
0 F			0.066		0.173		0.182		0.141	
400			400.144		400.266		400.177		400.173	
800			800.166		800.228		800.175		800.125	
1200			1200		1200		1200		1200	
1600			1600		1600		1600		1600	
2000			2000		2000		2000		2000	
2400			2400		2400		2400		2400	

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 4-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 5-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: ID#:

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 6-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 7-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 8-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 9-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Continuation 10-11

INSTRUMENTATION AND CONTROLS SERVICES

DATA SHEET

ICS/CREA1022-DS Rev. 04 (03/08/2017)

Page 1 of 1

Procedure: CALIBRATION OF ELECTRONIC RECORDERS

IDMS: # 20566

TECHNICIAN(S)/BADGE(S): _____ DATE: _____

WORK ORDER #: _____ ID#: _____

REVIEWED BY: _____ DATE: _____

GENERIC DATA SHEET FOR ELECTRONIC RECORDERS

[illegible]

STANDARDS:

ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:
ID Number:	Due Date:

COMMENTS: Confirmation 11-11



ISO 9001:2008
10000442QM08

Delta M Corporation
1003 Larsen Drive
Oak Ridge, TN 37830
T – (865)483-1569
F – (865)483-1142

Material Certification Documentation

The following documents are to certify that the material and test data as described below conforms in accordance with the requirements and specifications stated within the Purchase Order.

Customer : UT-Battelle, LLC for the Dept. of Energy
1 Bethel Valley Road, c/o ORNL
Oak Ridge, TN 37830

P.O. No. : 4000150155

D.M. Job No. : TC-160365


Mat'l Desc. : T5-U-062-304-K-M-600 Thermocouple

Mat'l Trace : .062-K-304-MgO – PN: 100472
PO# 160339

Quantity : 100 pc (95pc-160339.1 / 5pc-160339.2)

Certificate Of Compliance

This certifies that the articles and/or services supplied to **UT-Battelle, LLC** by Delta M Corporation on **October 12th, 2016** are in Compliance with the requirements of your Purchase Order **4000150155**. This Certification also applies to any documented amendments and/or clarifications pertaining to this stated Purchase Order.


DELTA M CORPORATION
Rob Belcher



Idaho Laboratories Corporation

100472
#160339.1

2101 Hemmert Ave.
Idaho Falls, ID 83401
Phone (208) 522-0055
Fax (800) 524-4522

MATERIAL CERTIFICATE

Material Heat #: 39700
ILC Sales Order #: 216492
Customer P.O. #: 160339

Material Description: 062-KS-304
Customer: DELTA M

The materials and services supplied are in conformance with ASTM E585/585M-12 and/or customer purchase order requirements. Thermocouple material has been calibrated as covered by ASTM E-220 07a, ASTM E-230/E230M, AMS 2750, ANSI/NCSL Z540.1 and ITP 0017 and is traceable to the National Institute of Standards and Technology.

CALIBRATION REPORT

Actual Temperature (°F)	Measured Temperature (°F)	Deviation (°F)
1000.515	1004.0	3.486
1001.952	1005.309	3.357
1504.813	1508.371	3.559
1504.484	1508.327	3.844
1996.717	2002.973	6.256
1996.412	2002.783	6.371

RAW MATERIALS REPORT

Tube		Thermoelement		Thermoelement		Insulator	
Material	304SST	FUR-KP		FUR-KN		MgO	
Heat #	954673	2353		740		16919.700	
Spec.	ASTMA269					E1652-14A	
C	0.021%	Al	<0.01	Co	1.11%	Al2O3	0.03%
Cr	18.2%	C	<0.001	Cu	1.96%	B	< 26 PPM
Cu	0.52%	Co	<0.01	Fe	0.15%	C	< 50 PPM
Fe	BAL.	Cr	9.05%	Ni	bal.	CaO	0.35%
Mn	1.69%	Cu	<0.005	Si	2.46%	Cd	< 3 PPM
Mo	0.50%	Fe	0.48%			Fe2O3	0.04%
N	0.07%	Mn	<0.01			MgO	99.47%
Ni	8.1%	Ni	bal.			S	< 5 PPM
P	0.038%	Si	0.40%			SiO2	0.10%
S	0.0005%						
Si	0.45%						



[Signature]
ILC Quality Assurance

Sep 30, 2016
Date

[Signature]
Q.A. int.



Idaho Laboratories Corporation

100472
#160339.2

2101 Hammett Ave.
Idaho Falls, ID 83401
Phone (208) 522-0055
Fax (800) 524-4522

MATERIAL CERTIFICATE

Material Heat #: 39288
ILC Sales Order #: 216492
Customer P.O. #: 160339

Material Description: 062-KS-304
Customer: DELTA M

The materials and services supplied are in conformance with ASTM E585/585M-12 and/or customer purchase order requirements. Thermocouple material has been calibrated as covered by ASTM E-220 07a, ASTM E-230/E230M, AMS 2750, ANSI/NC SL Z540.1 and ITP 0017 and is traceable to the National Institute of Standards and Technology.

CALIBRATION REPORT

Actual Temperature (°F)	Measured Temperature (°F)	Deviation (°F)
1000.0	1000.57	0.57
1000.0	1000.77	0.77
1500.0	1502.48	2.48
1500.0	1503.08	3.08
2000.0	2004.39	4.39
2000.0	2005.4	5.4

RAW MATERIALS REPORT

Tube		Thermoelement		Thermoelement		Insulator	
Material	304SST	FUR-KP		FUR-KN		MgO	
Heat #	954673	2353		740		5-H-11	
Spec.	ASTMA269	Al	<0.01	Co	1.11%	Al2O3	0.02%
C	0.021%	C	<0.001	Cu	1.96%	B	11.0 PPM
Cr	18.2%	Co	<0.01	Fe	0.15%	C	0.004%
Cu	0.52%	Cr	9.05%	Ni	bal.	CaO	0.14%
Fe	BAL.	Cu	<0.005	Si	2.46%	Fe2O3	0.03%
Mn	1.69%	Fe	0.48%			MgO	99.760%
Mo	0.50%	Mn	<0.01			S	<0.002%
N	0.07%	Ni	bal.			SiO2	0.03%
Ni	8.1%	Si	0.40%				
P	0.038%						
S	0.0005%						
Si	0.45%						



ILC Quality Assurance

Oct 5, 2016

Date



Q.A. int.

11/5/2018
 Calibration Check Of Type K Thermocouples
 Standard T.C.s A001277 and A001278
 Work Order: 3548806

Per ASTM E230 the allowable error applies only to new standard Type K wire. If calibrating used wire the purpose of the allowable error column is only for comparability, and does not imply a pass or fail condition for the used thermocouples.

Standard Type S A001278-A	Standard Type S A001278-B	Type K Under Test Number One	Type K Under Test Number Two	Type K Under Test Number Three	Type K Under Test Number Four	Type K Under Test Number Five	Standard Type S A001277-A	Standard Type S A001277-B
21.4	21.4	21.5	21.5	21.4	21.4	21.4	21.6	21.5
200.0	200.1	202.8	202.7	202.3	202.7	202.5	199.7	199.6
399.1	399.0	401.1	401.1	400.8	401.3	400.9	398.6	398.7
598.0	598.1	602.0	602.1	601.6	602.2	601.2	597.9	598.1
800.0	800.0	805.1	805.2	804.5	805.3	804.4	799.8	800.0
1003.2	1003.4	1009.3	1009.5	1009.1	1009.4	1008.2	1003.0	1003.3
1201.6	1201.4	1207.7	1207.5	1207.6	1207.8	1207.3	1201.2	1201.5

Average Standard Reading	Standard Type K Allowable Error Deg F		T.C. One Calculated Error	T.C. Two Calculated Error	T.C. Three Calculated Error	T.C. Four Calculated Error	T.C. Five Calculated Error
	Plus	Minus					
21.5	3.96	-3.96	-0.02	-0.02	0.08	0.08	0.08
199.9	3.96	-3.96	-2.95	-2.85	-2.45	-2.85	-2.65
398.9	5.38	-5.38	-2.25	-2.25	-1.95	-2.45	-2.05
598.0	8.07	-8.07	-3.98	-4.08	-3.58	-4.18	-3.18
800.0	10.80	-10.80	-5.15	-5.25	-4.55	-5.35	-4.45
1003.2	13.54	-13.54	-6.08	-6.28	-5.88	-6.18	-4.98
1201.4	16.22	-16.22	-6.28	-6.08	-6.17	-6.38	-5.88





Calibration Results

Oak Ridge National Laboratory

ORNL Metrology Laboratory
Bethel Valley Rd. Bldg. 5510A
Oak Ridge, TN 37831-6366

Unit Under Test Information	Customer Information	Test Information
Manufacturer: Stanley Description: 40 Foot Tape Measure Model Number: 33-740 Serial Number: None Asset / ID Number: A006327 Custodian: Oscar A Martinez Work Order Number: 2018000749	Oscar A Martinez Building 5700 Room H320 Mail Stop 6170	Certificate Number: 2018000749 Overall Result: Pass Performed on: 3/20/2018 Next Cal Due: 3/20/2023 Performed by: Jerry Freeman Environment: 20°C 40%Rh Received: In Tolerance
Notes:		
<div>Asset No. </div> <div>Work Order No. </div>		

ORNL Metrology Laboratory (ORNL ML) certifies that the above listed instrument meets or exceeds all specifications as stated in the referenced procedure unless otherwise noted. This Report of Calibration applies only to the item being calibrated, identified above.

This calibration report documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI). Calibration data and conformity assessment (Pass/Fail decision) is limited to the performance of the instrument at the time of test. The "Next Cal Due" date is based on manufacturer's recommendations or best calibration practices and with customer agreement (in the case of external ORNL customers); the instrument should not be used past this date without recalibration. This report shall not be reproduced, except in full, unless written permission for an approved abstract is obtained from ORNL ML. Any report containing accredited data shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. Calibration reports without authorizing signature(s) are not valid.

For accredited data, measurement uncertainties at the time of test, expressed in base units, are given on the following pages, where applicable. They are calculated in accordance with the methods described in EA-4/02, NIST TN1297, DKD-3, or other applicable documents that comply with the Guide to the Uncertainty in Measurement (GUM), using a coverage factor of $k=2$, corresponding to a confidence level of approximately 95%. Unless otherwise indicated, any conformity determination in this report is based on a Test Uncertainty Ratio (TUR) of 4:1 or greater. Any TUR less than 4:1 will be identified in the test data. It is the responsibility of the instrument custodian, with the assistance of his/her Quality Representative, to determine whether this level of confidence for the determination of conformance is adequate for the intended use of this instrument.

This calibration was performed using measurement standards traceable to the appropriate standard(s), maintained by the National Institute of Standards and Technology (NIST), to accepted intrinsic standards of measurement, or is derived by ratio type self-calibration techniques. The calibration system used to derive accredited data complies with the requirements of NIST Handbook 150, ANSI/NCSL Z540.1-1999 (R2002), ISO/IEC 17025.

Standards Used			
ID	Description	Service Date	Due Date
0084705	Agilent 5519A Laser Head (5530A System)	4/20/2017	4/20/2018

Found/Left

Procedure used: STANLEY 0 to 30 ft TAPE RULES

/LASER, Rev. 1.0

Test Data

UUT Range / Comment	Standard Reading	Standard Modifier	UUT Reading	UUT Tolerance	UUT Error	% Tol	Measurement Uncertainty	Accred	Test Status
INITIAL INSPECTION									
No Calibration Seals found on the UUT.									
Instrument was received in good, functional condition.									
UUT Full Length = 39 ft.									
UUT Resolution = 0.0625 in.									
95.995 in			96.00 in	0.032 in	0.005 in	16	3.5e-002 in	No	*Pass
191.996 in			192.00 in	0.039 in	0.004 in	10	3.5e-002 in	No	*Pass
276.006 in			276.00 in	0.045 in	-0.006 in	13	3.5e-002 in	No	*Pass
372.016 in			372.00 in	0.053 in	-0.016 in	30	3.5e-002 in	No	*Pass
468.024 in			468.00 in	0.060 in	-0.024 in	40	3.5e-002 in	No	*Pass

Test Status Notes

* Test Uncertainty Ratio is less than 4:1!

Test Uncertainty Ratio is the ratio between the Unit Under Test specification and the Test Measurement Uncertainty (UUT Spec / Measurement Uncertainty).

-- End of measurement results--

Approved By: Brian Sizemore 3/20/2018 2:39:39PM
Mass/Dimensional Task Leader



Calibration Results

Oak Ridge National Laboratory

Mass Standard Laboratory
Bethel Valley Rd. Bldg. 2547 Rm. 4
Oak Ridge, TN 37831
Phone: 865.574.8978

<p style="text-align: center; color: blue;">Unit Under Test Information</p> <p> Manufacturer: Mettler Toledo Description: Balance 32 Kg Model Number: XP32001 Serial Number: Unknown Asset / ID Number: A000593 Custodian: Oscar A Martinez Work Order Number: 2019002157 </p>	<p style="text-align: center; color: blue;">Customer Information</p> <p> Oscar A Martinez Building 5700 Room H320 Mail Stop 6170 </p>
<p>Notes:</p>	
Asset No. 	Work Order No.



ORNL Metrology Laboratory (ORNL ML) certifies that the above listed instrument meets or exceeds all specifications as stated in the referenced procedure unless otherwise noted. This Report of Calibration applies only to the item being calibrated, identified above.

This calibration report documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI). Calibration data and conformity assessment (Pass/Fail decision) is limited to the performance of the instrument at the time of test. The "Next Cal Due" date is based on manufacturer's recommendations or best calibration practices; the instrument should not be used past this date without recalibration. This report shall not be reproduced, except in full, unless written permission for an approved abstract is obtained from ORNL ML. Any report containing accredited data shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. Calibration reports without authorizing signature(s) are not valid.

For accredited data, measurement uncertainties at the time of test, expressed in base units, are given on the following pages, where applicable. They are calculated in accordance with the methods described in EA-4/02, NIST TN1297, DKD-3, or other applicable documents that comply with the Guide to the Uncertainty in Measurement (GUM), using a coverage factor of $k=2$, corresponding to a confidence level of approximately 95%. The ability of the ORNL Metrology Laboratory to determine the conformance of the calibrated instrument to its specifications is limited to the level of certainty thereby indicated. It is the responsibility of the instrument custodian, with the assistance of his/her Quality Representative, to determine whether this level of confidence for the determination of conformance is adequate for the intended use of this instrument.

This calibration was performed using measurement standards traceable to the appropriate standard(s), maintained by the National Institute of Standards and Technology (NIST), to accepted intrinsic standards of measurement, or is derived by ratio type self-calibration techniques. The calibration system used to derive accredited data complies with the requirements of NIST Handbook 150, ANSI/NC SL Z540.1-1999 (R2002), ISO/IEC 17025.

Magnetic screening was not performed and any errors due to magnetic properties of the items were not considered in the uncertainty calculation.

Approved by: Brian Sizemore 7/26/2019
Mass/Dimensional Task Leader

XP32001 Asset No. A000593 Serial No. Unknown
Performed on: 7/25/2019 3:01:18PM

Cover Sheet

Oak Ridge National Laboratory



Mass Metrology

Building 2547 Room 4

Oak Ridge, TN 37831

CALIBRATION REPORT



Delta Range Balance

			
ID#	A000593	Procedure	XP32001L
Cal Date	7/25/19	Make	Mettler
Standards Used		Next Due Date	
ID #	Cal Due Date	7/25/20	
M212203	9/18/19	Work Order Number	2019002157
		Metrologist	954800
		Location	NTRC, L110

Corner load (Eccentricity) Test	
Eccentricity Weight	10000 g
MFG Eccentricity Tolerance +/-	1 g

Instructions

Place the eccentricity weight in the center position zero the balance. Add a 1 g weight and record the reading. Then move weights to each remaining position and record the reading. Weights should be placed 3/4 distance from the center at each position as shown below. Place an "X" in the box that indicates the appropriate pan style of the balance under test.

X

As Found		
Position	UUT Reading (g)	Absolute Error g
Center	0.9	~
1	0.9	0.0
2	0.8	0.1
3	0.9	0.0
4	1.0	0.1
Center	0.9	0.0
PASS		0.1

As Left		
Position	UUT Reading (g)	Absolute Error g
Center	1.0	~
1	0.9	0.1
2	0.8	0.2
3	1.0	0.0
4	1.0	0.0
Center	1.0	0.0
PASS		0.2

Standard Deviation (Repeatability) Test	
Repeatability Weight	10000 g
Tare Weight	5000
Number of Measurements	6
MFG Repeatability Tolerance	0.6 g

Instructions



Place the tare weight on the pan and tare the balance. Remove the tare weight (reading will be negative) and record Empty Reading. Do not zero or tare the balance for the rest of this test. Place the repeatability weight in the center and record the reading. Continue removing and placing the repeatability weight until the required measurements are taken.

Standard Deviation (Repeatability) (Cont)																																																	
As Found				As Left																																													
Reading #	Empty Reading (g)	Loaded Reading (g)	Difference Reading (g)	Reading #	Empty Reading (g)	Loaded Reading (g)	Difference Reading (g)																																										
1	-5000.6	5001.5	10002.1	1	-5000.0	5000.1	10000.1																																										
2	-5000.6	5001.5	10002.1	2	-5000.0	5000.1	10000.1																																										
3	-5000.6	5001.5	10002.1	3	-5000.0	5000.1	10000.1																																										
4	-5000.6	5001.5	10002.1	4	-5000.0	5000.1	10000.1																																										
5	-5000.6	5001.5	10002.1	5	-5000.0	5000.1	10000.1																																										
6	-5000.6	5001.5	10002.1	6	-5000.0	5000.1	10000.1																																										
Standard Deviation		0.00	PASS	Standard Deviation		0.00	PASS																																										
Linearity Test																																																	
Reference Weight				500 g																																													
MFG Linearity Tolerance +/-				0.3 g																																													
<p>Instructions</p> <p>Place preload weight on pan, tare, and record Preload Tared reading. Next place Reference Weight on pan and record Reading. Repeat process for each point listed below. (If As Found readings fail, and the balance has two internal weights, perform an internal calibration.)</p>																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr><th colspan="3">As Found</th></tr> <tr> <th>Preload Weight (g)</th> <th>Preload Tared (g)</th> <th>Reading (g)</th> </tr> </thead> <tbody> <tr><td>0</td><td>0.0</td><td>500.5</td></tr> <tr><td>10000</td><td>0.0</td><td>500.7</td></tr> <tr><td>20000</td><td>0.0</td><td>500.7</td></tr> <tr><td>30000</td><td>0.0</td><td>501.4</td></tr> <tr> <td>Max-Min/2</td> <td>0.45</td> <td>*FAIL*</td> </tr> </tbody> </table>				As Found			Preload Weight (g)	Preload Tared (g)	Reading (g)	0	0.0	500.5	10000	0.0	500.7	20000	0.0	500.7	30000	0.0	501.4	Max-Min/2	0.45	*FAIL*	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr><th colspan="3">As Left</th></tr> <tr> <th>Preload Weight (g)</th> <th>Preload Tared (g)</th> <th>Reading (g)</th> </tr> </thead> <tbody> <tr><td>0</td><td>0.0</td><td>500.0</td></tr> <tr><td>10000</td><td>0.0</td><td>500.0</td></tr> <tr><td>20000</td><td>0.0</td><td>500.0</td></tr> <tr><td>30000</td><td>0.0</td><td>500.0</td></tr> <tr> <td>Max-Min/2</td> <td>0.00</td> <td>PASS</td> </tr> </tbody> </table>				As Left			Preload Weight (g)	Preload Tared (g)	Reading (g)	0	0.0	500.0	10000	0.0	500.0	20000	0.0	500.0	30000	0.0	500.0	Max-Min/2	0.00	PASS
As Found																																																	
Preload Weight (g)	Preload Tared (g)	Reading (g)																																															
0	0.0	500.5																																															
10000	0.0	500.7																																															
20000	0.0	500.7																																															
30000	0.0	501.4																																															
Max-Min/2	0.45	*FAIL*																																															
As Left																																																	
Preload Weight (g)	Preload Tared (g)	Reading (g)																																															
0	0.0	500.0																																															
10000	0.0	500.0																																															
20000	0.0	500.0																																															
30000	0.0	500.0																																															
Max-Min/2	0.00	PASS																																															
Span Test																																																	
Span Weight				32000 g																																													
MFG Span Tolerance +/-				1 g																																													
<p>Instructions</p> <p>Zero the balance with no weight applied. Place the span weight in the center of the pan and record the reading.</p>																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr><th colspan="3">As Found</th></tr> <tr> <th>Weight Value (g)</th> <th>Reading (g)</th> <th></th> </tr> </thead> <tbody> <tr> <td>32000</td> <td>32009</td> <td>*FAIL*</td> </tr> </tbody> </table>				As Found			Weight Value (g)	Reading (g)		32000	32009	*FAIL*	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr><th colspan="3">As Left</th></tr> <tr> <th>Weight Value (g)</th> <th>Reading (g)</th> <th></th> </tr> </thead> <tbody> <tr> <td>32000</td> <td>32000</td> <td>PASS</td> </tr> </tbody> </table>				As Left			Weight Value (g)	Reading (g)		32000	32000	PASS																								
As Found																																																	
Weight Value (g)	Reading (g)																																																
32000	32009	*FAIL*																																															
As Left																																																	
Weight Value (g)	Reading (g)																																																
32000	32000	PASS																																															
<p>This calibration was performed using measurement standards traceable to the appropriate standard(s), maintained by the National Institute of Standards and Technology (NIST) or other approved National Measurement Institutes, to accepted intrinsic standards of measurement, or is derived by ratio type self-calibration techniques.</p>																																																	
<p>Notes</p> <div style="border: 1px solid black; height: 40px; width: 100%;"></div>																																																	



Oak Ridge National Laboratory

ORNL Metrology Laboratory
Bethel Valley Rd. Bldg. 5510A
Oak Ridge, TN 37831-6366

Unit Under Test Information Manufacturer: Wedge Innovations Description: Digital Level Model Number: SmartTool Serial Number: N/A Asset / ID Number: M212348 Custodian: Oscar A Martinez Work Order Number: 2019002173 Notes:	Customer Information Oscar A Martinez Building 5700 Room H320 Mail Stop 6170	Test Information Certificate Number: 2019002173 Overall Result: Pass Performed on: 7/30/2019 Next Cal Due: 7/30/2020 Performed by: Jerry Freeman Environment: 20°C 45%Rh Received: In Tolerance
<div>Asset No. </div> <div>Work Order No. </div>		

ORNL Metrology Laboratory (ORNL ML) certifies that the above listed instrument meets or exceeds all specifications as stated in the referenced procedure unless otherwise noted. This Report of Calibration applies only to the item being calibrated, identified above.

This calibration report documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI). Calibration data and conformity assessment (Pass/Fail decision) is limited to the performance of the instrument at the time of test. The "Next Cal Due" date is based on manufacturer's recommendations or best calibration practices and with customer agreement (in the case of external ORNL customers); the instrument should not be used past this date without recalibration. This report shall not be reproduced, except in full, unless written permission for an approved abstract is obtained from ORNL ML. Any report containing accredited data shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. Calibration reports without authorizing signature(s) are not valid.

For accredited data, measurement uncertainties at the time of test, expressed in base units, are given on the following pages, where applicable. They are calculated in accordance with the methods described in EA-402, NIST TN1297, DKD-3, or other applicable documents that comply with the Guide to the Uncertainty in Measurement (GUM), using a coverage factor of $k=2$, corresponding to a confidence level of approximately 95%. Unless otherwise indicated, any conformity determination in this report is based on a Test Uncertainty Ratio (TUR) of 4:1 or greater. Any TUR less than 4:1 will be identified in the test data. It is the responsibility of the instrument custodian, with the assistance of his/her Quality Representative, to determine whether this level of confidence for the determination of conformance is adequate for the intended use of this instrument.

This calibration was performed using measurement standards traceable to the appropriate standard(s), maintained by the National Institute of Standards and Technology (NIST), to accepted intrinsic standards of measurement, or is derived by ratio type self-calibration techniques. The calibration system used to derive accredited data complies with the requirements of NIST Handbook 150, ANSI/NCSL Z540.1-1999 (R2002), ISO/IEC 17025.

Standards Used			
ID	Description	Service Date	Due Date
M212335	Mitutoyo America CRTA920H Coordinate Measuring Machine	2/7/2019	2/7/2020

MEITEM Report Cal_Cert_ORNL_Final.rpt

Page 1/2

Print Date: 7/30/2019 9:50:04 AM

— End of measurement results—

Approved By: Brian Sizemore 7/30/2019 9:49:17AM
Mass/Dimensional Task Leader

OAK RIDGE NATIONAL LABORATORY

QUALITY DEPARTMENT

TEST REPORT

PRECISION LEVEL

ITEM: LEVEL, PRECISION 6"

Serial Number: M212348

MANUFACTURER: SMARTTOOL

REF Number: 311-006-501

CUSTODIAN: O. A. Martinez

This is to certify that this level has a sensitivity of 0.1/per degree
and a calibrated accuracy of 0.1/per degree division.

This tool calibrated by reversal technique on
granite surface plate.

Temperature: 68 ° F

Date 7/30/2019

Calibrated By 701194

Due Date 7/30/2020

Approved By *Chris A. Ljerner* ²⁸⁶⁴² 7/30/19

NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY TRACEABILITY
ESTABLISHED THROUGH ORNL PRIMARY STANDARDS

Item Number	Calibration Date	Due Date
M212335	2/7/19	2/7/20

Oak Ridge National Laboratory Metrology Laboratory

Instrument Out of Tolerance Notification

The following instrument(s) was(were) found Out of Tolerance (OOT) in the As Found Calibration process. In accordance with SBMS Calibration Subject Area procedure "Verifying the Quality of Calibration", this notification requires the recipient to take the following actions:

1. compare the OOT condition against the requirements for each application of the instrument,
2. determine if there were any impacts,
3. document the OOT evaluation, and
4. implement appropriate actions.

Equipment Custodian: Oscar A Martinez

Instrument ID Number: A000593

Model Name/Number: XP32001

Instrument Description: Balance 32 Kg

Work Order Number: 2019002157

Manufacturer: Mettler Toledo

Disposition of Instrument: After adjustment and or repair, the instrument passed the As Left calibration process.

Notes:

See the Calibration Data attached to the instrument for a full description of the As Found As Left condition.



Oak Ridge National Laboratory

ORNL Metrology Laboratory
Bethel Valley Rd. Bldg. 5510A
Oak Ridge, TN 37831-6366

Unit Under Test Information	Customer Information	Test Information
Manufacturer: Oak Ridge National Laboratory Description: 1 Meter Length Standard Model Number: None Serial Number: N/A Asset / ID Number: A001146 Custodian: Matthew R Feldman Work Order Number: 2016002294	Matthew R Feldman Bldg 5700 Room N323 Mail Stop 6170 865-241-8801	Certificate Number: 2016002294 Overall Result: Pass Performed on: 6/30/2016 Next Cal Due: 6/30/2021 Performed by: Jerry Freeman Environment: 20°C 47%Rh Received: In Tolerance
Notes:		
Asset No.  Work Order No. 		

ORNL Metrology Laboratory (ORNL ML) certifies that the above listed instrument meets or exceeds all specifications as stated in the referenced procedure unless otherwise noted. This Report of Calibration applies only to the item being calibrated, identified above.

This calibration report documents the traceability to national standards, which realize the units of measurement according to the International System of Units (SI). Calibration data and conformity assessment (Pass/Fail decision) is limited to the performance of the instrument at the time of test. The "Next Cal Due" date is based on manufacturer's recommendations or best calibration practices and with customer agreement (in the case of external ORNL customers); the instrument should not be used past this date without recalibration. This report shall not be reproduced, except in full, unless written permission for an approved abstract is obtained from ORNL ML. Any report containing accredited data shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. Calibration reports without authorizing signature(s) are not valid.

For accredited data, measurement uncertainties at the time of test, expressed in base units, are given on the following pages, where applicable. They are calculated in accordance with the methods described in EA-4/02, NIST TN1297, DKD-3, or other applicable documents that comply with the Guide to the Uncertainty in Measurement (GUM), using a coverage factor of $k=2$, corresponding to a confidence level of approximately 95%. Unless otherwise indicated, any conformity determination in this report is based on a Test Uncertainty Ratio (TUR) of 4:1 or greater. Any TUR less than 4:1 will be identified in the test data. It is the responsibility of the instrument custodian, with the assistance of his/her Quality Representative, to determine whether this level of confidence for the determination of conformance is adequate for the intended use of this instrument.

This calibration was performed using measurement standards traceable to the appropriate standard(s), maintained by the National Institute of Standards and Technology (NIST), to accepted intrinsic standards of measurement, or is derived by ratio type self-calibration techniques. The calibration system used to derive accredited data complies with the requirements of NIST Handbook 150, ANSI/NCSL Z540.1-1999 (R2002), ISO/IEC 17025.

Standards Used

ID	Description	Service Date	Due Date
M212335	Mitutoyo America CRTA920H Coordinate Measuring Machine	2/11/2016	2/11/2017

– End of measurement results–

Approved By: Brian Sizemore 7/7/2016
Mass/Dimensional Task Leader

OAK RIDGE NATIONAL LABORATORY

METROLOGY DEPARTMENT

TEST REPORT

ITEM: 39.38" LENGTH STANDARD

Serial Number: A001146

CUSTODIAN: M. FELDMAN

	AS FOUND	REQUIREMENT	INSPECTION METHOD
LENGTH	39.4000/39.4010	39.38	CMM

Temperature: 68 ° F

Date 6/30/16

Inspector '701194

Date Due 6/30/2021

Reviewed by

Brian X. Syme 28642 7/7/16

NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY TRACEABILITY
ESTABLISHED THROUGH ORNL PRIMARY STANDARDS

Standards used:

ID#

Calibration Due Date

M212335

2/11/17

