

Spinning Reserves from Controllable Packaged Through the Wall Air Conditioner (PTAC) Units

November 2002

Prepared by
B. J. Kirby, M. R. Ally
Oak Ridge National Laboratory

DOCUMENT AVAILABILITY

Reports produced after January 1, 1996, are generally available free via the U.S. Department of Energy (DOE) Information Bridge:

Web site: <http://www.osti.gov/bridge>

Reports produced before January 1, 1996, may be purchased by members of the public from the following source:

National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
Telephone: 703-605-6000 (1-800-553-6847)
TDD: 703-487-4639
Fax: 703-605-6900
E-mail: info@ntis.fedworld.gov
Web site: <http://www.ntis.gov/support/ordernowabout.htm>

Reports are available to DOE employees, DOE contractors, Energy Technology Data Exchange (ETDE) representatives, and International Nuclear Information System (INIS) representatives from the following source:

Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831
Telephone: 865-576-8401
Fax: 865-576-5728
E-mail: reports@adonis.osti.gov
Web site: <http://www.osti.gov/contact.html>

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Consortium for Electric Reliability Technology Solutions

**Spinning Reserves from Controllable Packaged
Through the Wall Air Conditioner (PTAC) Units**

**Brendan Kirby
Moonis Ally
Oak Ridge National Laboratory**

November 2002

The work described in this report was coordinated by the Consortium for Electric Reliability Technology Solutions on behalf of the California Energy Commission, the Assistant Secretary for Energy Efficiency and Renewable Energy, Office of Power Technologies, Transmission Reliability Program of the U. S. Department of Energy under Contract No. DE-AC03-76SF00098.

A Phase I Report
Prepared for the
Consortium for Electric Reliability Technology Solutions (CERTS) Program,
U.S. Department of Energy

Prepared by
Oak Ridge National Laboratory
Oak Ridge, Tennessee 37831-6070
Managed by
UT-BATTELLE, LLC
for the
U. S. Department of Energy
under contract DE-AC05-00OR22725

Table of Contents

FIGURES	v
ACRONYMS	vii
EXECUTIVE SUMMARY	ix
1. INTRODUCTION	1
2. BACKGROUND	3
2.1. SPINNING RESERVE REQUIREMENTS	3
2.2. LOAD PROVISION OF SPINNING RESERVES	4
3. RESOURCE SIZE	7
3.1. COMMERCIAL COOLING DEMAND IN THE U.S.....	7
3.2. RESIDENTIAL COOLING DEMAND IN THE U.S.....	8
3.3. FIELD EVALUATION OF PTAC SUPERVISORY CONTROLLERS.....	8
3.3.1. Data Collection and Data Reduction.....	10
3.3.2. Hourly and Seasonal PTAC Availability	11
4. SPINNING RESERVE PRICES.....	15
5. OTHER ISSUES.....	21
6. CONCLUSIONS.....	23
ACKNOWLEDGMENT.....	25
REFERENCES	25
APPENDIX A.....	A-1
A.1. Split of Residential Energy End-Use Demand in the U.S.....	A-3
A.2. Total Number of Households, Floorspace and Household Size	A-3
A.3. Share of Households by Housing Type and by Type of Ownership.....	A-4
APPENDIX B.....	B-1
B.1. Summer Data: Controlled Rooms – July.....	B-3
B.2. Controlled Rooms – August.....	B-4
B.3. Controlled Rooms – September	B-5
B.4. Uncontrolled Rooms – July.....	B-6
B.5. Uncontrolled Rooms – August.....	B-7

B.6. Uncontrolled Rooms – September	B-8
B.7. Composite Summer Data on Controlled Rooms	B-9
B.8. Composite Summer Data for Uncontrolled Rooms	B-10
B.9. Occupancy Rate During Summer for Controlled and Uncontrolled Rooms.....	B-11
B.10. Winter Data: Controlled Rooms – January	B-12
B.11. Controlled Rooms – February	B-13
B.12. Controlled Rooms – March.....	B-14
B.13. Uncontrolled Rooms – January	B-15
B.14. Uncontrolled Rooms – February	B-16
B.15. Uncontrolled Rooms – March.....	B-17

Figures

1.	Spinning reserve stands ready to immediately respond when contingencies occur	3
2.	Spinning reserve is relieved by supplemental reserves and backup supply fairly quickly	4
3.	Segmented commercial cooling demand in the U.S.	7
4.	Test site (Pigeon Forge, Tennessee.....	9
5.	Clockwise from left: front desk controller at motel, installed Digi-Log unit and control board, ORNL data processing and data transfer module	9
6.	Schematic of the signal initiation, reception, and data collection.....	10
7.	Graph of electric demand for cooling versus time of day for July, August and September 2001 for 12 controlled rooms.....	11
8.	Graph of electric demand for cooling versus time of day for July, August and September 2001 for 12 uncontrolled rooms.....	12
9.	Graph of electric demand for heating versus time of day for January, February and March 2001 for 12 controlled rooms	13
10.	Graph of electric demand for heating versus time of day for January, February and March 2001 for 12 uncontrolled rooms	13
11.	TVA average hourly system summer 2001 load.....	15
12.	TVA average hourly system summer 2001 marginal energy cost.....	16
13.	TVA average hourly system winter 2001 load	16
14.	TVA average hourly system winter 2001 marginal energy cost.....	17
15.	Average hourly CAISO spinning reserve prices for July and February 2002	18
16.	NYISO spinning reserve prices for July 2001 do not reflect all of the compensation a spinning reserve generator receives	19

Acronyms

ACE	area control error
CA ISO	California Independent System Operator
CEC	California Energy Commission
CERTS	Consortium for Electric Reliability Technology Solutions
CDWR	California Department of Water Resources
DCS	Disturbance Control Standard
DOE	U. S. Department of Energy
ERCOT	Electric Reliability Council of Texas
HVAC	heating, ventilation and air conditioning
Hz	hertz
ISO	independent system operator
ISO-NE	New England independent system operator
kW-h	kilowatts of spinning reserve available for use in one hour period
kWh	kilowatt-hour
LIPA	Long Island Power Authority
MW	megawatt
MWh	megawatt-hour
NERC	North American Electric Reliability Council
NYISO	New York Independent System Operator
NYSERDA	New York Energy Research and Development Authority
ORNL	Oak Ridge National Laboratory
PTAC	controlled packaged through the wall air conditioner
SCE	Southern California Edison
WECC	Western Electricity Coordinating Council

Executive Summary

This report summarizes the feasibility of providing spinning reserves from packaged through the wall air conditioning (PTAC) units. Spinning reserves, together with non-spinning reserves, compose the contingency reserves; the essential resources that the power system operator uses to restore the generation and load balance and maintain bulk power system reliability in the event of a major generation or transmission outage. Spinning reserves are the fastest responding and most expensive reserves. Many responsive load technologies could (and we hope will) be used to provide spinning reserve. It is also easier for many loads (including air conditioning loads) to provide the relatively shorter and less frequent interruptions required to respond to contingencies than it is for them to reduce consumption for an entire peak period. Oak Ridge National Laboratory (ORNL) is conducting research on obtaining spinning reserve from large pumping loads and from residential and small commercial thermostat controlled heating, ventilation and air conditioning (HVAC) units. The technology selected for this project, Digi-Log's retrofit PTAC controller, offers significant advantages.

To evaluate the availability of spinning reserve capacity from responsive heating and air conditioning loads, ORNL obtained data from a number of units operating over a year at a motel in the TVA service territory. A total of 24 PTAC units in as many rooms were fitted with Digi-Log's supervisory control unit that could be controlled from the motel front desk. Twelve of the rooms formed the group in which the controller was controlled from the hotel front desk only. The remaining twelve rooms were controlled by the occupant and formed the uncontrolled group. This enables us to evaluate the spinning reserve capacity from PTACS that were operating normally and from those under active energy management.

A second generation of the Digi-Log controller that will respond quickly enough to provide spinning reserve has been designed but not yet manufactured. Manufacture of these units is pending arrival of funds from NYSERDA. The new Digi-Log equipment will utilize satellite signals from Skytel to activate the controller from a remote site by the ISO and to respond to curtailment events.

PTACs account for approximately 3% of the total commercial cooling load in the US, equivalent to an average energy consumption rate of 3,000 MW with peak consumption being significantly higher. Hence PTACs alone represent a sizable opportunity for providing spinning reserves from load. The residential buildings sector cooling and heating load averages about 33,000 MW, more than 10 times the commercial PTAC load. The buildings sector represents an even greater opportunity than the PTAC commercial sector for providing spinning reserves from load. Technology to implement load curtailment and monitor its effect already exists and can readily be further customized to meet ISO and utility needs.

Further research is needed to prove the technical feasibility of PTAC units and other small loads providing spinning reserves. Aggregation, communication, control, and monitoring issues remain to be addressed. If the technical issues can be resolved however, it is likely that system operators, loads, and regulators will have significant incentives to resolve these other resources since spinning reserve from load has the potential to provide large benefits to each community.

1. INTRODUCTION

This report summarizes the feasibility of providing spinning reserves from packaged through the wall air conditioning (PTAC) units. Spinning reserves, together with non-spinning reserves, compose the contingency reserves; the essential resources that the power system operator uses to restore the generation and load balance and maintain bulk power system reliability in the event of a major generation or transmission outage. Spinning reserves are the fastest responding and most expensive reserves. While North American Electric Reliability Council (NERC) rules do not currently allow loads to provide spinning reserve there is increasing recognition that these rules should be changed. This project examines how much spinning reserve a specific type of load (PTAC units) could provide and how that reserve capacity varies with time of day, month, and power system needs.

Providing spinning reserves from load has several advantages for both the power system and the responding load. It is likely to be more reliable and faster than reserve supplied from generation. Some loads are inherently better suited to provide spinning reserves as opposed to providing demand relief, though provision of both is also possible. Also, when loads provide spinning reserves it frees existing generating capacity to serve load. The net result is to increase the capacity and reliability of the power system without increasing the number of operating power plants. This is especially important in capacity-constrained regions of the country.

Many responsive load technologies could (and we hope will) be used to provide spinning reserve. Oak Ridge National Laboratory (ORNL) is conducting research on obtaining spinning reserve from large pumping loads and from residential and small commercial thermostat controlled heating, ventilation and air conditioning (HVAC) units. The technology selected for this project, Digi-Log's retrofit PTAC controller, offers significant advantages. The loads they control represent a large resource that is highly correlated with power system load and power system stress. The technology is already developed for reducing energy consumption and peak shaving. ORNL has compatible monitoring equipment to record test facility performance. Extending the capabilities of the existing technology to provide spinning reserve appears to be feasible. Rapid full deployment is possible if the demonstration project proves the viability of loads providing spinning reserve. The cost of full implementation should also be low. Adding spinning reserve capability will provide a significant additional incentive for utilities and independent system operators (ISOs) to adopt the technology in their regions.

The Department of Energy (DOE) is interested in collaborating with utilities, ISOs, equipment manufacturers, and loads to examine the technical potential for responsive loads to supply spinning reserves to the power system. We recognize that current NERC rules do not allow loads to supply spinning reserves. However, preliminary discussions with NERC as well as the ongoing work of the NERC Policy 10 and Policy 1 committees as well as work by WECC show that the utility industry is starting to recognize that responsive load can provide spinning reserve. The critical technical requirement for spinning reserve is to rapidly restore the generation/load balance after a serious contingency (the loss of a major generator or transmission link). Fundamentally, this restoration can be addressed from either the generation or load side. The time is right to initiate testing of responsive load providing spinning reserve.

ORNL is working with Long Island Power Authority (LIPA), the New York State Energy Research and Development Authority (NYSERDA) and the New York ISO on a project to demonstrate the use of controllable PTAC units to obtain spinning reserve from hotel/motel rooms. All three organizations are familiar with and interested in the concept of load providing spinning reserve and are interested in testing supplying spinning reserves from PTAC units. ORNL also has spinning reserve and ancillary service projects involving responsive load with the California Independent System Operator (CA ISO), California Energy Commission (CEC), and the California Department of Water Resources (CDWR) and is discussing projects with the New England Independent System Operator (NEISO).

This report summarizes the feasibility of providing spinning reserves from an experiment conducted with the controller in 24 rooms in a motel in Pigeon Forge, Tennessee. The cost of data collection was leveraged from DOE's Emerging Technology Program which is studying the energy savings benefits of the same technology.

2. BACKGROUND

2.1 SPINNING RESERVE REQUIREMENTS

The power system has essentially no energy storage capability. It must hold sufficient fast responding resources in reserve ready to respond in case a generator or transmission line suddenly trips off line. NERC's Disturbance Control Standard (DCS) requires control areas to restore their area control error (ACE) within fifteen minutes of a significant contingency. To be prepared to accomplish this, NERC and regional reliability council rules require each control area to have sufficient contingency reserves available to compensate for the largest credible contingency. This is often the loss of the largest generator in the region. NERC rules also currently require the spinning reserves to be generation that is on line, unloaded, responsive to system frequency deviations, under automatic control, able to begin responding immediately, and fully responsive within ten minutes. Non-spinning reserves also have to be fully responsive in ten minutes but they do not have to begin responding immediately or be responsive to system frequency.

Though spinning reserves are required to be continuously available they are deployed relatively infrequently, typically a few times per month. Figure 1 shows the required rapid power system response when a contingency occurs. In this case the Texas ERCOT system lost 2600 MW of generation but successfully recovered within ten minutes.




Fig. 1. Spinning reserve stands ready to immediately respond when contingencies occur.

In the restructured environment ISOs typically procure spinning reserves through markets; hourly competitive auctions. Prices for spinning reserves can be quite high and are usually set by the lost opportunity cost for the generator supplying the reserves. That is, the largest cost is the lost profit the generator could have made if it had been selling energy rather than sitting idle ready to respond if a contingency occurred.




Fig. 2. Spinning reserve is relieved by supplemental reserves and backup supply fairly quickly.

Spinning reserves are relieved as quickly as possible by supplemental reserves. Supplemental reserves can be off-line generation that is able to start quickly or load that can be reduced quickly. Supplemental reserve typically commands a somewhat lower price than spinning reserve. Supplemental reserves are themselves relieved by backup supplies which return the power system to commercial market operation. The exact duration for each of these reserves varies from system to system but the system is typically restored to full commercial operation within two hours. Figure 2 shows the coordinated timing of reliability reserve services.

2.2 LOAD PROVISION OF SPINNING RESERVES

Spinning reserves typically command the highest price when the system load is highest. System load is highest when customer air conditioners are also running the most, on the hottest days. It is also easier for air conditioning loads to provide the relatively shorter and less frequent interruptions required to respond to contingencies than it is for them to reduce consumption for an entire peak period due to the limited thermal storage available from the typical hotel/motel room. Finally, both the load and the system want the air conditioners to return to service as quickly as possible (understanding the need to stagger their return to service). The load wants to return to service to re-cool the room. The power system wants the loads returned to service *and be re-armed* so that the fast spinning reserve response capability is available in case of a subsequent contingency. Unlike generators, responsive loads do not have a minimum run time that the system operator must accommodate.

Fortunately too, providing spinning reserves complements the load's energy management function. Thermal storage is limited. Air conditioners cannot be cycled off for more than a fraction of an hour under normal conditions. Obtaining an overall demand reduction of 1 MW, for example, might require sequentially cycling 3 MW of air conditioners. When providing spinning reserve, however, all of the air conditioners would be cycled off simultaneously providing the full 3 MW of spinning reserve instead of 1 MW of energy reduction. Further, while providing 1 MW of energy consumption reduction the remaining 2 MW is still available as spinning reserve. And the cost to implement the spinning reserve function is only the incremental cost for additional monitoring and communications.

3. RESOURCE SIZE

Contingency reserves only have value to the bulk power system if they are sufficiently large to make a significant contribution. While most individual loads are not large enough to have such an impact, aggregations of loads are. The scope of the Phase I work is to establish the feasibility of generating spinning reserves from load and to estimate the magnitude of spinning reserves that may be available at various times of the day when load is in demand. The project involved working with private companies, corporations, utilities and the ISOs to the extent that such voluntary cooperation was mutually beneficial and possible. Data gathering and analysis would be in support of preparing a NERC waiver if the utilities and ISOs perceived that the data from this DOE Consortium for Electric Reliability Technology Solutions (CERTS) program was sufficiently compelling.

3.1 COMMERCIAL COOLING DEMAND IN THE U.S.

The commercial cooling demand in the U.S is 1.4 Quad¹ (1.4×10^{15} Btu or 4.1×10^{11} kWh) and is segmented as shown in figure 3.

Of the 1.4 Quads, PTACs provide 3 % or 4.2×10^{13} Btu (1.23×10^{10} kWh). Based on 8760 hours in a year and essentially half the year when cooling is needed, 1.23×10^{10} kWh of energy is




Fig. 3. Segmented commercial cooling demand in the U.S.

¹ Source: Energy Consumption Characteristics of Commercial Building HVAC Systems Volume I: Chillers, Refrigerant Compressors, and Heating systems. Final Report prepared by A. D. Little, Inc. for U.S. Department of Energy Office of Building Technology, April 2001.

equivalent to an energy consumption rate of 3,000 MW, much more during peak usage periods. Hence PTACs represent a sizable market in terms of megawatts, albeit only 3% of commercial cooling load in the U.S. This number jumps to an average of 14,000 MW (much greater on peak) if small, thermostat controlled heating and AC units are included.

3.2 RESIDENTIAL COOLING DEMAND IN THE U.S.

Tables for the residential load for cooling and heating, average household size, and type of ownership are given in Appendix A. In year 2000, there were 105.4 million households with an average population of 2.6 persons/household. Electric cooling and heating load from 105.4 million households can provide 37,000 MW towards spinning reserve

Each household has thermostatic control and hence the residential market is an excellent sector for providing spinning reserves from load. The technology to access spinning reserves is already present and has been deployed by utility companies. We are working with the commercial vendors, utilities and ISOs to further develop this capability.

Inclusion of residential units would increase the potential averaged resource size to over 40,000 MW based on 8760 hours in a year for cooling and heating (excluding resistance heating). Clearly, the resource pool is extremely large even if no other load types are considered.

3.3 FIELD EVALUATION OF PTAC SUPERVISORY CONTROLLERS

To evaluate the availability of spinning reserve capacity from responsive heating and air conditioning loads, ORNL obtained data from a number of units operating over a year at a motel in the TVA service territory. This facility was already participating in an evaluation of the energy savings benefits of the Digi-Log technology. A total of 24 PTAC units in as many rooms were fitted with Digi-Log's supervisory control unit that could be controlled from the motel front desk. Twelve of the rooms formed the group in which the controller was controlled from the hotel front desk only. The remaining twelve rooms were controlled by the occupant and formed the uncontrolled group. The occupancy rate, defined as the number of days in a month the rooms were occupied, was maintained as equal as possible. This enables us to evaluate the spinning reserve capacity from PTACS that were operating normally and from those under active energy management.

Photographs of the site where data was collected and installation of the controllers under the PTACs are shown in Figure 4.



Fig. 4. Test site (Pigeon Forge, Tennessee)

Data downloads from the 24 ORNL monitored-rooms were conducted automatically nightly, using an on-board, dial-out modem inside the monitoring device.

The Power Controller Unit was developed by Digi-Log Technologies Inc. as a tool for reducing energy consumption and protecting the HVAC units in low and high voltage situations, therefore lowering operating costs in the lodging industry. The primary functions of the Power Control Unit are to: monitor the power supply of the HVAC unit (protect it from high or low voltages), respond to room temperature extremes and/or an alarming smoke detector (by generating a phone call followed by an alarm code, also lowering motel insurance costs), and enable remote programming and control of various dial up commands and functions. A communication link via telephone (computer modem or touch-tone phone keypad) is established between each Power Controller Unit and the front desk, using the room phone line and a phone line splitter. When a PC is used, Digi-Log Technologies Inc. software and Host Interface Unit are required. The equipment is shown in Figure 5.



Fig. 5. Clockwise from left: front desk controller at motel, installed Digi-Log unit and control board, ORNL data processing and data transfer module.

A second generation of the Digi-Log controller that will respond quickly enough to provide spinning reserve has been designed but not yet manufactured. Manufacture of these units is pending arrival of funds from NYSERDA, expected in November 2002. The new Digi-Log equipment will utilize satellite signals from Skytel to activate the controller from a remote site by the ISO as shown in Figure 6, and to respond to curtailment events. Performance monitoring will still be through the phone system.




Fig. 6. Schematic of the signal initiation, reception, and data collection

3.3.1 Data Collection and Data Reduction

Data was collected at one minute intervals, stored and subsequently downloaded automatically at predetermined times via a modem connection. Data consisted of a time stamp, current, voltage, humidity and room temperature. For analyses, data were averaged over a one-hour period. The energy consumption was calculated assuming a conservative (understating energy consumption) power factor of 0.8. The averaged values for each one-hour interval were summed for each of the 12 rooms in the controlled and uncontrolled sets. For example, power (kW) demand from 8:00 a.m. to 9:00 a.m. (one-hour) consists of the sum of the averaged demand for each of the 12 rooms in the particular control set. In this manner the profile of kW versus time of day in hourly intervals could be constructed to ascertain the load that may be available as spinning reserve. The room temperature profiles and the electric demand give a consistent picture of how the PTAC is being used during heavy load demand in the peak summer months of July, August and September. The data in this report covers the peak summer months and the peak winter months of January, February and March.

Detailed data for the summer (July, August, September) and winter (January, February, March) are given in Appendix B.

3.3.2 Hourly and Seasonal PTAC Availability

This Phase I study on 24 motel rooms clearly presents a compelling case for load to contribute towards spinning reserve. For example, consider the cooling load during summer shown below in Figures 7 and 8, in which load is plotted versus time of day. As expected, the cooling load rises between 11:00 am and 5:00 pm when solar insolation is higher than early morning or later in the afternoon. Also, the cooling demand is greatest in July than it is in August or September because occupancy rates are highest in July than in the following two months for this motel. This trend is observed for both sets of control (Figure 7) and uncontrolled rooms (Figure 8) in the Phase I study.




Fig. 7. Graph of electric demand for cooling versus time of day for July, August and September 2001 for 12 controlled rooms.

It is worthwhile to note that the energy consumption rates for the uncontrolled rooms (Figure 8) are higher than those for the controlled rooms in which the front desk had the override option. The tables in Appendix B for the total kWhs in July for the uncontrolled and controlled rooms are 182.9 and 174.0, respectively. This indicates that spinning reserves are significant for uncontrolled as well as controlled rooms and that these reserves are available over and above energy management activities, as in the case of the controlled rooms. Note that during maximum load demand times (2:30 pm – 5:00 pm), approximately 1.1 kW of spinning reserves is available per PTAC for uncontrolled and controlled sets of rooms.




Fig. 8. Graph of electric demand for cooling versus time of day for July, August and September 2001 for 12 uncontrolled rooms.

The amount of energy savings in the control and uncontrolled sets of rooms depends upon the room occupancy rate, which were kept similar for a valid comparison of the energy consumption rates. During occupancy, supervisory control saved an average of 31% of total room HVAC energy consumption. During vacancy, supervisory control saved 43% of total energy consumption. This translates into about 2,190 kWh per room per year. At electricity cost of \$0.08/kWh, the savings are approximately \$175 per room per year. Digi-Log, Inc. custom made 24 PTAC controller units at a cost of \$399 each. At this price, the payback is 2.28 years. Mass production of the controller units would dramatically reduce unit costs, making the payback more attractive.

The winter data represents the heating load. All of the PTACs used electric resistance elements for heating. Winter occupancy for this motel is low compared to the summer months. Still, the heating load is significant. Figures 9 and 10 present the composite winter heating loads for the uncontrolled and controlled rooms.

During January, February and March, the potential for spinning reserves are shown in Figures 9 and 10 for the controlled and uncontrolled rooms, respectively. Note the heavy heating load in January depicted by the concave downward trend of the curve and the “inverted” (concave upward) heating curves for both February and March. The averaged January temperatures for the 12 rooms (controlled and uncontrolled) are quite high (74.6 F and 73.6 F, respectively) compared to the averaged temperatures in February of 70.2 F (controlled) and 69.2 F (uncontrolled). Similarly for March, the average temperatures were 69.9 F (controlled) and 68.5 F (uncontrolled). That might explain why the heating energy is higher in January versus the

following two winter months of February and March. Also, as the day progresses, the sun's energy warms the ambient and that along with seasonal milder temperatures headed into Spring further explains the concave upward trend in the energy consumption rates in February and March in contrast to the concave downward trend in January. These trends seem to be corroborated by the load curves from the utilities discussed in following pages.




Fig. 9. Graph of electric demand for heating versus time of day for January, February and March 2001 for 12 controlled rooms.




Fig. 10. Graph of electric demand for heating versus time of day for January, February and March 2001 for 12 uncontrolled rooms.

4. SPINNING RESERVE PRICES

Under restructuring, spinning reserves are generally obtained through hourly markets. It is useful to examine spinning reserve market prices for two reasons. First, they provide an indication of the financial viability of loads providing spinning reserves. Second, they provide an indication of *when* the system values spinning reserves. While the system's need for spinning reserves is relatively constant the supply from generators is not. There are times when excess generation is on line but unloaded. This often occurs at night when units that can not be shut down are operated at reduced load awaiting the following day's peak when they will be needed. These unloaded generators can supply spinning reserves very cheaply during these hours. There is no need for loads to respond. At other times, however, there is great value in having loads respond. Hourly spinning reserve prices indicate that value.

TVA – The test motel is located in Pigeon Forge Tennessee which is in the TVA service territory. Unfortunately TVA does not yet operate an hourly spinning reserve market, so spinning reserve prices could not be matched to the hourly PTAC availability data. Average hourly system load is presented in Figures 11 and 12; average hourly system marginal energy cost is presented in Figures 13 and 14. These provide a rough proxy for determining when spinning reserve would have a high value.




Fig. 11. TVA average hourly system summer 2001 load.




Fig. 12. TVA average hourly system summer 2001 marginal energy cost.




Fig. 13. TVA average hourly system winter 2001 load.




Fig. 14. TVA average hourly system winter 2001 marginal energy cost.

Comparing Figures 7 and 11 it can be seen that the PTAC unit's hourly energy requirements and spinning reserve availability are consistent with the overall TVA system load requirements. As expected, system marginal energy costs (Figure 12) also track system load. Spinning reserve costs are likely to show a similar pattern but probably with increased volatility.

Comparing winter conditions shown in Figures 8 and 13 confirms that for both the motel and the overall system February and March were milder than January. One observable winter difference is that the system as a whole shows the typical winter double hump with load dropping in the middle of the day while the PTAC units do not reflect this pattern.

Supervisory thermostat control is economically attractive to utilities and end-users. Conservatively, gas turbine generation cost is about \$500/kW. The cost of a pager to provide thermostatic supervisory control is approximately \$50 and each PTAC can contribute up to 1.1 kW towards spinning reserves or essentially, \$46/kW. The cost of each kW from spinning reserves therefore, is approximately one-tenth the cost of producing it using gas turbines. It behooves us to consider generating spinning reserves from responsive loads versus new generation. On a yearly basis, a typical PTAC in the Southeastern United States consumes 3363 kWh for cooling (7 months) and 3636 kWh for heating (5 months). In field tests, supervisory controllers can save at least 28% of energy which amounts to \$113 per year, based on \$0.059 per kWh. Mass produced supervisory controllers are projected to cost \$30 each, enabling a payback of approximately 4 months. Spinning reserves from the utility's standpoint as well as from the end-user's standpoint is economically viable.

California – The CA ISO does run an hourly market for spinning reserve (and the other ancillary services). Figure 15 presents average hourly prices from February and July 2002 (the California markets were not well behaved in 2001). As can be seen, ancillary service prices are quite volatile and vary throughout the day. Not surprisingly, spinning reserve prices are highest when air-conditioning demand is highest. Fortunately this is when air-conditioning can supply the most spinning reserve. Also not surprisingly, prices in February are well below prices in July in California.




Fig. 15. Average hourly CAISO spinning reserve prices for July and February 2002.

New York – The current spinning reserve market in New York does not capture the full costs of supplying spinning reserve from generation. As shown in Figure 16, average market prices for spinning reserve were low in 2001 due to the market structure and bidding requirements for energy and the ancillary services. In addition to the hourly spinning reserve market prices generators supplying spinning reserves are compensated for their lost opportunity cost – the profits the generators lost because they could not sell into the energy market while they were providing spinning reserves. Generators supplying spinning reserves also typically receive installed capacity payments. New York recognizes these shortcomings in their ancillary service markets and is working to correct them. Still, the *pattern* does reflect higher value in the afternoon and evening than overnight, matching the PTAC capabilities.




Fig. 16. NYISO spinning reserve prices for July 2001 do not reflect all of the compensation a spinning reserve generator receives.

Generation Cost – Another way to take a preliminary look at the financial viability is to compare the cost of obtaining spinning reserve from a conventional resource such as a generator. There the primary cost is the capital cost of having a generator available but not selling into the energy market. A simple comparison of capital costs (\$/kW capacity) indicates that the incremental cost of adding a spinning reserve response capability to a responsive load energy management system is much lower than the cost of generation capacity (~\$500-\$1000/kW).

5. OTHER ISSUES

This project was not designed to address every concern associated with providing spinning reserve from responsive load. Its scope is limited to addressing the size of the resource and its coincidence with power system needs. We recognize that there are additional concerns. We feel that there are good reasons to believe that these other issues can be satisfactorily addressed if the concept proves out technically. Further, we believe that there will be strong incentives to address these other issues once the technical questions are addressed because this concept (spinning reserve from responsive loads) provides benefits to power system operators, supplying loads, generators (freeing them to sell energy rather than constraining them to supply spinning reserves), to all other loads (by increasing power system reliability, decreasing reliability costs, and increasing the available energy supply), and to the transmission system owners (by increasing the transmission system's effective capacity). We provide a brief discussion of some of these additional issues to demonstrate that they are recognized and that further research will address them.

Real-Time Response Monitoring – Spinning reserve is such a critical reliability service, the resources supplying the service (generators) are individually so large (typically hundreds of MW), and the service has to be supplied so fast that the system operator monitors the response of each resource in real-time. Signals are sent from each generator to the system operator's central control facility every two to eight seconds. Under normal conditions (before a contingency event occurs) the system operator uses this monitoring to provide assurance that the reserves are available. When a contingency event occurs, the system operator uses this monitoring to provide assurance that each spinning reserve supplier is indeed responding. The system operator can rapidly take corrective action if one of the generators is not responding as expected.

Real-time monitoring of responsive load could also be provided when loads supply spinning reserve. But there are good reasons to think that this may not be required due to differences in the inherent nature of loads versus generators. First, loads are turning off when they supply spinning reserve while generators are increasing output. As a general rule turning off a load is more reliable than ramping up a generator: fewer things have to go right for the process to be successful. Second, individual loads are typically much smaller than individual generators. If a single 1 kW load fails to respond, for example, there is much less impact on the power system than if a single generator that is supplying 100 MW of spinning reserve fails to respond. Third, individual loads are distributed throughout the power system so problems on the transmission system are less likely to significantly impact the availability of a large amount of spinning reserve. It *is* critical to assure that the reserves do respond, without monitoring or verification there is no incentive for the supplier to continue to supply, but that monitoring may not need to be telemetered to the system operator from each load in real time. After-the-fact monitoring or periodic verification may be adequate if it captures the required fast-response. The reason this issue is of interest is because real-time telemetry can be a significant cost.

Frequency Response – Spinning reserve resources must be automatically and autonomously responsive to system frequency. If system frequency drops sufficiently, spinning reserve resources should try to restore the generation/load balance without waiting for instructions from

the system operator. For loads supplying spinning reserve this response is similar to under frequency load shedding except that the response occurs much closer to the 60 Hz operating frequency, within the generator governor response band (starting at about ± 0.035 Hz). Technically, automatic frequency response is not difficult to implement. The response of individual units could be staggered in frequency such that the aggregated load response duplicates the 5% droop characteristic of a typical generator.

6.0 CONCLUSIONS

This Phase I study on 24 motel rooms clearly presents a compelling case for load to contribute towards spinning reserve. Examination of hourly load patterns for both controlled and uncontrolled PTAC units shows that they are consistent with overall system loading and spinning reserve prices in the summer. The cooling load rises between 11:00am and 5:00pm when solar insolation is higher than early morning or later in the evening. The same physical forces are driving the overall system load and the PTAC load.

In the commercial sector PTACs account for approximately 3% (1.23×10^{10} kW-h) of the total cooling load (4.2×10^{11} kW-h). Based on 8760 hours in a year and half a year of cooling season, the 1.23×10^{10} kW-h of energy is equivalent to an average energy consumption rate of 3,000 MW with peak consumption being significantly higher. Hence PTACs alone represent a sizable opportunity for providing spinning reserves from load. Each PTAC can contribute approximately 1.1 kW towards spinning reserves in the summer time.

The residential buildings sector comprises of 105.4 million units whose cooling and heating loads for the year is equivalent to a yearly average of 32,792 MW, more than 10 times the commercial PTAC load. The buildings sector represents an even greater opportunity than the PTAC commercial sector for providing spinning reserves from load.

Technology to implement load curtailment and monitoring its effect on conditioned space from a physically remote site already exists and can readily be further customized or tailored for the ISO and utilities.

Our discussion with the utility companies, LIPA, Southern California Edison (SCE), Commonwealth Edison and with manufacturers of controllable thermostats indicate a strong interest determining the technical viability of obtaining spinning reserves from responsive loads.

Benefits to the ISO and to the public are that complete feeders need not be targeted during curtailment, but only those loads that do not have a high priority, for example air-conditioning can be remotely turned off for short periods of time (10 – 15 minutes) until generation that is not on-line and is not fully loaded can be brought on to the grid and/or more traditional (and slower) interruptible load can respond.

Controllable PTAC units give the ISO added leverage to be ready for the next curtailment event, should one occur within a short time span.

Further research is needed to prove the technical feasibility of PTAC units and other small loads providing spinning reserves. Aggregation, communication, control, and monitoring issues remain to be addressed. If the technical issues can be resolved, however, it is likely that system operators, loads, and regulators will have significant incentives to resolve these other issues since spinning reserve from load has the potential to provide large benefits to each community.

ACKNOWLEDGMENT

The authors would like to acknowledge the support provided by the DOE EERE Emerging Technology Program management (James R. Brodrick and Rick Orrison) to evaluate the energy savings of the distributed controllers. The authors also wish to thank Evelyn Baskin, Building Equipment Group, for providing energy savings data and to Susan Johnsen for formatting and preparing this report.

REFERENCES

1. Energy Consumption Characteristics of Commercial Building HVAC Systems Volume I: Chillers, Refrigerant Compressors, and Heating systems. Final Report prepared by A. D. Little, Inc. for U.S. Department of Energy Office of Building Technology, April 2001.
2. 2000 BTS Core Databook, U.S. DOE Office of Building Technology, State and Community Programs, August 7, 2000.

APPENDIX A

A.1 Split of Residential Energy End-Use Demand in the U.S (Ref. 2).

Residential Energy End-Use Splits by Fuel Type (quads)

	Natural	Fuel	LPG	Other	Renw.	Site	Site	
	Gas	Oil		Fuel	Energy	Electric	Total	Percent
Space Heating	3.01	0.71	0.27	0.16	0.4	0.45	5	48.8
Space Cooling						0.65	0.65	6.3
Water Heating	1.23	0.13	0.1		0.01	0.44	1.91	18.7
Lighting						0.39	0.39	3.8
Refrigeration						0.57	0.57	5.6
Wet Clean	0.06					0.29	0.35	3.4
Cooking	0.18		0.03			0.22	0.43	4.2
Electronics						0.35	0.35	3.4
Motors						0.06	0.06	0.6
Heating Appliances						0.11	0.11	1.1
Other	0.11		0.01				0.12	1.2
Miscellaneous						0.3	0.3	2.9
Total (quads)	4.59	0.84	0.41	0.16	0.41	3.83	10.24	100
Total (MWh)	1.3E+09	2.5E+08	1.2E+08	4.7E+07	1.2E+08	1.1E+09	3.0E+09	

	Site Electric
Space Heating	0.45
Space Cooling	0.65
Total (quads)	1.1
Total (MWh) ---->	3.2E+08
Energy Rate (MW)---->	36,792
based on 8760 h/year	
and no duty cycling	
With 50% duty cycling--->	73,584

A.2 Total Number of Households, Floorspace and Household Size

Total Number of Households and Buildings, and Housesize by by Year						
Year	Households (millions)	Percent Post-1990 Households	Buildings (millions)	Floorspace (billion sf)	U.S. Population (millions)	Average Household Size
1980	79.6	N/A	65.5	142.5	228	2.9
1990	94.2	N/A	74.2	169.2	250	2.7
1998	102.8	14%	82.6	168.8	271	2.6
2000	105.4	18%	N/A	N/A	275	2.6
2010	117.1	32%	N/A	N/A	298	2.5
2020	127.5	44%	N/A	N/A	323	2.5

A.3 Share of Households by Housing Type, and by Type of Ownership


Share of Households, by Housing Type, and by Type of Ownership

Housing Type	Owned (%)	Rented (%)	Total (%)
Single-Family:	60.3	12.4	72.7
- Detached	54.8	8	62.8
- Attached	5.4	4.4	9.8
Multi-Family:	2.1	19	21.1
- 2 to 4 units	0.9	4.6	5.5
- 5 or more units	1.2	14.4	15.6
Mobile Homes	5.2	1.1	6.3
TOTAL	67.6	32.5	100

APPENDIX B


B.1 Summer Data: Controlled Rooms – July

CONTROLLED ROOMS (July, 2001)													
Time	Room 501	Room 508	Room 509	Room 513	Room 516	Room 519	Room 520	Room 523	R00m 524	Room 528	Room 727	Sum kW	Adj. For 12 Rooms
	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW		
8:00 AM	0.7	0.605	0.609	0.411	0.695	0.603	0.775	0.345	0.629	0.488	1.029	6.889	7.515
9:00 AM	0.755	0.658	0.654	0.405	0.738	0.985	0.748	0.994	0.87	0.772	1.386	8.965	9.780
10:00 AM	0.762	1.027	0.797	0.734	0.701	1.162	0.885	1.562	1.28	0.758	1.161	10.829	11.813
11:00 AM	0.921	0.88	0.629	0.847	0.702	1.045	0.755	1.607	1.305	0.792	1.159	10.642	11.609
12:00 PM	1.121	0.806	0.596	1.109	0.573	1.294	0.768	1.394	1.164	0.853	1.456	11.134	12.146
1:00 PM	1.142	0.852	0.637	0.884	0.639	1.363	0.946	2.01	1.192	0.87	1.449	11.984	13.073
2:00 PM	1.402	0.813	0.658	0.965	0.707	1.243	0.839	1.517	1.13	0.838	1.463	11.575	12.627
3:00 PM	1.275	0.846	0.894	1.052	0.623	1.164	0.873	0.867	1.119	1.117	1.427	11.257	12.280
4:00 PM	1.391	0.967	0.693	0.982	0.839	1.09	1.024	1.171	1.308	1.128	1.611	12.204	13.313
5:00 PM	1.129	1.131	0.669	1.037	0.623	1.061	1.261	1.421	1.257	0.965	1.745	12.299	13.417
6:00 PM	1.198	0.7	0.731	0.981	0.591	1.059	1.355	1.301	1.091	0.997	1.711	11.715	12.780
7:00 PM	1.071	0.696	0.707	0.933	0.593	0.918	1.206	1.011	1.042	0.963	1.318	10.458	11.409
8:00 PM	0.974	0.867	0.63	0.872	0.547	1.058	1.121	1.157	0.981	0.943	1.358	10.508	11.463
9:00 PM	1.086	0.77	0.691	0.761	0.565	1.159	0.993	0.824	0.937	0.872	1.27	9.928	10.831
10:00 PM	0.694	0.723	0.458	0.593	0.784	0.914	1.206	0.483	0.943	0.813	1.51	9.121	9.950
	15.621	12.341	10.053	12.566	9.92	16.118	14.755	17.664	16.248	13.169	21.053		174.009
Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Avg. temp.	
Time	F	F	F	F	F	F	F	F	F	F	F	F	F
8:00 AM	69.7	74.9	74.4	77.7	70.8	75.6	74.7	76.3	76	76.1	71.6	74.3	74.3
9:00 AM	71	75.1	74.8	77.6	70.3	75.1	74.8	75.2	76.4	75.9	71.7	74.4	74.4
10:00 AM	71.8	74.2	74.5	76.5	70.3	74.6	74.5	74.8	74.8	76.1	73.2	74.1	74.1
11:00 AM	72.9	73.9	74.3	75.3	70.8	74.6	74.5	73.9	74.7	76	75.6	74.2	74.2
12:00 PM	72.4	74.1	74.6	74.1	70.7	74.4	74.5	72.1	74.5	76.1	75.5	73.9	73.9
1:00 PM	71.7	74.2	74.7	73.7	70.1	74.4	73.9	69.8	74.4	76.2	75.3	73.5	73.5
2:00 PM	71.6	74.2	74.9	73.2	70	74.4	74	73.4	74.3	76.5	75.4	73.8	73.8
3:00 PM	72.2	74.3	74.6	72.7	70.7	74.8	75	74	74.4	76	75.7	74.0	74.0
4:00 PM	72.1	74.1	74.3	73.4	70.6	75.1	74.7	73.6	74.3	75.6	75.9	74.0	74.0
5:00 PM	72.5	73.7	75	73.8	71.8	76.1	74.1	74.6	74.3	75.7	76.4	74.4	74.4
6:00 PM	72	74.2	75.2	73.8	72.3	76.3	73.6	74.8	74.8	76.1	77.1	74.6	74.6
7:00 PM	72	75.1	75	73.7	72.4	76	73.6	74	75	76	77.5	74.6	74.6
8:00 PM	72.8	74.8	74.7	74.2	72.5	75.6	73.9	74.4	75.4	76	77.8	74.7	74.7
9:00 PM	73.4	74.7	74.6	75.4	72.6	75.3	74.5	74.7	75.2	75.7	77.5	74.9	74.9
10:00 PM	75.7	75.1	74.2	76.6	72.3	75.3	73.9	76.3	75.1	75.7	77.1	75.2	75.2
												74.3	




B.2 Controlled Rooms – August

CONTROLLED ROOMS														
	Room 501	Room 502	Room 508	Room 509	Room 513	Room 516	Room 519	Room 520	Room 523	Room 524	Room 528	Room 727		
Time	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	Time	Sum kW
8:00 AM	0.367	0.381	0.559	0.431	0.59	1.207	0.228	0.725	0.419	0.413	0.721	0.604	8:00 AM	6.645
9:00 AM	0.406	0.438	0.589	0.327	0.739	0.863	0.245	1.115	0.533	0.494	0.709	0.737	9:00 AM	7.195
10:00 AM	0.44	0.423	0.627	0.452	0.916	0.878	0.435	1.193	0.527	0.566	0.741	0.677	10:00 AM	7.875
11:00 AM	0.434	0.381	0.629	0.586	0.89	1.005	0.366	0.855	0.485	0.643	0.705	0.654	11:00 AM	7.633
12:00 PM	0.524	0.348	0.677	0.365	0.885	0.852	0.513	1.071	0.727	0.806	0.725	0.742	12:00 PM	8.235
1:00 PM	0.529	0.351	0.686	0.691	0.988	0.892	0.709	1.157	0.751	0.836	0.744	0.709	1:00 PM	9.043
2:00 PM	0.673	0.403	0.712	0.731	1.062	0.896	0.581	1.418	0.697	0.748	0.797	0.77	2:00 PM	9.488
3:00 PM	0.474	0.44	0.689	0.846	1.11	0.957	0.7	1.453	0.706	0.689	0.967	0.855	3:00 PM	9.886
4:00 PM	0.562	0.554	0.807	0.72	1.125	0.966	0.762	1.195	1.228	0.721	0.999	0.821	4:00 PM	10.46
5:00 PM	0.454	0.691	0.834	0.866	1.125	0.915	0.677	1.137	1.411	0.869	0.942	1.08	5:00 PM	11.001
6:00 PM	0.549	0.675	0.749	0.978	1.027	0.614	0.631	1.095	1.262	0.853	0.962	1.154	6:00 PM	10.549
7:00 PM	0.541	0.679	0.828	1.08	1.057	0.629	0.593	0.935	1.128	0.902	0.833	1.02	7:00 PM	10.225
8:00 PM	0.477	0.482	0.82	1.015	0.928	0.58	0.572	1.155	0.98	0.711	0.713	0.987	8:00 PM	9.42
9:00 PM	0.448	0.394	0.734	0.797	0.875	0.635	0.47	1.035	1.016	0.675	0.749	0.974	9:00 PM	8.802
10:00 PM	0.473	0.433	0.682	0.62	0.761	0.897	0.334	1.147	0.764	0.611	0.886	0.706	10:00 PM	8.314
	7.351	7.073	10.622	10.505	14.078	12.786	7.816	16.686	12.634	10.537	12.193	12.49		134.771
Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Avg. Temp.	
F	F	F	F	F	F	F	F	F	F	F	F	F	F	
73.3	72.5	74.7	74.2	72.8	75.8	79	75.4	75.6	76.1	74.6	68.9	74.4		
74.6	71.9	75	74.6	73.6	76.2	78.6	74.2	75.6	76.7	75.1	70	74.7		
76	71.5	74.7	75.1	73.7	77.7	78.9	73.4	75.8	76.7	75.5	71.8	75.1		
77	71.6	74.7	74.9	73	78	78.4	74.6	76	76.4	75.6	72.8	75.3		
76.6	71.8	74.7	75.5	72.8	78.1	78.9	74.5	76.2	75.7	75.7	72.9	75.3		
77.6	72.3	74.7	75.6	73.2	78.1	79	74.1	76.4	75.1	75.9	73.3	75.4		
77	72.5	74.7	74.4	74	78.1	79.6	73.6	76.5	75.2	75.9	73.8	75.4		
78.2	72.6	74.8	73.1	74.3	78	78.4	73	77	75.6	75.7	74.7	75.5		
77.5	72.3	74.9	74	74	78.4	78.4	73.4	76.2	75.4	75.4	74.7	75.4		
78.8	71.2	74.7	73.7	74	78.5	78.4	74	74.8	75.5	75.6	74.7	75.3		
77.9	71.1	75.1	73.1	74	78.6	78.5	74.4	74.7	75.8	75.7	73.8	75.2		
78.3	71	74.7	72.2	73.9	78.5	78.5	75.3	75.1	75.7	75.8	73.3	75.2		
79.3	71.6	74.8	71.5	73.8	78.4	78.8	75.2	75.3	76.1	75.9	73.1	75.3		
79	72	74.6	71.6	74	78.2	79.2	74.7	75.6	76.2	76	73.5	75.4		
77.3	72.1	74.5	72.7	73.6	78.1	79.2	74.5	75.9	76.2	75.3	73.2	75.2		
													75.2	




B.3 Controlled Rooms – September

CONTROLLED ROOMS(Sept, 2001)													
	Room 501	Room 502	Room 508	Room 509	Room 513	Room 516	Room 520	Room 523	Room 528			Adj. For 12 Rooms	
Time	kW	kW	kW	kW	kW	kW	kW	kW	kW		Sum kW	Sum kW*12/9	
8:00 AM	0.299	0.123	0.309	0.352	0.423	0.395	0.549	0.263	0.257		2.97	3.960	
9:00 AM	0.392	0.132	0.393	0.349	0.45	0.413	0.593	0.216	0.294		3.232	4.309	
10:00 AM	0.388	0.102	0.521	0.357	0.53	0.583	0.624	0.289	0.398		3.792	5.056	
11:00 AM	0.337	0.226	0.509	0.426	0.538	0.572	0.686	0.294	0.419		4.007	5.343	
12:00 PM	0.415	0.214	0.49	0.424	0.506	0.577	0.663	0.565	0.542		4.396	5.861	
1:00 PM	0.416	0.241	0.479	0.392	0.66	0.546	0.666	0.644	0.519		4.563	6.084	
2:00 PM	0.53	0.248	0.511	0.403	0.541	0.58	0.765	0.555	0.532		4.665	6.220	
3:00 PM	0.542	0.265	0.55	0.474	0.526	0.615	0.787	0.761	0.517		5.037	6.716	
4:00 PM	0.506	0.262	0.545	0.642	0.567	0.658	0.787	0.678	0.578		5.223	6.964	
5:00 PM	0.59	0.287	0.423	0.61	0.685	0.72	0.771	0.562	0.618		5.266	7.021	
6:00 PM	0.585	0.225	0.523	0.535	0.649	0.707	0.795	0.501	0.564		5.084	6.779	
7:00 PM	0.531	0.194	0.569	0.551	0.605	0.668	0.831	0.472	0.611		5.032	6.709	
8:00 PM	0.579	0.217	0.547	0.464	0.595	0.657	0.821	0.358	0.626		4.864	6.485	
9:00 PM	0.429	0.198	0.521	0.389	0.611	0.577	0.784	0.441	0.608		4.558	6.077	
10:00 PM	0.402	0.161	0.448	0.404	0.636	0.615	0.758	0.472	0.536		4.432	5.909	
Time	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F			Avg. Temp F	
8:00 AM	73.6	72.9	72.8	72.2	73.7	74.6	75	74.2	73				73.6
9:00 AM	73.6	72.8	73.1	72.3	73.5	74.6	74.7	74.5	73.5				73.6
10:00 AM	74	72.9	73.4	73	73.7	74.5	74.5	74.8	73.4				73.8
11:00 AM	74.6	72.8	73.8	73.7	74.3	74.9	74.5	75.8	73.5				74.2
12:00 PM	75.2	72.6	74.3	74.6	74.6	75.3	74.6	76.3	73.3				74.5
1:00 PM	75.7	72.9	74.2	75.2	74.3	75.5	75	76.3	73.2				74.7
2:00 PM	76	73.2	74.5	75.6	74.4	75.7	75.1	76.7	73.4				75.0
3:00 PM	76.3	73.3	74.8	75.8	75.1	75.6	75.2	77.1	73.8				75.2
4:00 PM	76.7	73.6	75.1	75.2	75.5	75.7	75.3	77.1	73.5				75.3
5:00 PM	77.1	73.6	75.6	74.8	75.8	75.8	75.5	77.1	73.7				75.4
6:00 PM	77.5	74.2	76	75	76	75.8	75.7	77.3	73.7				75.7
7:00 PM	77.6	74.8	76	74.7	76.2	76.2	75.6	77.4	73.5				75.8
8:00 PM	77.5	75.1	75.9	74.7	76.1	76	75.6	77.5	73.3				75.7
9:00 PM	77	75	75.7	74.7	75.9	76	75.7	77.5	72.9				75.6
10:00 PM	76.3	74.7	75.4	74.3	75.4	75.9	75.6	77	72.6				75.2
													74.9




B.4 Uncontrolled Rooms – July

Uncontrolled Rooms, July 2001.														
Time	Room 401	Room 413	Room 416	Room 602	Room 608	Room 609	Room 619	Room 620	Room 623	Room 624	Room 627	Room 628	Time	Sum kW
	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW		
8:00 AM	1.068	0.621	0.902	0.656	0.576	0.444	0.504	0.788	0.499	0.728	0.611	0.749	8:00 AM	8.146
9:00 AM	1.033	0.775	1.123	0.556	0.737	0.581	0.543	0.854	0.795	0.948	0.698	0.894	9:00 AM	9.637
10:00 AM	1.04	0.898	1.278	0.801	0.884	0.565	0.726	1.049	0.887	1.04	0.992	1.085	10:00 AM	11.245
11:00 AM	1.277	0.872	1.213	0.812	0.908	0.75	0.952	0.965	0.956	1.258	1.107	1.164	11:00 AM	12.234
12:00 PM	1.488	0.868	1.234	0.75	0.767	0.763	0.974	1.228	0.971	1.265	1.089	1.154	12:00 PM	12.551
1:00 PM	1.428	0.823	1.26	0.794	0.748	0.821	1.062	1.287	1.102	1.298	1.012	1.11	1:00 PM	12.745
2:00 PM	1.468	0.955	1.44	0.982	0.814	0.951	1.083	1.335	1.161	1.232	1.197	1.133	2:00 PM	13.751
3:00 PM	1.628	1.169	1.472	0.966	0.933	0.931	1.016	1.383	1.117	1.127	1.313	1.083	3:00 PM	14.138
4:00 PM	1.602	1.418	1.317	0.912	1.057	0.851	1.136	1.485	1.082	1.035	1.279	1.139	4:00 PM	14.313
5:00 PM	1.436	1.401	1.429	0.866	1.087	0.789	1.044	1.476	0.896	1.207	1.177	1.184	5:00 PM	13.992
6:00 PM	1.125	1.454	1.434	0.799	1.101	0.886	1.008	1.302	0.96	1.127	1.165	1.137	6:00 PM	13.498
7:00 PM	1.165	1.115	1.474	0.793	1.087	0.773	0.973	1.279	0.905	1.063	1.138	1.147	7:00 PM	12.912
8:00 PM	1.095	0.869	1.17	0.678	1.172	0.694	0.935	1.358	0.817	1.12	1.076	0.939	8:00 PM	11.923
9:00 PM	0.935	0.964	1.051	0.605	1.119	0.597	0.87	1.236	0.814	1.214	1.054	0.951	9:00 PM	11.410
10:00 PM	0.943	1.101	0.977	0.562	0.926	0.54	0.783	1.232	0.492	1.116	0.922	0.787	10:00 PM	10.381
	18.731	15.303	18.774	11.532	13.916	10.936	13.609	18.257	13.454	16.778	15.830	15.756		182.876
Time	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Avg. Temp. F	
8:00 AM	71.8	74.8	74.3	74.3	72.2	75.9	75.6	73.8	74.7	74.7	75	73.4	74.2	
9:00 AM	72	75.3	74.1	74.5	71.8	76.1	75.7	73	74.6	74.5	74.9	72.4	74.1	
10:00 AM	72.7	75.3	73.5	72.2	71.6	76.4	75.8	72	73.6	73.8	75.4	71.9	73.7	
11:00 AM	72.3	74.9	73.4	73.5	71.6	76.1	75.3	71.6	73.4	73.1	75.4	71.3	73.5	
12:00 PM	70.9	74.3	73.7	73.1	72	76	75	71.3	73.3	72.4	74.8	71.1	73.2	
1:00 PM	69.9	74.9	73.5	73.1	71.8	75.9	74.6	70.8	72.7	71.9	74.9	71.4	73.0	
2:00 PM	71.3	75.1	73.7	72.3	72.2	75.8	74.6	70.5	72.5	71.9	74.6	71.7	73.0	
3:00 PM	70	75.2	73.5	72	71.9	75.5	75	70.5	72.3	72.4	74.1	71.9	72.9	
4:00 PM	70.1	75	71.9	72.4	71.4	75.7	75.1	69.7	72.3	73.7	74.1	72.2	72.8	
5:00 PM	70.3	74.3	72.4	73	71.1	75.9	75	69.8	72.3	73.4	74.5	72.1	72.8	
6:00 PM	70.9	74.4	72.3	74.2	71.2	76	75	70.4	73.2	73	74.3	72.1	73.1	
7:00 PM	71.5	74.1	72.6	74.7	71.7	76.3	75.2	70.6	73.2	73.8	74.7	71.9	73.4	
8:00 PM	71.9	74.5	73.7	75	71	76.5	75.3	70.9	73.3	73.5	75	72.4	73.6	
9:00 PM	72.2	74.9	74.4	75.5	70.6	76.8	75.2	70.8	73.5	73.4	75.3	72.8	73.8	
10:00 PM	73	75.1	74.5	75.6	70.9	76.9	75.3	71	74.3	73.1	75.2	73.1	74.0	
													73.4	




B.5 Uncontrolled Rooms – August

Uncontrolled Rooms-August															
Time	Room 401 kW	Room 413 kW	Room 416 kW	Room 602 kW	Room 608 kW	Room 609 kW	Room 619 kW	Room 620 kW	Room 623 kW	Room 624 kW	Room 627 kW	Room 628 kW		Sum kW	
8:00 AM	0.735	0.46	0.819	0.518	0.789	0.666	0.427	0.877	0.542	0.783	0.593	0.56		8:00 AM 7.769	
9:00 AM	0.92	0.441	0.905	0.744	0.79	0.6	0.471	0.897	0.594	0.843	0.61	0.613		9:00 AM 8.428	
10:00 AM	1.024	0.596	1.014	0.764	0.899	0.626	0.487	0.953	0.601	0.87	0.768	0.756		10:00 AM 9.358	
11:00 AM	1.141	0.694	1.06	0.783	1.018	0.905	0.543	1.057	0.945	0.906	0.786	0.802		11:00 AM 10.64	
12:00 PM	1.217	0.82	1.117	0.878	1.078	0.848	0.936	1.108	0.701	0.923	0.827	0.943		12:00 PM 11.396	
1:00 PM	1.213	0.842	1.176	0.861	1.081	0.727	0.951	1.096	0.762	0.902	0.853	0.951		1:00 PM 11.415	
2:00 PM	1.265	0.883	1.213	0.788	1.054	0.753	0.93	1.147	0.832	0.94	0.853	0.851		2:00 PM 11.509	
3:00 PM	1.169	0.78	1.229	0.979	1.11	0.782	0.885	1.182	0.903	0.97	0.895	0.863		3:00 PM 11.747	
4:00 PM	1.24	0.719	1.278	0.986	1.109	0.844	0.96	1.211	0.982	1.023	0.867	0.928		4:00 PM 12.147	
5:00 PM	1.062	0.741	1.239	1.101	1.094	0.917	1.061	1.259	1.027	1.054	1.091	1		5:00 PM 12.646	
6:00 PM	1.219	0.729	1.065	1.087	0.987	1.055	0.849	1.182	0.798	1.033	1.007	1.032		6:00 PM 12.043	
7:00 PM	1.165	0.687	1.081	0.995	0.881	0.985	0.809	1.166	0.772	0.963	0.937	1.036		7:00 PM 11.477	
8:00 PM	1.032	0.663	0.973	0.891	1.052	0.875	0.682	1.111	0.742	0.905	1.039	0.997		8:00 PM 10.962	
9:00 PM	1.049	0.766	0.958	0.791	0.851	0.872	0.717	1.032	0.707	0.842	0.904	0.798		9:00 PM 10.287	
10:00 PM	0.965	0.656	0.837	0.714	0.877	0.751	0.565	1.026	0.725	1.029	0.937	0.665		10:00 PM 9.747	
	16.416	10.477	15.964	12.88	14.67	12.206	11.273	16.304	11.633	13.986	12.967	12.795		161.571	
Time	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Avg. Temp F	
8:00 AM	72.9	76	73.4	72.4	70.9	75.3	77	71.9	73.7	73.6	75.3	74.4		73.9	
9:00 AM	73.1	76.3	73.6	71.4	70.4	75.5	77	71.8	73.8	74	75.4	74.4		73.9	
10:00 AM	72.9	76.6	74.3	71.1	70	75.7	77	71.2	74	73.8	75.8	74.1		73.9	
11:00 AM	73.5	76.5	74.9	70.9	69.4	75.3	77.2	70.8	74	73.8	76.4	73.5		73.9	
12:00 PM	73.1	76	74.6	70.1	68.5	75.1	76.5	70.4	74.1	73.9	76.5	72.8		73.5	
1:00 PM	72.8	75.8	74.1	69.9	68.8	75.6	76.2	70.3	74.3	73.9	76.5	72.3		73.4	
2:00 PM	72.7	75.6	73.6	70.6	69.2	75.8	76.1	70.4	74.2	73.9	76.7	72.8		73.5	
3:00 PM	72.8	75.7	73.4	70.2	69.3	75.7	76.3	70.4	73.8	74.1	76.7	73.2		73.5	
4:00 PM	73.5	76.1	73.3	69.8	69.1	75.8	76.4	70.5	73.8	74.6	76.9	72.9		73.6	
5:00 PM	74.2	76.4	73.1	69.9	69.2	75.5	76.2	70.3	73.4	74.3	76.3	72.9		73.5	
6:00 PM	74.2	76.5	73.6	69.4	69.3	75.4	76.4	70.5	74	74.1	76.2	72.5		73.5	
7:00 PM	74.1	76.5	74	69.5	70.1	75.4	76.8	70.7	74.6	74.4	76.3	72.3		73.7	
8:00 PM	74.5	76.6	74.2	70	69.5	75.3	76.9	70.7	74.6	74.5	76.3	72		73.8	
9:00 PM	74.4	76.4	73.9	70.2	69.5	75.3	76.7	71	74.7	74.8	76.2	72.4		73.8	
10:00 PM	73.8	76.8	74.5	70.5	70.1	75.6	76.9	71	74.2	74.3	75.9	73.3		73.9	
														73.7	




B.6 Uncontrolled Rooms – September

UNCONTROLLED ROOMS (Sept., 2001)															
	Room 401	Room 413	Room 416	Room 602	Room 609	Room 619	Room 620	Room 623	Room 624	Room 627	Room 628		Sum kW	Adj. For 12 Rooms Sum kW	
Time	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	Time	Sum kW	Sum kW	
8:00 AM	0.392	0.452	0.527	0.417	0.361	0.301	0.553	0.409	0.38	0.376	0.42	8:00 AM	4.588	5.01	
9:00 AM	0.482	0.454	0.372	0.411	0.454	0.285	0.607	0.376	0.43	0.4	0.387	9:00 AM	4.658	5.08	
10:00 AM	0.416	0.56	0.583	0.349	0.438	0.339	0.536	0.415	0.364	0.534	0.537	10:00 AM	5.071	5.53	
11:00 AM	0.56	0.511	0.955	0.376	0.546	0.424	0.732	0.455	0.439	0.615	0.612	11:00 AM	6.225	6.79	
12:00 PM	0.706	0.452	0.753	0.415	0.587	0.625	0.755	0.574	0.492	0.595	0.557	12:00 PM	6.511	7.10	
1:00 PM	0.773	0.48	0.725	0.449	0.653	0.923	0.914	0.689	0.498	0.592	0.533	1:00 PM	7.229	7.89	
2:00 PM	0.811	0.579	0.742	0.522	0.652	0.841	0.999	0.737	0.468	0.646	0.511	2:00 PM	7.508	8.19	
3:00 PM	0.968	0.616	0.816	0.586	0.73	0.86	0.853	0.805	0.511	0.732	0.631	3:00 PM	8.108	8.85	
4:00 PM	0.853	0.652	0.813	0.855	0.701	0.821	0.813	0.855	0.508	0.653	0.623	4:00 PM	8.147	8.89	
5:00 PM	0.947	0.747	0.874	0.896	0.729	0.965	0.788	0.654	0.502	0.726	0.614	5:00 PM	8.442	9.21	
6:00 PM	0.79	0.657	0.893	0.617	0.75	0.913	0.885	0.695	0.554	0.799	0.629	6:00 PM	8.182	8.93	
7:00 PM	0.753	0.614	0.715	0.64	0.658	0.876	0.858	0.657	0.53	0.744	0.613	7:00 PM	7.658	8.35	
8:00 PM	0.542	0.646	0.719	0.566	0.563	0.718	0.692	0.565	0.511	0.632	0.611	8:00 PM	6.765	7.38	
9:00 PM	0.558	0.62	0.588	0.588	0.472	0.578	0.566	0.53	0.516	0.557	0.565	9:00 PM	6.138	6.70	
10:00 PM	0.566	0.596	0.676	0.529	0.602	0.528	0.569	0.623	0.495	0.548	0.577	10:00 PM	6.309	6.88	
														110.77	
Temp	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.		Avg. Temp.		
F	F	F	F	F	F	F	F	F	F	F	F		F		
70.9	73.5	71.6	70.2	73.1	73.2	69.7	72.7	72.2	72	71.1		71.8			
71.3	73.7	72	70.6	72.6	73.1	69.8	72.8	72.1	72.9	71.5		72.0			
71.6	73.8	72.2	71.2	73.2	73.5	70.3	73.3	72.5	73.9	71.4		72.4			
72	74	72.3	71.3	74	74.1	70.4	73.9	73	74.4	71.3		72.8			
72.3	74.1	72.6	72.1	74.3	74.4	70.7	74.4	73.1	74.4	71.5		73.1			
72.6	74.5	72.6	72.3	74.6	74	70.5	75	73.4	74.6	72		73.3			
73	74.8	72.6	72.3	74.6	73.8	70.8	75.4	73.7	74.7	72.4		73.5			
73	75	72.7	72.4	74.5	73.5	71.2	75.7	74.3	75.3	72.3		73.6			
73.1	75.3	73.2	72.5	74.8	73.9	71.4	76	74.6	75.5	72.6		73.9			
73.2	75.3	73.2	72.7	74.8	73.7	71.6	75.9	74.5	75.5	72.7		73.9			
73.8	75.1	72.9	72.6	74.8	73.1	71.7	76	74.7	75.3	72.7		73.9			
74.2	75.1	73.6	72.4	74.7	73.2	71.8	75.8	74.7	75.1	72.6		73.9			
74.3	74.9	73.4	72.2	74.6	73.1	71.9	75.6	74.7	75	72.3		73.8			
74.4	74.7	73.3	71.8	74.8	73.7	72.1	75.5	74.2	74.6	72.2		73.8			
73.9	74.7	73.3	71.6	74.8	74.2	72.1	75.4	73.9	74.4	72.1		73.7			
													73.3		




B.7 Composite Summer Data on Controlled Rooms

CONTROLLED ROOMS						
	July 2001	July 2001	AUG. 2001	AUG. 2001	SEPT., 2001	SEPT., 2002
	Adj. For 12 Rooms	Avg. temp.	12 Rooms	Avg. Temp.	Adj. For 12 Rooms	Avg. Temp
Time	Sum kW	F	Sum kW	F	Sum kW	F
8:00 AM	7.515	74.3	6.645	74.4	3.960	73.6
9:00 AM	9.780	74.4	7.195	74.7	4.309	73.6
10:00 AM	11.813	74.1	7.875	75.1	5.056	73.8
11:00 AM	11.609	74.2	7.633	75.3	5.343	74.2
12:00 PM	12.146	73.9	8.235	75.3	5.861	74.5
1:00 PM	13.073	73.5	9.043	75.4	6.084	74.7
2:00 PM	12.627	73.8	9.488	75.4	6.220	75.0
3:00 PM	12.280	74.0	9.886	75.5	6.716	75.2
4:00 PM	13.313	74.0	10.460	75.4	6.964	75.3
5:00 PM	13.417	74.4	11.001	75.3	7.021	75.4
6:00 PM	12.780	74.6	10.549	75.2	6.779	75.7
7:00 PM	11.409	74.6	10.225	75.2	6.709	75.8
8:00 PM	11.463	74.7	9.420	75.3	6.485	75.7
9:00 PM	10.831	74.9	8.802	75.4	6.077	75.6
10:00 PM	9.950	75.2	8.314	75.2	5.909	75.2
	174.0		134.8		89.5	




B.8 Composite Summer Data for Uncontrolled Rooms

UNCONTROLLED ROOMS						
	JULY 2001	JULY 2001	AUG. 2001	AUG. 2001	SEPT., 2001	
					Adj. For 12 Rooms	
	Sum kW	Avg. Temp.	Sum	Avg. Temp	Sum kW	Avg. Temp.
Time		F	kW	F		F
8:00 AM	8.1	74.2	7.8	73.9	5.0	71.8
9:00 AM	9.6	74.1	8.4	73.9	5.1	72.0
10:00 AM	11.2	73.7	9.4	73.9	5.5	72.4
11:00 AM	12.2	73.5	10.6	73.9	6.8	72.8
12:00 PM	12.6	73.2	11.4	73.5	7.1	73.1
1:00 PM	12.7	73.0	11.4	73.4	7.9	73.3
2:00 PM	13.8	73.0	11.5	73.5	8.2	73.5
3:00 PM	14.1	72.9	11.7	73.5	8.8	73.6
4:00 PM	14.3	72.8	12.1	73.6	8.9	73.9
5:00 PM	14.0	72.8	12.6	73.5	9.2	73.9
6:00 PM	13.5	73.1	12.0	73.5	8.9	73.9
7:00 PM	12.9	73.4	11.5	73.7	8.4	73.9
8:00 PM	11.9	73.6	11.0	73.8	7.4	73.8
9:00 PM	11.4	73.8	10.3	73.8	6.7	73.8
10:00 PM	10.4	74.0	9.7	73.9	6.9	73.7
	182.876		161.571		110.77	



B.9 Occupancy Rate During Summer for Controlled and Uncontrolled Rooms

The occupancy rates for the controlled and uncontrolled groups were maintained intentionally as close as possible by the motel management for the purposes of energy consumption (kWh) calculations. Note that the occupancy rate is highest in July when families are on vacation, especially during the 4th of July weekend, and that is also the period when electricity demand peaks. From the composite summer data, it is evident that the greatest contribution to spinning reserve can be made in July.




Winter Data

The winter data represents the heating load. Occupancy during the winter months is very low compared to the summer months. Our data indicates that the motel occupancy in winter is about 44% of that in the summer.


B.10 Controlled Rooms – January

CONTROLLED ROOMS (January, 2001)											Sum	Adj. For 12 Rooms
Time	Room 501	Room 508	Room 509	Room 513	Room 516	Room 519	Room 520	Room 524	Room 528	Room 727	kW	kW
8:00 AM	0.607	0.621	0.458	0.416	0.658	0.681	0.816	0.77	0.561	1.106	6.69	8.03
9:00 AM	0.651	0.585	0.654	0.661	0.769	1.136	0.931	0.866	0.772	1.386	8.41	10.09
10:00 AM	0.836	0.823	0.797	0.793	0.735	1.34	0.922	1.209	0.758	1.161	9.37	11.25
11:00 AM	0.941	0.895	0.643	0.982	0.752	1.205	0.79	1.305	0.792	1.159	9.46	11.36
12:00 PM	0.984	0.824	0.552	0.803	0.698	1.493	0.884	1.164	0.853	1.456	9.71	11.65
1:00 PM	1.035	0.892	0.839	0.891	0.784	1.572	0.97	1.193	0.859	1.449	10.48	12.58
2:00 PM	1.165	0.81	0.845	0.964	0.86	1.435	1.02	1.123	0.944	1.463	10.63	12.75
3:00 PM	1.18	0.942	0.989	0.929	0.833	1.343	1.06	1.121	1.091	1.427	10.92	13.10
4:00 PM	1.095	1.056	0.88	0.91	1.055	1.246	1.178	1.311	1.066	1.611	11.41	13.69
5:00 PM	0.896	1.116	0.924	0.948	0.984	1.224	1.216	1.255	0.956	1.745	11.26	13.52
6:00 PM	0.968	0.902	1.004	0.934	0.86	1.222	1.287	1.087	1.021	1.711	11.00	13.20
7:00 PM	1.009	0.892	0.989	0.897	0.855	1.06	1.094	1.043	0.978	1.318	10.14	12.16
8:00 PM	0.898	0.886	0.93	0.801	0.833	1.221	1.169	0.972	0.921	1.358	9.99	11.99
9:00 PM	0.905	0.868	0.86	0.712	0.847	1.337	1.294	0.966	0.836	1.27	9.90	11.87
10:00 PM	0.687	0.739	0.912	0.629	0.941	1.055	1.244	0.916	0.817	1.51	9.45	11.34
												178.58
Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Avg. Temp.	
F	F	F	F	F	F	F	F	F	F	F	F	
73	76	74.4	75.7	72.3	77	74.2	76	76.1	71.8	74.7		
73.7	76.5	74.8	75.1	71.6	76.5	74.1	75.9	75.9	71.7	74.6		
73.9	76.3	74.5	74.3	72	75.9	74.1	75.1	76.1	73.2	74.5		
74.2	75.7	74.9	73.4	72.1	75.8	74.2	74.7	76	75.6	74.7		
74.3	75.4	75.5	73.8	72.4	75.6	74.4	74.5	76.1	75.5	74.8		
74.3	75	75	72.9	71.7	75.4	73.8	74.3	76.4	75.3	74.4		
74.2	74.9	74.7	72.3	71.5	75.3	74	74.3	76.2	75.4	74.3		
74.1	74.7	74.3	72.6	71.8	75.7	74.2	74.4	75.8	75.7	74.3		
73.8	74.3	74	73.2	71.7	75.1	73.9	74.3	75.7	75.9	74.2		
74.3	74.3	74.5	73.3	72.4	76.3	74	74.3	76	76.4	74.6		
74.3	74.7	74.4	72.7	73.2	76.5	73.9	74.8	76	77.1	74.8		
74.3	75.2	74.1	74.2	73.6	76.8	74	75	76	77.5	75.1		
74.4	75.4	73.9	74.4	73	76.5	74	75.4	76	77.8	75.1		
74.8	75.6	73.8	75.1	73.4	76.2	73.4	75.2	75.8	77.5	75.1		
75.9	75.9	73.6	75.2	73.4	76.1	73	75.1	75.7	77.1	75.1		
												74.67




B.11 Controlled Rooms – February

CONTROLLED ROOMS												Adj. For 12 Rooms	
	Room 501	Room 502	Room 508	Room 509	Room 513	Room 516	Room 519	Room 520	Room 523	Room 524	Room 528	Sum	Sum
Time	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
8:00 AM	0.618	0.503	0.099	0.442	0.487	0.132	0.093	0.117	0.209	0.49	0.409	3.60	3.93
9:00 AM	0.462	0.424	0.169	0.225	0.396	0.155	0.069	0.141	0.15	0.568	0.373	3.13	3.42
10:00 AM	0.422	0.264	0.102	0.358	0.407	0.201	0.091	0.228	0.085	0.41	0.162	2.73	2.98
11:00 AM	0.239	0.112	0.073	0.376	0.495	0.132	0.058	0.186	0.077	0.431	0.136	2.32	2.53
12:00 PM	0.224	0.072	0.041	0.208	0.354	0.264	0.05	0.182	0.094	0.498	0.114	2.10	2.29
1:00 PM	0.236	0.055	0.053	0.187	0.3	0.255	0.044	0.188	0.057	0.595	0.08	2.05	2.24
2:00 PM	0.21	0.046	0.037	0.159	0.21	0.14	0.105	0.182	0.055	0.505	0.186	1.84	2.00
3:00 PM	0.334	0.146	0.029	0.112	0.306	0.11	0.055	0.2	0.057	0.446	0.167	1.96	2.14
4:00 PM	0.343	0.155	0.027	0.126	0.299	0.111	0.061	0.165	0.065	0.428	0.109	1.89	2.06
5:00 PM	0.233	0.187	0.051	0.171	0.359	0.116	0.07	0.166	0.105	0.404	0.104	1.97	2.14
6:00 PM	0.248	0.218	0.072	0.153	0.417	0.197	0.118	0.134	0.323	0.54	0.128	2.55	2.78
7:00 PM	0.354	0.149	0.128	0.15	0.526	0.116	0.111	0.129	0.163	0.494	0.234	2.55	2.79
8:00 PM	0.331	0.211	0.167	0.158	0.455	0.112	0.073	0.12	0.241	0.414	0.424	2.71	2.95
9:00 PM	0.325	0.248	0.124	0.154	0.479	0.125	0.065	0.1	0.158	0.575	0.231	2.58	2.82
10:00 PM	0.334	0.216	0.12	0.137	0.509	0.188	0.234	0.104	0.167	0.481	0.38	2.87	3.13
	4.913	3.006	1.292	3.116	5.999	2.354	1.297	2.342	2.006	7.279	3.237	36.84	40.19
Temp	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Avg. Temp.	
Time	F	F	F	F	F	F	F	F	F	F	F	F	
8:00 AM	67.95	66.38	67	70	69	68	67	70	68	71	67	68.3	
9:00 AM	67.49	65.75	66	69	68	68	67	69	67	71	66.5	67.7	
10:00 AM	68.02	66	66	70	68	69	68	70	68	71	67	68.3	
11:00 AM	68.16	66	66	71	68	69	69	69	69	70	67	68.4	
12:00 PM	68.73	66	67	73	69	70	70	69	70	70	67	69.1	
1:00 PM	69.49	67	67	74	70	70	72	70	72	70	67	69.9	
2:00 PM	70.48	67	67	74	70	70	73	70	73	71	68	70.3	
3:00 PM	71.3	68	68	75	72	70	74	71	74	71	68	71.1	
4:00 PM	72.04	69	69	75	72	70	75	71	75	72	69	71.7	
5:00 PM	72.54	69	69	75	73	71	75	72	75	72	70	72.1	
6:00 PM	72.65	69	69	74	73	71	74	72	74	72	70	71.9	
7:00 PM	72.34	69	69	74	73	71.5	73	72	73	73	70	71.8	
8:00 PM	71.74	69	69	73	73	71	72	72	72	73	70	71.4	
9:00 PM	71.08	68	69	72	72	71	71	72	72	73	70	71.0	
10:00 PM	70.46	68	69	72	71	71	71	71	71	73	69	70.6	
												70.2	




B.12 Controlled Room – March

CONTROLLED ROOMS- March, 2001														Adj. For 12 Rooms
Time	Room 501	Room 502	Room 508	Room 509	Room 513	Room 516	Room 519	Room 520	Room 523	Room 524	Room 528	Sum	Sum	
	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	
8:00 AM	0.323	0.166	0.296	0.261	0.268	0.15	0.336	0.047	0.543	0.205	0.186	2.78	3.03	
9:00 AM	0.35	0.297	0.32	0.09	0.171	0.135	0.266	0.029	0.299	0.168	0.302	2.43	2.65	
10:00 AM	0.254	0.392	0.17	0.098	0.157	0.144	0.386	0.056	0.337	0.226	0.364	2.58	2.82	
11:00 AM	0.232	0.22	0.152	0.094	0.259	0.1	0.212	0.045	0.158	0.271	0.406	2.15	2.34	
12:00 PM	0.229	0.195	0.116	0.143	0.168	0.104	0.179	0.045	0.078	0.11	0.257	1.62	1.77	
1:00 PM	0.207	0.151	0.085	0.111	0.125	0.105	0.14	0.068	0.059	0.128	0.231	1.41	1.54	
2:00 PM	0.162	0.18	0.191	0.12	0.127	0.086	0.165	0.073	0.056	0.125	0.208	1.49	1.63	
3:00 PM	0.111	0.176	0.199	0.083	0.127	0.081	0.216	0.063	0.067	0.118	0.205	1.45	1.58	
4:00 PM	0.132	0.142	0.189	0.092	0.153	0.106	0.191	0.049	0.126	0.205	0.322	1.71	1.86	
5:00 PM	0.113	0.156	0.26	0.08	0.176	0.102	0.183	0.064	0.113	0.174	0.188	1.61	1.76	
6:00 PM	0.288	0.184	0.215	0.088	0.193	0.084	0.201	0.067	0.219	0.134	0.154	1.83	1.99	
7:00 PM	0.21	0.256	0.276	0.107	0.135	0.089	0.29	0.055	0.308	0.146	0.259	2.13	2.32	
8:00 PM	0.246	0.18	0.375	0.085	0.134	0.111	0.353	0.055	0.196	0.151	0.215	2.10	2.29	
9:00 PM	0.139	0.274	0.467	0.109	0.192	0.106	0.22	0.069	0.393	0.148	0.161	2.28	2.49	
10:00 PM	0.185	0.313	0.406	0.091	0.342	0.146	0.375	0.081	0.33	0.167	0.12	2.56	2.79	
	3.181	3.282	3.717	1.652	2.727	1.649	3.713	0.866	3.282	2.476	3.578	30.12	32.86	
Time	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Temp. F	Avg. Temp. F		
8:00 AM	63.8	65.9	67.1	68.4	65.2	67.9	67.9	69	67.3	69	66.3	67.1		
9:00 AM	64.4	66.5	67.4	68.9	66	68	69.3	69	67.5	69	66.7	67.5		
10:00 AM	65.9	66.8	67.5	69.9	65.7	68	72.3	69.2	68.5	69.1	67	68.2		
11:00 AM	66.8	66.5	67.2	71.6	66.2	68	72.2	69.5	69.3	69.6	67.5	68.6		
12:00 PM	67.2	67.5	67.2	72.9	66.9	68.7	73.2	70	69.8	69.7	67.8	69.2		
1:00 PM	68.3	68	67.6	73.7	67.9	69.4	73.9	70.5	70.8	69.7	68.1	69.8		
2:00 PM	68.5	67.9	68.2	74.1	68.8	69.8	74.6	70.9	71.7	69.9	68.6	70.3		
3:00 PM	68.7	68.5	69.3	74.2	69.7	70.3	75.3	71.2	72.2	70.2	68.8	70.8		
4:00 PM	69.1	68.8	69.5	74.1	70	70.6	75.9	71.5	72.6	70.3	69.3	71.1		
5:00 PM	69.2	68.9	69.7	74	70.2	70.9	76.2	71.5	72.7	70.5	69.6	71.2		
6:00 PM	69.9	69	69.7	73.7	70.6	70.9	76.4	71.5	72.1	70.8	69.5	71.3		
7:00 PM	69.5	69	69.6	73.4	70.5	70.9	76.5	71.7	72.2	70.9	69.9	71.3		
8:00 PM	68.7	68.8	69.7	72.8	70.1	71.1	76.6	71.7	71.6	70.9	69.7	71.1		
9:00 PM	68.3	68.5	69.6	72.1	69.6	70.9	76.2	71.6	71.1	70.8	69.5	70.7		
10:00 PM	67.8	68.1	69.7	71.4	69.1	70.7	73.9	71.2	70.6	70.6	69.1	70.2		
												69.9		




B.13 Uncontrolled Rooms – January

UNCONTROLLED ROOMS (January 2001)													Adj. For 12 Rooms	
Time	Room 413	Room 416	Room 602	Room 608	Room 609	Room 619	Room 620	Room 623	Room 624	Room 627	Room 628	Sum	Sum	
	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	
8:00 AM	0.621	1.086	1.083	0.615	0.444	0.504	0.854	0.529	1.528	0.601	0.749	8.61	9.40	
9:00 AM	0.775	1.215	0.945	0.737	0.581	0.543	0.854	0.841	0.955	0.919	0.994	9.36	10.21	
10:00 AM	0.898	1.249	0.801	0.884	0.565	0.726	1.049	0.939	1.037	1.099	1.285	10.53	11.49	
11:00 AM	0.876	1.241	0.812	0.908	0.75	0.963	0.965	0.956	1.244	1.079	1.164	10.96	11.95	
12:00 PM	0.857	1.25	0.75	0.767	0.763	0.97	1.249	0.971	1.255	0.987	1.154	10.97	11.97	
1:00 PM	0.839	1.444	0.794	0.748	0.821	1.06	1.267	1.102	1.336	1.118	1.111	11.64	12.70	
2:00 PM	0.911	1.443	0.982	0.814	0.951	1.026	1.335	1.161	1.225	1.242	1.133	12.22	13.33	
3:00 PM	1.145	1.423	0.966	0.933	0.931	1.06	1.383	1.117	1.109	1.275	1.083	12.43	13.55	
4:00 PM	1.417	1.313	0.912	1.057	0.851	1.104	1.485	1.082	1.012	1.301	1.139	12.67	13.83	
5:00 PM	1.423	1.413	0.866	1.087	0.789	1.032	1.476	0.896	1.059	1.108	1.184	12.33	13.45	
6:00 PM	1.265	1.487	0.799	1.101	0.886	1.002	1.302	0.96	1.163	1.18	1.137	12.28	13.40	
7:00 PM	1.121	1.196	0.793	1.087	0.773	0.991	1.279	0.905	1.033	1.101	1.147	11.43	12.46	
8:00 PM	0.871	1.084	0.678	1.172	0.694	0.942	1.358	0.817	1.057	1.076	0.939	10.69	11.66	
9:00 PM	0.959	0.997	0.605	1.119	0.597	0.858	1.236	0.814	1.205	1.081	0.951	10.42	11.37	
10:00 PM	0.97	0.884	0.562	0.926	0.54	0.779	1.232	0.492	1.198	0.837	0.787	9.21	10.04	
													180.82	
Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.		Avg. Temp.	
F	F	F	F	F	F	F	F	F	F	F	F		F	
74.8	74.5	74.2	72.2	75.9	75.6	73.3	74.9	74.6	75	73.4			74.4	
75.3	73.7	74.4	71.8	76.1	75.7	73	74.8	74.4	75.1	72.4			74.2	
75.3	73.5	74.1	71.6	76.4	75.8	72	73.6	73.8	74.9	72			73.9	
74.9	73.6	73.5	71.6	76.1	75.3	71.6	73.4	72.9	75.1	71.3			73.6	
74.3	73.3	73.1	72	76	74.9	71	73.3	72.4	74.8	71.1			73.3	
74.8	73.5	73.1	71.8	75.9	74.6	71.2	72.7	71.6	74.6	71.4			73.2	
75.2	73.3	72.3	72.2	75.8	75	70.5	72.5	72.2	74.3	71.7			73.2	
75.2	73.2	72	71.9	75.5	75	70.5	72.3	72.3	74.3	71.9			73.1	
75.1	72.4	72.4	71.4	75.7	75	69.7	72.3	73.7	74	72.2			73.1	
74.3	72.2	73	71.1	75.9	75.1	69.8	72.8	73.8	74.5	72.1			73.1	
74.1	72.6	74.2	71.2	76	75.1	70.4	73.2	73.4	74.5	72.1			73.3	
74.1	73.5	74.7	71.7	76.3	75.2	70.6	73.2	73.8	74.7	71.9			73.6	
74.5	74.1	75	71	76.5	75.2	70.9	73.3	73.9	75.2	72.4			73.8	
74.9	74.5	75.5	70.6	76.8	75.1	70.8	73.5	73.5	75.2	72.8			73.9	
74.8	74.6	75.6	70.9	76.9	75.3	71	74.3	73.1	75.1	73.1			74.1	
													73.59	




B.14 Uncontrolled Rooms – February

UNCONTROLLED ROOMS-February																									
	Room 401	Room 413	Room 416	Room 602	Room 608	Room 609	Room 619	Room 620	Room 623	Room 624	Room 627	Room 628	Sum												
Time	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW												
8:00 AM	1.428	0.298	0.162	0.284	0.436	0.198	0.094	0.102	0.119	0.35	0.773	0.329	4.57												
9:00 AM	1.234	0.341	0.166	0.258	0.289	0.166	0.105	0.215	0.248	0.258	0.538	0.261	4.08												
10:00 AM	1.601	0.22	0.161	0.297	0.316	0.073	0.098	0.156	0.037	0.209	0.239	0.24	3.65												
11:00 AM	1.408	0.158	0.128	0.137	0.208	0.115	0.104	0.079	0.023	0.148	0.205	0.22	2.93												
12:00 PM	1.461	0.127	0.136	0.059	0.249	0.051	0.058	0.071	0.034	0.157	0.222	0.246	2.87												
1:00 PM	1.336	0.119	0.135	0.088	0.187	0.045	0.047	0.206	0.059	0.137	0.279	0.198	2.84												
2:00 PM	1.072	0.108	0.144	0.035	0.185	0.042	0.147	0.034	0.061	0.112	0.149	0.18	2.27												
3:00 PM	1.037	0.14	0.15	0.031	0.197	0.058	0.097	0.038	0.056	0.157	0.202	0.181	2.34												
4:00 PM	0.741	0.153	0.227	0.035	0.233	0.132	0.079	0.025	0.055	0.224	0.261	0.271	2.44												
5:00 PM	0.821	0.115	0.218	0.1	0.23	0.231	0.133	0.036	0.061	0.232	0.476	0.272	2.93												
6:00 PM	0.886	0.101	0.193	0.103	0.23	0.206	0.069	0.174	0.055	0.324	0.425	0.271	3.04												
7:00 PM	1.116	0.085	0.19	0.232	0.208	0.164	0.047	0.157	0.173	0.273	0.416	0.276	3.34												
8:00 PM	1.079	0.099	0.258	0.274	0.234	0.264	0.093	0.045	0.127	0.235	0.318	0.249	3.28												
9:00 PM	1.085	0.091	0.24	0.279	0.159	0.143	0.165	0.069	0.148	0.246	0.264	0.368	3.26												
10:00 PM	1.149	0.161	0.214	0.477	0.175	0.191	0.15	0.073	0.167	0.237	0.323	0.38	3.70												
	17.454	2.316	2.722	2.689	3.536	2.079	1.486	1.48	1.423	3.299	5.09	3.942	47.52												
Temp	F	F	F	F	F	F	F	F	F	F	F	F	Avg. Temp												
8:00 AM	69.4	67.6	67.1	63	66.7	66.2	67.2	65.8	65.4	67.5	68.5	65.5	66.7												
9:00 AM	69.7	67.5	67.2	63.2	65.84	66.5	67.4	66.1	66.3	67.6	67	64.3	66.6												
10:00 AM	70.2	68.4	67.4	63.9	66.04	68.7	68.1	66.1	67.7	67.7	67.5	64.6	67.2												
11:00 AM	70.8	68.7	67.4	64.3	66.17	70.7	69.1	66.3	69.1	67.9	67	64.8	67.7												
12:00 PM	71.5	69.1	67.6	64.4	66.5	72.1	70.1	66.9	70.5	67.8	67.5	65.3	68.3												
1:00 PM	72.3	69.4	68	64.4	66.93	73.2	70.8	67.8	71.7	68	68.4	65.9	68.9												
2:00 PM	72.6	70.4	68.4	65	67.7	74	72.1	68.1	72.8	68.5	68.9	66.6	69.6												
3:00 PM	72.8	71.3	68.8	65.6	68.37	73.9	73.1	68.7	73.8	69	69.6	67	70.2												
4:00 PM	72.8	71.8	69.4	66.3	68.97	73.6	74.4	69.2	74.1	69.6	69.8	67.6	70.6												
5:00 PM	73.1	72.3	69.8	66.6	69.19	73.3	74.5	69.2	73.9	70	70.2	67.9	70.8												
6:00 PM	73.4	72.4	69.7	66.6	69.06	72.8	74.3	69.5	73.2	70.1	70.4	67.8	70.8												
7:00 PM	73.3	71.9	69.6	66.7	68.86	72.1	73.8	69.6	72.1	70.1	70.4	67.6	70.5												
8:00 PM	72.9	71.4	69.6	66.6	68.64	71.7	73.3	69.3	71.2	69.8	69.8	67.4	70.1												
9:00 PM	72.4	70.7	69.2	66.6	68.46	71	72.5	69.1	70.1	69.6	69.1	67.2	69.7												
10:00 PM	71.9	70.4	69	66.8	68.33	70.4	72.1	68.9	69.6	69.3	68.5	67	69.4												
													69.1												



B.15 Uncontrolled Rooms – March

UNCONTROLLED ROOMS-March, 2001													
	Room 401	Room 413	Room 416	Room 602	Room 608	Room 609	Room 619	Room 620	Room 623	Room 624	Room 627	Room 628	Sum
Time	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
8:00 AM	0.61	0.279	0.116	0.782	0.162	0.081	0.119	0.147	0.173	0.316	0.336	0.239	3.36
9:00 AM	0.67	0.275	0.077	0.493	0.125	0.177	0.082	0.242	0.119	0.192	0.231	0.198	2.88
10:00 AM	0.57	0.068	0.068	0.431	0.119	0.099	0.175	0.204	0.119	0.314	0.185	0.189	2.54
11:00 AM	0.44	0.022	0.106	0.336	0.114	0.119	0.08	0.136	0.156	0.333	0.169	0.121	2.13
12:00 PM	0.38	0.019	0.067	0.218	0.093	0.083	0.1	0.126	0.13	0.164	0.255	0.229	1.86
1:00 PM	0.34	0.019	0.058	0.198	0.104	0.063	0.08	0.118	0.098	0.202	0.148	0.205	1.63
2:00 PM	0.24	0.019	0.066	0.208	0.09	0.057	0.072	0.125	0.09	0.186	0.291	0.185	1.63
3:00 PM	0.7	0.031	0.079	0.296	0.079	0.061	0.114	0.107	0.086	0.167	0.232	0.173	2.13
4:00 PM	0.57	0.047	0.057	0.331	0.128	0.068	0.114	0.119	0.212	0.28	0.275	0.12	2.32
5:00 PM	0.58	0.078	0.069	0.27	0.279	0.209	0.073	0.134	0.2	0.411	0.281	0.167	2.75
6:00 PM	0.49	0.138	0.062	0.315	0.173	0.085	0.115	0.173	0.108	0.465	0.216	0.106	2.45
7:00 PM	0.56	0.107	0.05	0.268	0.201	0.083	0.073	0.225	0.119	0.373	0.213	0.149	2.42
8:00 PM	0.46	0.081	0.068	0.249	0.188	0.11	0.164	0.207	0.122	0.335	0.337	0.314	2.64
9:00 PM	0.44	0.226	0.105	0.271	0.194	0.083	0.225	0.253	0.173	0.252	0.399	0.314	2.94
10:00 PM	0.48	0.412	0.144	0.348	0.213	0.207	0.179	0.263	0.324	0.201	0.41	0.208	3.39
	7.53	1.82	1.19	5.01	2.26	1.59	1.77	2.58	2.23	4.19	3.98	2.92	37.06
Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Temp.	Avg. Temp.
Time	F	F	F	F	F	F	F	F	F	F	F	F	F
8:00 AM	66	65.5	66.2	66.3	64.8	66.2	68.5	66.1	66.2	66.1	65.6	64.4	66.0
9:00 AM	66.4	65.8	66.3	66.1	64.9	66.2	69.1	66.4	66.9	66.5	66	64.7	66.3
10:00 AM	67.3	66.1	66.6	66.3	64.9	68.4	70.1	66.1	68.2	66.3	67.1	64.8	66.9
11:00 AM	67.4	66.3	66.6	66.2	65.1	70.2	70.9	65.8	69.2	66.5	67.3	65.3	67.2
12:00 PM	67.7	67	66.7	66.6	65.6	71.4	71.5	66.2	69.6	66.9	67.7	65.8	67.7
1:00 PM	68.3	67.7	67.3	66.8	66.1	72.1	71.7	66.9	70.7	67	67.9	66.3	68.2
2:00 PM	69.1	68.6	67.9	67.4	66.7	72.6	72.2	67.4	71.5	67.1	68.4	66.8	68.8
3:00 PM	69.8	69.3	68.2	67.9	67.1	72.7	73	68	71.9	67.9	68.7	67	69.3
4:00 PM	70.3	69.8	68.5	68.3	67.5	72.6	73.5	68.4	72.3	68.4	69.2	67.1	69.7
5:00 PM	70.9	70.4	68.8	68.5	70.7	72.4	73.6	68.6	72.2	68.7	69.3	67.2	70.1
6:00 PM	71	70.8	68.9	68.3	67.8	72.2	73.3	68.9	71.7	69.1	69.1	67.2	69.9
7:00 PM	70.6	70.8	68.9	68.1	68	71.7	72.9	69.2	71.1	69.4	68.6	67.1	69.7
8:00 PM	70.1	69.9	68.9	68.2	68.1	71.1	72.5	69.4	70.4	69.4	68.3	67	69.4
9:00 PM	69.4	69.1	68.8	68.2	68.2	70.1	71.9	69.4	69.9	69.3	67.7	67	69.1
10:00 PM	68.6	68.9	68.6	68	68	69.7	71.8	69.4	69.6	68.9	67.6	66.6	68.8
													68.5



INTERNAL DISTRIBUTION

1. M. R. Ally, 3147, MS-6070
2. M. A. Brown, 4500N, MS-6186
3. J. E. Christian, 3147, MS-6070
4. P. D. Fairchild, 3147, MS-6070
5. M. A. Karnitz, 4500N, 6186
- 6-10. B. J. Kirby, 3147, MS-6070
11. J. J. Tomlinson, 3147, MS-6070
12. ORNL Central Research Library, 4500N, MS-6191
- 13-14. Laboratory Records, 4500N, MS-6285

EXTERNAL DISTRIBUTION

15. Fernando L. Alvarado, Professor, Department of Electrical and Computer Engineering, University of Wisconsin-Madison, 2544 Engineering Hall, 1415 Engineering Drive, Madison, WI 53706, E-mail: Alvarado@engr.wisc.edu
16. James R. Brodrick, EE-2J/Forrestal Building, U. S. Department of Energy, 1000 Independence Avenue, SW, Washington, DC 20585, E-mail: James.Brodrick@ee.doe.gov
17. Vikram S. Budhraja, President, Electric Power Group, LLC, 201 South Lake Avenue, Suite 400, Pasadena, CA 91101, E-mail: budhraja@electricpowergroup.com
18. Jim Dyer, Electric Power Group, LLC, 201 South Lake Avenue, Suite 400, Pasadena, CA 91101, E-mail: dyer@electricpowergroup.com
- 19-23. Joseph Eto, CERTS Program Manager, Lawrence Berkeley National Laboratory, Bldg. 90 Room 4126K, MS: 90-4000, University of California, Berkeley, CA 94720
24. Charles Goldman, Environmental Energy Technology, Lawrence Berkeley National Laboratory, 1 Cyclotron Road, MS: 90R4000, Berkeley, CA 94720, E-mail: CAGoldman@lbl.gov
25. George Gross, Professor, Department of Electrical and Computer Engineering, University of Illinois at Urbana-Champaign, 339 William L. Everitt Laboratory, MC 702, 1406 West Green Street, Urbana, IL 61801, E-mail: gross@staff.uiuc.edu
26. Carl H. Imhoff, Product Line Manager for Energy Operations and Maintenance, Pacific Northwest National Laboratory, 902 Battelle Boulevard, P. O. Box 999, Richland, WA 99352, E-mail: Carl.Imhoff@pnl.gov
27. Mark D. Levine, Director, Environmental Energy Technologies Division, Lawrence Berkeley National Laboratory, 1 Cyclotron Road, MS-90R3027D, Berkeley, CA 94720, E-mail: mdlevine@lbl.gov
28. Chris Marnay, Energy Analysis, Lawrence Berkeley National Laboratory, 1 Cyclotron Road, MS 90R4000, Berkeley, CA 94720, E-mail: C_Marnay@lbl.gov
29. Carlos A. Martinez, Electric Power Group, LLC, 201 South Lake Avenue, Suite 400, Pasadena, CA 91101, E-mail: martinca@edisonX.com

30. Timothy D. Mount, Professor, Applied Economics and Management, 214 Warren Hall, Cornell University, Ithaca, NY 14853-7801, E-mail: tdm2@cornell.edu
31. Shmuel S. Oren, Department of Industrial Engineering and Operations Research, 4119 Etcheverry Hall, University of California at Berkeley, Berkeley, CA 94720-1777, E-mail: shmuel@euler.berkeley.edu
32. Richard Orrison, EE-2J/Forrestal Building, U. S. Department of Energy, 1000 Independence Avenue, SW, Washington, DC 20585, E-mail: Richard.Orrison@EE.DOE.GOV
33. Philip N. Overholt, EE-16/Forrestal Building, U. S. Department of Energy, 1000 Independence Avenue, SW, Washington, DC 20585
34. Alonso Rodriguez, Electric Power Group, LLC, 201 South Lake Avenue, Suite 400, Pasadena, CA 91101
35. William D. Schulze, Professor, Applied Economics and Management, 301 Warren Hall, Cornell University, Ithaca, NY 14853-7801, E-mail: wds3@cornell.edu
36. Richard E. Schuler, Professor, Civil and Environmental Engineering and Economics, 466 Uris Hall, Cornell University, Ithaca, NY 14853-7801, E-mail: res1@cornell.edu
37. Sarosh N. Talukdar, Carnegie Mellon, ECE Department, Pittsburgh, PA 15213, E-mail: talukdar@ece.cmu.edu
38. Marjorie Tatro, Director, Energy and Transportation Security Department, Sandia National Laboratory, 1515 Eubank SE, MS 0704, Albuquerque, NM 87185-0704, E-mail: mltatro@sandia.gov
39. Robert J. Thomas, Director, Power Systems Engineering Research Center, Cornell University, 428 Phillips Hall, Ithaca, NY 14853, E-mail: rjt1@cornell.edu