

# FLOOR PROBE/CONTAMINATION MONITOR (NE MODEL FLP3D)

## TEST AND EVALUATION REPORT

**May 2003**

Ayman A. Shourbaji  
Peter J. Chiaro  
Fred R. Gibson  
Vaughn Patania

#### DOCUMENT AVAILABILITY

Reports produced after January 1, 1996, are generally available free via the U.S. Department of Energy (DOE) Information Bridge:

**Web site:** <http://www.osti.gov/bridge>

Reports produced before January 1, 1996, may be purchased by members of the public from the following source:

National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
**Telephone:** 703-605-6000 (1-800-553-6847)  
**TDD:** 703-487-4639  
**Fax:** 703-605-6900  
**E-mail:** [info@ntis.fedworld.gov](mailto:info@ntis.fedworld.gov)  
**Web site:** <http://www.ntis.gov/support/ordernowabout.htm>

Reports are available to DOE employees, DOE contractors, Energy Technology Data Exchange (ETDE) representatives, and International Nuclear Information System (INIS) representatives from the following source:

Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831  
**Telephone:** 865-576-8401  
**Fax:** 865-576-5728  
**E-mail:** [reports@adonis.osti.gov](mailto:reports@adonis.osti.gov)  
**Web site:** <http://www.osti.gov/contact.html>

#### DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

#### COPYRIGHT NOTICE

The submitted manuscript has been authored by a contractor of the U.S. Government under contract DE-AC05-00OR22725. Accordingly, the U.S. Government retains a paid-up, nonexclusive, irrevocable, worldwide license to publish or reproduce the published form of this contribution, prepare derivative works, distribute copies to the public, and perform publicly and display publicly, or allow others to do so, for U.S. Government purposes.

**FLOOR PROBE/CONTAMINATION MONITOR  
(NE MODEL FLP3D)**

**TEST AND EVALUATION REPORT**

Ayman A. Shourbaji  
Peter J. Chiaro  
Fred R. Gibson  
Vaughn Patania

April 2003

Prepared by  
OAK RIDGE NATIONAL LABORATORY  
Oak Ridge, Tennessee 37831-6285  
managed by  
UT-BATTELLE, LLC  
for the  
U.S. DEPARTMENT OF ENERGY  
under contract DE-AC05-00OR22725

**TABLE OF CONTENTS**

	<b>Page</b>
LIST OF FIGURES .....	iii
EXECUTIVE SUMMARY .....	iv
1. INTRODUCTION.....	1
2. BRIEF DESCRIPTION.....	1
3. TEST PROCEDURES .....	2
4. DISCUSSIONS .....	2
4.1 NORMAL TEMPERATURE, TEMPERATURE SHOCK, RELATIVE HUMIDITY TEST.....	2
4.2 RADIO FREQUENCY TEST.....	2
4.3 MAGNETIC FIELD TEST.....	3
4.4 DETECTION SENSITIVITY TEST.....	3
5. RECOMMENDATION.....	4
APPENDIX A ENVIRONMENTAL EFFECTS LABORATORY TEST RESULTS.....	5
APPENDIX B RADIO FREQUENCY FIELD TEST RESULTS .....	9
APPENDIX C MAGNETIC FIELD RESPONSE TEST RESULTS.....	11
APPENDIX D DETECTION SENSITIVITY TEST RESULTS .....	13
TABLE D1 SENSITIVITY MEASUREMENTS AT 0 MM (SOURCE TOUCHING DETECTOR).....	15
TABLE D2 SENSITIVITY MEASUREMENTS AT 22 MM (SOURCE 22 MM AWAY FROM DETECTOR).....	15

## LIST OF FIGURES

<b>Figure</b>		<b>Page</b>
D1.	Bottom view of probe indicating radiological measurement locations.....	14
D2.	Beta Sensitivity at 0 mm.....	16
D3.	Beta Sensitivity at 22mm.....	16
D4.	Alpha Sensitivity at 0 mm.....	17
D5.	Alpha Sensitivity at 22 mm.....	17

## EXECUTIVE SUMMARY

A floor contamination monitor model FLP3D manufactured by Saint-Gobain Crystals & Detectors UK Ltd was tested at Oak Ridge National Laboratory. The purpose of the test is to evaluate the monitor's performance as a mobile instrument capable of detecting alpha and/or beta contamination that may exist on a flat surface such as a floor. The monitor consists of a large area scintillation probe (600 cm<sup>2</sup>) and a rate meter mounted on heavy-duty wheels with a 22 mm separation between the monitored surface and the probe. Performance was evaluated under normal and severe environmental conditions in terms of temperature and humidity variations, and exposure to RF and magnetic fields. Sensitivity measurements were also made to determine the probe's efficiency for detecting alpha and beta contamination.

The overall performance of the floor monitor is considered satisfactory under the various environmental conditions with no major problems observed. The monitor is approximately 50% efficient for <sup>90</sup>Sr/<sup>90</sup>Y with the source placed in contact with the detector's protective grille (0 mm) and at a distance of 22 mm. However, in its present physical configuration, the floor monitor is inefficient in detecting alpha contamination due to the 22 mm separation between the surface to be monitored and the detector's surface. The alpha detection efficiency can be enhanced to a reasonable value by redesigning the brackets holding the heavy-duty wheels to reduce the height between the surface to be monitored and the surface of the probe to a few millimeters. For use at ORNL, this change is recommended.

## 1. INTRODUCTION

A floor contamination monitor model FLP3D manufactured by Saint-Gobain Crystals & Detectors UK Ltd was tested at Oak Ridge National Laboratory (ORNL). The purpose of the test is to evaluate the monitor's performance as a mobile instrument capable of detecting alpha and/or beta contamination that may exist on a flat surface such as a floor. The monitor's performance was evaluated under normal and severe environmental conditions in terms of temperature and humidity variations, and exposure to RF and magnetic fields. Tests included gradual temperature variations from ambient to extreme temperatures (50° C, -10° C), thermal shock by rapid temperature cycling between ambient and extreme temperatures, exposure to radio frequency fields over a wide range of frequency (0.1 MHz to 1000 MHz), and exposure to AC and DC magnetic fields. Sensitivity measurements were also made to determine the probe's efficiency for detecting alpha and beta contaminations.

## 2. BRIEF DESCRIPTION

The FLP3D floor monitor consists of a scintillation probe model FLP3 with a 600 cm<sup>2</sup> sensitive area, and a ratemeter model DELTA5B. The probe, photomultiplier tube, and thick film resistor network are housed in a light-tight plastic housing. The ratemeter is designed to fit securely on top of the probe housing through two runners and can be easily detached. High voltage required for probe operation is supplied by the ratemeter. Various modes of operation can be selected to monitor alpha contamination only, beta contamination only, or alpha plus beta. Measurement capability includes measured count rate or contamination level. User-selectable display units include:

- Count per second (cps)
- Count per minute (cpm)
- Bq
- Dpm, Bq/cm<sup>2</sup>

### Specific Notes:

1. For better results, the manufacturer recommends allowing a one-second exposure time so that the entire sensitive area of the probe is exposed to the measurement area. Based on the probe dimension of 20 cm in the monitoring direction, the recommended speed is 20 cm per second.
2. The standard floor monitor has four small wheels (balls) attached to the bottom of the probe housing in such a way that the height between the probe and the surface to be monitored can be adjusted to either 2 mm (recommended for better alpha efficiency) or 8 mm for beta. The floor monitor under evaluation is equipped with castors for mobility on rough surfaces. The use of the castors option causes an increase in the minimum distance from 2 mm to 22 mm. Alpha efficiency is severely reduced. A change in the castor design is highly recommended.

### 3. TEST PROCEDURES

The following tests were performed to evaluate the overall performance of the floor monitor for detecting alpha and beta contamination under various environmental conditions. A brief description of each test procedure is given in section 4.

- Normal Temperature
- Temperature Shock
- Relative Humidity
- Radio Frequency (RF) Susceptibility
- Magnetic Field Susceptibility
- Detection Sensitivity Test

Test results are listed in Appendix A, B, C, and D.

### 4. DISCUSSIONS

The following discussions summarize the findings from each test performed.

#### 4.1 Normal Temperature, Temperature Shock, Relative Humidity Test

The floor monitor was tested under various temperature and humidity conditions using capabilities available at the Environmental Effects Laboratory (EELab). The test was conducted with the monitor exposed to a plated source,  $^{137}\text{Cs}$ . The purpose of the test was to expose the equipment to an environment of changing temperatures and humidity at varying rates, simulating normal as well as harsh operating environments. Data collected is reported in Appendix A.

**Conclusion:** The overall performance of the monitor was satisfactory during the normal temperature test cycle, the temperature shock cycle, and the humidity test cycle. Minor deviations were noted during the temperature shock cycle at two steps. Between  $-10^{\circ}\text{C}$  and  $22^{\circ}\text{C}$ , the confidence (+) interval was slightly higher than the calculated value. Between  $22^{\circ}\text{C}$  and  $50^{\circ}\text{C}$ , the mean and the confidence (-) interval were slightly lower than the calculated values. These deviations do not constitute any operational limitation and are not considered indicators of a serious systematic problem.

#### 4.2 Radio Frequency Test

The floor monitor was tested to determine its susceptibility to RF fields. The test was conducted with the monitor inside the GTEM test chamber while being exposed to a  $^{137}\text{Cs}$  source. An RF field was applied at 20 V/m intensity from 100 kHz to 1000 MHz (1 GHz). Data collected from this test is reported in Appendix B.

**Conclusion:** The floor monitor performed satisfactorily over the test frequency range with the exception being between 75 MHz and 82 MHz. At these frequencies, the display became erratic and various status/mode indicators flashed ON and OFF.



### 4.3 Magnetic Field Test

The magnetic field test was conducted by placing the floor monitor inside a Merrit Coil magnetic field generator with the capability to apply a DC magnetic field up to 12.5 Gauss and an AC magnetic field up to 4.5 Gauss at 60 Hz. Measurements were made in two different orientations that were 90° apart at an intensity of 10 Gauss. The system's performance was measured using a 7 μCi <sup>137</sup>Cs source. Test results are reported in Appendix C.

**Conclusion:** The monitor was susceptible when exposed to the DC field in both orientations. No susceptibilities were observed when the monitor was exposed to the AC fields.

### 4.4 Detection Sensitivity Test

Several measurements were made to determine the probe's sensitivity to detecting alpha and/or beta contamination across the probe's surface area. As illustrated by Figure D1, nine alpha and nine beta measurements were taken along the perimeter and the center of the probe using <sup>239</sup>Pu and <sup>90</sup>Sr/<sup>90</sup>Y sources with known activities. Two sets of data were obtained for each source; one with the source in contact with the probe's grille, marked as zero mm, and the other with the source at a distance of 22 mm. According to the present monitoring configuration, the 22 mm distance represents the lowest possible height between the surface to be monitored and the probe's surface. Data are tabulated in Tables D1 and D2.

Table D1 contains the data recorded for alpha and beta at the zero mm position. The beta measurements clearly indicate that the measurements are fairly uniformly distributed over the probe's active area with an efficiency of approximately 50%, except for the center where it's slightly higher, 63%, as illustrated by Figure D2. The alpha measurements, on the other hand, indicate a uniform distribution with much lower efficiency, approximately 14%, as shown in Figure D4. The alpha and beta measurements for the 22 mm position are tabulated in Table D2. Consistency in beta measurements at each position is quite obvious as indicated by the uniformity of the data and the detection efficiency as shown in Figure D3. Alpha radiation sensitivity is quite poor at the 22 mm position as can be seen in Figure D4. The efficiency determined with the source in the center position is greatest (~2.5%) and drops off sharply as it is moved from the center position. When the detector-to-source distance is reduced to contact, the sensitivity is greatly improved and relatively flat over the sensitive surface of the detector as can be seen in Figure D5.

**Conclusion:** The floor monitor in its present physical configuration appears to be efficient and reliable in detecting and monitoring beta contamination. As an alpha contamination monitor, it's considered to be inefficient and unreliable. Enhancement can be made in alpha contamination detection by redesigning the brackets holding the wheels allowing the probe's surface to be much closer to the surfaces to be monitored.

## **5. RECOMMENDATION**

In order to utilize the full capabilities of the floor monitor, it is recommended that the brackets holding the heavy-duty wheels be redesigned to bring the probe closer to the surface to be monitored. The manufacturer recommended height for an efficient alpha detection is 2 mm. Such a design change would allow the monitor to be useful for monitoring alpha and beta contamination.

**APPENDIX A**

**ENVIRONMENTAL EFFECTS LABORATORY TEST RESULTS  
(TEMPERATURE, TEMPERATURE SHOCK, HUMIDITY)**

# Environmental Effects Laboratory Test Report

## Normal Temperature

**Manufacturer:** Bicon/ NE Technology Delta 5 Floor Monitor

**Model:** FLM30

**Date(s) Tested:** 10/23/2002 thru 10/26/2002

**Number Tested:** 1      **Serial Number(s):** 129

**Range(s) Tested:** N/A

**Procedure Used:** ORNL-EF-01 Rev 0

**Basic Test Parameters:** -10 to +50 C (+14 to 122 F)

**Acceptance Criteria:** ± 15% of the nominal mean from 0 to 40, ± 20% of the nominal mean at -10 and 50

**Data Collection Method:** Data was obtained by observing each unit's response before and during exposure. Confidence intervals, determined using the 0.95 quantile of the students t distribution (95% confidence interval), are used to ascertain whether results are conclusive or inconclusive.

### Observations

Degrees C	Mean Readings		Results Conclusive		Description
	In	Out	Yes	No	
-10	1		1		
0	1		1		
10	1		1		
30	1		1		
40	1		1		
50	1		1		

key: h=high, l=low

**General Comments:** None

Environmental Effects Laboratory  
Test Report

**Temperature Shock**

**Manufacturer:** Bicon/ NE Technology Delta 5 Floor Monitor

**Model:** FLM30

**Date(s) Tested:** 10/23/2002 thru 10/26/2002

**Number tested:** 1 Serial Number(s): 129

**Range(s) tested:** N/A

**Procedure Used:** ORNL-EF-02, dated 03/03/95

**Basic Test Parameters:** Unit(s) exposed to rapid temperature changes of 22 to -10, -10 to 22, 22 to 50, and 50 to 22 (in C).

**Acceptance Criteria:** ± 15% of the nominal mean taken at 22 C.

**Data Collection Method:** Data was obtained by observing each unit's response using a camera and VCR. Confidence intervals, determined using the 0.95 quantile of the students t distribution (95% confidence interval), are used to ascertain whether results are conclusive or inconclusive.

**Observations**

	Mean Readings		Results Conclusive ?		Description
	In	Out	Yes	No	
22 to -10	1		1		
-10 to 22	1			1	Conf-Int (+) > Acceptance Range
22 to 50		1 (l)	1		Mean < Acceptance Range Conf-Int (-) < Acceptance Range.
50 to 22	1		1		

key: h=high, l=low

**General Comments:** None

Environmental Effects Laboratory  
Test Report

**Relative Humidity**

**Manufacturer:** Bicon/ NE Technology Delta 5 Floor Monitor

**Model:** FLM30

**Date(s) Tested:** 10/23/2002 thru 10/26/2002

**Number Tested:** 1 **Serial Number(s):** 129

**Range(s) Tested:** N/A

**Procedure Used:** ORNL-EF-03 Rev. No. 0

**Basic Test Parameters:** 40% relative humidity (RH) and 95% RH at 35° +/- 2 °C

**Acceptance Criteria:** ± 15% of the nominal mean determined at 40% when exposed 95% then back 40%.

**Data Collection Method:** Data was obtained by observing each unit's response before and during exposure. Confidence intervals, determined using the 0.95 quantile of the students t distribution (95% confidence interval), are used to ascertain whether results are conclusive or inconclusive.

**Observations**

Relative Humidity	Mean Readings		Results Conclusive ?		Description
	In	Out	Yes	No	
95%	1		1		
40%	1		1		

**key: h=high, l=low**

**General Comments:** The 95% soak time was 19 hours.

**APPENDIX B**  
**RADIO FREQUENCY FIELD TEST RESULTS**

# Environmental Effects Laboratory

## Test Report

### Radio Frequency - Microwave Field

Manufacturer: Bicron NE Technology Delta 5 Floor Monitor

Model: FLM30

Date(s) 11/5/2002

Number tested: 1

Serial Number(s): 129

Range(s) tested: N/A

Test Plan/Procedure Used: ORNL-IR-02, Rev. 1

Basic Test Parameters: Frequency Scan of 0.1 to 1000 MHz.

20 ( $\pm 2$ ) Volts/meter Amplitude Modulated with 1 kHz at 80%.

Acceptance Criteria:  $\pm 15\%$  of the nominal mean and stability during scan.

Data Collection Method:

Data was obtained by observing each unit's response before and during exposure. Confidence intervals, determined using the 0.95 quantile of the students t distribution (95% confidence interval), are used to ascertain whether results are conclusive or inconclusive.

---

### Observations

**The following anomaly was observed:**

**Between 75Mhz and 82Mhz the display became erratic, with numbers disappearing, over-range indicated on bar display, and various other status or mode indicators flashing on and off in an unpredictable way.**

**At all other frequencies, values were within the acceptance range.**

General Comments: None



**APPENDIX C**  
**MAGNETIC FIELD RESPONSE TEST RESULTS**

# Environmental Effects Laboratory Test Report

## Magnetic Field

Manufacturer: Bicron Delta 5 Floor Monitor  
 Model: FLM 3D  
 Date(s) Tested: 10/30/2002  
 Number Tested: 1 Serial Number(s): 129  
 Range(s) Tested: N/A  
 Procedure Used: ORNL-IR-05  
 Basic Test Parameters: 10 Gauss (10 Oersted) DC and 60 Hz (1.26 Gauss) AC in two orientations relative to the magnetic field.

Acceptance Criteria: ± 15% of the nominal mean without any field present.

Data Collection Method: Data was obtained by observing the response of each unit under test before and during exposure. Confidence intervals, determined using the 0.95 quantile of the students t distribution (95% confidence interval), are used to ascertain whether results are conclusive or inconclusive.

### Observations


	Mean Readings		Results Conclusive ?		Description
	In	Out	Yes	No	
10 Gauss DC Orientation 1		1 (L)	1		
10 Gauss DC Orientation 2		1 (L)	1		
60 Hz AC Orientation 1	1		1		
60 Hz AC Orientation 2	1		1		

key : H=high, L = low

Comments: None  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**APPENDIX D**

**DETECTION SENSITIVITY TEST RESULTS**



AB: Front Edge  
 CD: Rear Edge


**Figure D1. Bottom view of probe indicating radiological measurement locations**

**Table D1. Sensitivity Measurements at 0 mm (Source touching detector)**

Measurement Point	Source: <sup>90</sup> Sr <sup>90</sup> Y (#4853), 2" Daim, 4,010/3400dpm					Source: <sup>239</sup> Pu (#Pu-239-3602), 1" Diam., 115,052 dpm				
	Beta at 0 mm (cpm)			Beta Average	Beta Efficiency (%)	Alpha at 0 mm (kcpm)			Alpha Average	Alpha Efficiency (%)
m1	1961.0	1838.0	1778.0	1859.0	54.7	15.7	15.4	15.2	15.4	13.41
m2	1938.0	2003.0	1841.0	1927.3	56.7	17.2	17.4	17.6	17.4	15.12
m3	1946.0	1871.0	2021.0	1946.0	57.2	15.2	15.8	15.6	15.5	13.50
m4	1941.0	1841.0	1934.0	1905.3	56.0	14.6	14.5	14.2	14.4	12.55
m5	2145.0	2280.0	2003.0	2142.7	63.0	17.0	16.8	16.4	16.7	14.54
m6	1913.0	1860.0	1913.0	1895.3	55.7	14.7	14.8	15.0	14.8	12.89
m7	1818.0	1710.0	1549.0	1692.3	49.8	14.0	13.9	13.7	13.9	12.05
m8	1673.0	1628.0	1703.0	1668.0	49.1	14.8	14.7	15.0	14.8	12.89
m9	1658.0	1721.0	1616.0	1665.0	49.0	12.9	13.5	14.1	13.5	11.73


**Table D2. Sensitivity Measurements at 22 mm (Source 22 mm away from detector)**

Measurement Point	Source: <sup>90</sup> Sr <sup>90</sup> Y (#4853), 2" Daim, 4,010/3400dpm					Source: <sup>239</sup> Pu (#Pu-239-3602), 1" Diam., 115,052 dpm				
	Beta at 22mm (cpm)			Beta Average	Beta Efficiency (%)	Alpha at 22mm (cpm)			Alpha Average	Alpha Efficiency (%)
m1	1,864.0	1,800.0	1,740.0	1,801.3	53.0	128.0	113.0	93.8	111.6	0.10
m2	2,048.0	1,969.0	1,890.0	1,969.0	57.9	371.0	304.0	274.0	316.3	0.27
m3	1,838.0	1,834.0	1,909.0	1,860.3	54.7	234.0	161.0	135.0	176.7	0.15
m4	2,020.0	1,969.0	1,924.0	1,971.0	58.0	709.0	780.0	810.0	766.3	0.67
m5	2,230.0	2,175.0	2,094.0	2,166.3	63.7	2,611.0	2,562.0	3,379.0	2,850.7	2.48
m6	1,984.0	1,969.0	2,100.0	2,017.7	59.3	870.0	828.0	739.0	812.3	0.71
m7	1,841.0	1,830.0	1,894.0	1,855.0	54.6	18.8	15.0	22.5	18.8	0.02
m8	1,945.0	1,879.0	1,845.0	1,889.7	55.6	11.3	15.0	18.8	15.0	0.01
m9	1,645.0	1,759.0	1,823.0	1,742.3	51.2	7.5	11.3	15.0	11.3	0.01




X,Y,BC0

**Figure D2. Beta Sensitivity at 0 mm**




X,Y,BC22

**Figure D3. Beta Sensitivity at 22mm**



X, Y, AC22

**Figure D4. Alpha Sensitivity at 22 mm**



X, Y, AC0

**Figure D5. Alpha Sensitivity at 0 mm**

## **INTERNAL DISTRIBUTION**

1. Peter J. Chiaro, Jr.
2. Edward C. Fox
3. Fred R. Gibson
4. Donald C. Gregory
5. James E. Hardy
6. Jerry B. Hunt
7. Perry D. Pruitt
8. Kevin L. Reaves
9. William L. Robbins
10. Ayman A. Shourbaji
11. – 12. Central Research Library
13. Laboratory Records

## **EXTERNAL DISTRIBUTION**

Richard Oxford, Thermo Electron RMP, Solon, OH