

Detector Characterization Report

Response Related to Linear Movement and Radiation Levels for an Oak Ridge National Laboratory (ORNL)-Developed Ion Chamber and a Commercial Ion Chamber

P. J. Chiaro, Jr.
E. R. Tapp
J. S. Bogard



DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

COPYRIGHT NOTICE

The submitted manuscript has been authored by a contractor of the U.S. Government under contract DE-AC05-00OR22725. Accordingly, the U.S. Government retains a paid-up, nonexclusive, irrevocable, worldwide license to publish or reproduce the published form of this contribution, prepare derivative works, distribute copies to the public, and perform publicly and display publicly, or allow others to do so, for U.S. Government purposes.

DETECTOR CHARACTERIZATION REPORT

**RESPONSE RELATED TO LINEAR MOVEMENT AND RADIATION LEVELS FOR
AN OAK RIDGE NATIONAL LABORATORY (ORNL)-DEVELOPED ION CHAMBER
AND A COMMERCIAL ION CHAMBER**

P. J. Chiaro, Jr.
E. R. Tapp
J. S. Bogard

Instrumentation and Controls Division

October 2000

Prepared by
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37831-6285
Managed by
UT-BATTELLE
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-00OR22725

CONTENTS

1. BACKGROUND	1
2. CHARACTERIZATION PROTOCOL	1
3. CHARACTERIZATION RESULTS	2
4. DESCRIPTIONS OF ATTACHED CHARTS.....	2
APPENDIX 1A.....	4
APPENDIX 1B.....	5
APPENDIX 1C.....	6
APPENDIX 2A.....	7
APPENDIX 2B.....	8
APPENDIX 2C.....	9
APPENDIX 3A.....	10
APPENDIX 3B.....	11
APPENDIX 3C.....	12
APPENDIX 4A.....	13
APPENDIX 4B.....	14
APPENDIX 4C.....	15

DETECTOR CHARACTERIZATION REPORT

RESPONSE RELATED TO LINEAR MOVEMENT AND RADIATION LEVELS FOR AN OAK RIDGE NATIONAL LABORATORY (ORNL)-DEVELOPED ION CHAMBER AND A COMMERCIAL ION CHAMBER

1. BACKGROUND

Recent activities regarding the safeguarding of radioactive material have indicated there is a need to use radiation sensors to monitor intentional or unintentional material movement. Existing radiation detection systems were not typically designed for this type of operation since most of their use accounted for monitoring material while the material is stationary.

To ensure that a radiation monitoring system is capable of detecting the movement of radioactive material, a series of tests were needed. These tests would need to be performed in known radiological conditions, under controlled environmental conditions, and at known movement speeds. The Radiation Effects Facility (REF), located at the Radiation Calibration Laboratory, provided the necessary capabilities to perform these tests.

This report provides a compilation of the results from a characterization of two different sensors—a simple, air ionization chamber-based sensor developed at ORNL that consists of an ion chamber connected to a separate amplifier, and an Eberline model RO-7-LD. The RO-7-LD is also an air ionization chamber-based sensor, but the electronics are in the same physical package.

2. CHARACTERIZATION PROTOCOL

The evaluation process consists of establishing a sensor's nominal response at different horizontal positions along a flat plane perpendicular to a radiation beam followed by its response to the radiation field as it moves horizontally through the field. Although theoretical results are possible, real data obtained from actual exposures is more reliable and can be used to validate theoretical estimations. Since moving the source was undesirable, the test system was configured to move the sensor.

The characterization consisted of a) establishing the nominal response to a known radiation field from ^{137}Cs at fixed locations, b) moving the sensor through the radiation field, and c) tracking the response results.

A total of 600 readings over a period of one minute were taken to obtain each stationary response. Readings were obtained at 0.5 second intervals for each moving test. Movement speeds were 10 cm and 20 cm per second. The measured radiation level as provided by staff personnel at the REF was 50 mR/hr and 502 mR/hr.

The protocol followed is as follows:

1. Position the sensor on the track assembly.

2. Move the sensor to the nominal position (centered both horizontally and vertically in the radiation beam).
3. Expose the sensor to a 50 mR/hr ¹³⁷Cs radiation field and record a series of readings.
4. Determine and record the mean response.
5. Reduce the radiation field and move the sensor to the far end of the linear positioning system (in this test the position was 160 cm from the center position). Record the position from beam center.
6. Activate the radiation field and record the sensor's mean response.
7. Move the sensor in 20-cm increments and record the sensor's position (relative to beam center) and mean response.
8. Repeat step 7 until reaching the same distance on the other side of the beam.
9. Reduce the radiation field and reposition the sensor to the initial starting point.
10. Set the sensor movement speed to 10 cm/sec.
11. Activate the radiation field and initiate movement recording the detector response at 0.5-second intervals (max).
12. Plot the data to compare results from steps 6 through 8 with those results from step 11.
13. Repeat steps 10 through 12 using a speed of 20 cm/sec.
14. Repeat steps 2 through 13 at 500 mR/hr.

3. CHARACTERIZATION RESULTS

The results indicated that each detector responded to the change of activity at the speeds used. In addition, each detector's response approached 100% of the measured field value obtained from stationary measurements.

The ORNL sensor had a much lower relative response to radiation when compared to the RO-7-LD sensor. This was expected due to the design of the ORNL system. In addition, the ORNL sensor had a much greater contribution from "noise" as can be seen from the attached charts. This is much more apparent at the lower dose rate. Substantial increases in measured radiation levels can be seen from both sensors when exposed to the 502-mr/hr field. Additional evaluation of the response data will be required to determine maximum permissible movement speeds based on measured radiation levels. This should be done on a system as opposed to the component (the sensor), which was used for this evaluation.

4. DESCRIPTIONS OF ATTACHED CHARTS

Appendix 1A – ORNL sensor response as it moves through a 50-mR/hr field at 10 cm/second. Each measurement obtained from the stationary position is indicated on the chart. A direct comparison to the RO-7-LD is available in Appendix 1C. The measured response from the center position (mean response from +5 to -5 cm range) was 96% of the response obtained when the sensor was stationary.

Appendix 1B – RO-7-LD response as it moves through a 50-mR/hr field at 10 cm/second. The stationary measurement readings are identified on the chart. A direct comparison to the ORNL sensor is contained in Appendix 1C. The measured response from the center position (mean response from +5 to -5 cm range) was 100% of the response obtained when the sensor was stationary.

Appendix 1C – This chart displays the response comparison between the two sensors.

Appendix 2A – ORNL sensor response as it moves through a 50-mR/hr field at 20 cm/second. Each measurement obtained from the stationary position is indicated on the chart. A direct comparison to the RO-7-LD is available in Appendix 2C. It can be seen that the response is skewed due to the movement speed and response time. The measured response from the center position (mean response from +5 to –5 cm range) was 108% of the response obtained when the sensor was stationary.

Appendix 2B – RO-7-LD response as it moves through a 50-mR/hr field at 20 cm/second. The stationary measurement readings are identified on the chart. A direct comparison to the ORNL sensor is contained in Appendix 2C. As with the ORNL sensor, the response is skewed due to the movement speed and the response time of the sensor. The measured response from the center position (mean response from +5 to –5 cm range) was 93% of the response obtained when the sensor was stationary.

Appendix 2C – This chart displays the response comparison between the two sensors.

Appendix 3A - ORNL sensor response as it moves through a 502-mR/hr field at 10 cm/second. Each measurement obtained from the stationary position is indicated on the chart. A direct comparison to the RO-7-LD is available in Appendix 3C. The measured response from the center position (mean response from +5 to –5 cm range) was 98% of the response obtained when the sensor was stationary.

Appendix 3B – RO-7-LD response as it moves through a 502-mR/hr field at 10 cm/second. The stationary measurement readings are identified on the chart. A direct comparison to the ORNL sensor is contained in Appendix 3C. The measured response from the center position (mean response from +5 to –5 cm range) was 101% of the response obtained when the sensor was stationary.


Appendix 3C – This chart displays the response comparison between the two sensors.

Appendix 4A - ORNL sensor response as it moves through a 502-mR/hr field at 20 cm/second. Each measurement obtained from the stationary position is indicated on the chart. A direct comparison to the RO-7-LD is available in Appendix 4C. The measured response from the center position (mean response from +5 to –5 cm range) was 87% of the response obtained when the sensor was stationary.

Appendix 4B – RO-7-LD response as it moves through a 502-mR/hr field at 20 cm/second. The stationary measurement readings are identified on the chart. A direct comparison to the ORNL sensor is contained in Appendix 4C. The measured response from the center position (mean response from +5 to –5 cm range) was 97% of the response obtained when the sensor was stationary.


Appendix 4C – This chart displays the response comparison between the two sensors.

ORNL Sensor
10 cm/sec. Speed @ 50 mr/hr




APPENDIX 1A

RO-7-LD
10 cm/sec. Speed @ 50 mr/hr




APPENDIX 1B

Comparison Chart
10 cm/sec. Speed @ 50 mr/hr




APPENDIX 1C

ORNL Sensor
20 cm/sec. Speed @ 50 mr/hr




APPENDIX 2A

RO-7-LD
20 cm/sec. Speed @ 50 mr/hr




APPENDIX 2B

Comparison Chart
20 cm/sec. Speed @ 50 mr/hr




APPENDIX 2C

ORNL Sensor
10 cm/sec. Speed @ 502 mr/hr




APPENDIX 3A

RO-7-LD
10 cm/sec. Speed @ 502 mr/hr



APPENDIX 3B


Comparison Chart
10 cm/sec. Speed @ 502 mr/hr



Movement Direction = Left to Right


APPENDIX 3C

ORNL Sensor
20 cm/sec. Speed @ 502 mr/hr




APPENDIX 4A

RO-7-LD
20 cm/sec. Speed @ 502 mr/hr



APPENDIX 4B

Comparison Chart
20 cm/sec. Speed @ 502 mr/hr



APPENDIX 4C

INTERNAL DISTRIBUTION

1. J. S. Bogard
2. P. J. Chiaro, Jr.
3. J. E. Hardy
4. D. W. McDonald
5. E. R. Tapp
6. J. D. White
7. ORNL Laboratory Records-RC

EXTERNAL DISTRIBUTION

8. H. Y. Rollen, Jr., Lockheed Martin Energy Systems, P.O. Box 2009, Bldg. 1099COM, Oak Ridge, TN 37831-8257
9. J. M. Whitaker, Lockheed Martin Energy Systems, P.O. Box 2009, Bldg. 1099COM, Oak Ridge, TN 37831-8257