

Nuclear Hybrid Energy Systems Initial Integrated Case Study Development and Analysis



T. J. Harrison
M. S. Greenwood

December 2016

Approved for public release.
Distribution is unlimited.

DOCUMENT AVAILABILITY

Reports produced after January 1, 1996, are generally available free via US Department of Energy (DOE) SciTech Connect.

Website <http://www.osti.gov/scitech/>

Reports produced before January 1, 1996, may be purchased by members of the public from the following source:

National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
Telephone 703-605-6000 (1-800-553-6847)
TDD 703-487-4639
Fax 703-605-6900
E-mail info@ntis.gov
Website <http://www.ntis.gov/help/ordermethods.aspx>

Reports are available to DOE employees, DOE contractors, Energy Technology Data Exchange representatives, and International Nuclear Information System representatives from the following source:

Office of Scientific and Technical Information
PO Box 62
Oak Ridge, TN 37831
Telephone 865-576-8401
Fax 865-576-5728
E-mail reports@osti.gov
Website <http://www.osti.gov/contact.html>

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Reactor and Nuclear Systems Division

Nuclear Hybrid Energy Systems Initial Integrated Case Study Development and Analysis

T. J. Harrison
M. S. Greenwood

Date Published: December 2016

Prepared by
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, TN 37831-6283
managed by
UT-BATTELLE, LLC
for the
US DEPARTMENT OF ENERGY
under contract DE-AC05-00OR22725

CONTENTS

CONTENTS.....	iii
LIST OF TABLES.....	v
LIST OF FIGURES.....	v
ACRONYMS.....	vii
ABSTRACT.....	1
1. INTRODUCTION AND BACKGROUND.....	2
2. NUCLEAR HYBRID ENERGY SYSTEM BASE CASE.....	3
2.1 THE POWER PLANTS.....	3
2.2 THE BATTERY.....	3
2.3 THE INDUSTRIAL CUSTOMER.....	3
2.4 THE THERMAL MANIFOLD.....	4
3. FIGURE OF MERIT DEFINITION AND ANALYSIS METHODOLOGY.....	4
3.1 THE COST-BASED FIGURE OF MERIT.....	4
3.1.1 The Rationale for the Cost-Based Figure of Merit.....	4
3.1.2 Definition of Costs.....	4
3.1.3 Cost Estimation.....	5
3.2 EVALUATION OF INDIVIDUAL SYSTEM COSTS.....	8
3.2.1 Derivation of Generic Cost.....	8
3.2.2 Total Nuclear Power Cost.....	9
3.2.3 Total Gas Power Cost.....	10
3.2.4 Total Battery Cost.....	10
3.2.5 Unmet Demand Cost.....	10
4. CASE ANALYSIS.....	11
4.1 SUMMARY OF THE PROGRESSION OF ANALYTICAL METHODS AND RESULTS.....	11
4.2 SIMPLE ESTIMATE.....	11
4.3 APPLICATION OF THE DEMAND PROFILE.....	11
4.4 INCLUDING THE BATTERY.....	11
4.5 SIMPLE OPTIMIZATION OF THE INTEGRATED ELECTRICITY SYSTEM.....	12
4.6 INTRODUCTION OF THE TIME SERIES.....	12
4.7 INTRODUCTION OF THE THERMAL POWER CUSTOMER.....	13
4.8 TRADE STUDIES.....	14
4.9 SOURCES AND IMPACTS OF UNCERTAINTY IN THE MODELING AND ANALYSIS.....	14
4.9.1 Cost uncertainty.....	14
4.9.2 Cost volatility in addition to uncertainty.....	15
4.10 ANALYTICAL SUMMARY.....	16
5. THE DYNAMIC MODEL.....	16
5.1 THE TIGHTLY COUPLED NHES.....	16
6. CONTINUING AND FUTURE WORK.....	19
7. SUMMARY.....	20
8. WORKS CITED.....	21
9. APPENDIX.....	A-1
9.1 SIMPLE ADDITIVE COST ESTIMATE.....	A-1
9.2 EVALUATION OF TOTAL SYSTEM COST—REACTOR AND GAS TURBINE SYSTEM.....	A-2

9.3	EVALUATION OF TOTAL SYSTEM COST: REACTOR, GAS TURBINE, AND BATTERY SYSTEM	A-6
9.4	OPTIMIZATION OF THE REACTOR, GAS, AND BATTERY SYSTEM.....	A-8
9.5	NONECONOMIC FIGURES OF MERIT	A-13
9.6	INTRODUCTION OF THE INDUSTRY CUSTOMER.....	A-16
9.7	TRADE STUDIES IN GAS AND UNMET DEMAND COSTS	A-18

LIST OF TABLES

Table 1. Capital costs for power plants.....	5
Table 2. Fixed O&M costs for power plants.....	6
Table 3. Variable O&M costs for power plants.....	6
Table 4. Fuel costs for power plants.....	7
Table 5. CO ₂ emissions for power plants.....	7
Table 6. Identification and brief description of a tightly coupled NHES.....	17
Table 7. Power peaking by region.....	A-3
Table 8. Power production in a nuclear/gas system.....	A-6
Table 9. Power production in a nuclear/gas/battery system.....	A-8
Table 10. Power production in a nuclear/gas/battery system—Optimization Step 1.....	A-10
Table 11. Power production in a nuclear/gas/battery system—Optimization Step 2.....	A-11
Table 12. Power production in a nuclear/gas/battery system—Optimization Step 3.....	A-12
Table 13. Summary of case analyses.....	A-12
Table 14. Cost-optimized parameters.....	A-13
Table 15. Impact of gas prices on system optimization.....	A-19
Table 16. Impact of unmet demand prices on system optimization.....	A-19

LIST OF FIGURES

Fig. 1. Tightly coupled hybrid energy system.....	17
Fig. 2. Modified tightly coupled energy system.....	18
Fig. 3. The normalized power set point and steam turbine output.....	19
Fig. 4. NHES model analysis and optimization (Harrison 2016).....	20
Fig. 5. Levelized cost of nuclear and gas as a function of capacity factor (emissions cost = \$0/MT).....	A-1
Fig. 6. Reactor and gas turbine with common connection to the grid.....	A-2
Fig. 7. Cumulative density demand/mean demand.....	A-4
Fig. 8. Cumulative density din MWe.....	A-4
Fig. 9. Example dispatch curve (U.S. Energy Information Administration n.d.).....	A-5
Fig. 10. Reactor, gas turbine, and battery with common connection to the grid.....	A-7
Fig. 11. Levelized cost of nuclear and gas as a function of capacity factor (emissions cost = \$0/MT).....	A-9
Fig. 12. Power generation time series by type, unoptimized and unconstrained.....	A-14
Fig. 13. Power generation time series by type, first optimization with constraints.....	A-15
Fig. 14. Industry customer integration.....	A-17

ACRONYMS

BTU	British thermal unit
D&D	decommissioning and decontamination
EIA	U.S. Energy Information Administration
EPRI	Electric Power Research Institute
LWR	light water reactor
MT	metric ton
NEI	Nuclear Energy Institute
NHES	Nuclear Hybrid Energy System
O&M	operation and maintenance
PJM	Pennsylvania-New Jersey-Maryland

ABSTRACT

The US Department of Energy Office of Nuclear Energy established the Nuclear Hybrid Energy System (NHES) project to develop a systematic, rigorous, technically accurate set of methods to model, analyze, and optimize the integration of dispatchable nuclear, fossil, and electric storage with an industrial customer. Ideally, the optimized integration of these systems will provide economic and operational benefits to the overall system compared to independent operation, and it will enhance the stability and responsiveness of the grid as intermittent, nondispatchable, renewable resources provide a greater share of grid power.

This report describes development of a model for optimizing the cost of an NHES, which includes a nuclear power plant, a gas power plant, electric storage, and an industrial customer. The overall objective is to create a power system (NHES) that effectively and economically responds to variable grid demand. Variable grid demand correlates to increased use of intermittent renewable power, and it may lead to increased requirements for load following for the reactor integrated into the NHES. This would decrease cost savings and reduce the benefits of reduced emissions associated with nuclear power plants. This research addresses alternative optimization strategies for minimizing the levelized cost of electricity and other noneconomic factors while accommodating increased variance in grid electric demand.

Integrated nuclear hybrid energy systems are being investigated to leverage the emission-free energy of nuclear power without inducing a performance decrement that typically comes with reactor load following. By tightly integrating a nuclear reactor with an industrial customer, the variance in the grid's electric demand can be accommodated while maintaining the amount of nuclear power placed into service. This approach will become increasingly important as variable renewable power increases. To this end, the industrial customer in an NHES will use thermal and/or electrical energy from the reactor at times of decreased grid electrical demand.

It will be a challenge for nuclear hybrid energy systems to be cost-attractive when compared to integration only through the grid. Grid integration offers several advantages, such as independence of operation and a subsequent decoupling of feedback effects. Conversely, integrating the system can cost-optimize all of the sub-systems simultaneously while hedging against uncertainty through diversified energy sources. Cost-based optimization of an integrated nuclear hybrid energy system requires a balance of components¹ sizing (power capacity), the operational priorities, and overall availability, reliability, and utility while meeting its grid supply requirements.

A base case configuration for a nuclear hybrid energy system was created to develop and exercise the methodology for NHES analysis. This NHES includes a nuclear power plant, a natural gas power plant, a grid-scale storage battery, and an industrial customer. The overall cost of the power system includes capital, operations and maintenance, and fuel costs, but it also must account for any unmet demand costs, as well as the cost of environmental impacts such as emissions costs, if any. These costs carry uncertainty or volatility in either their point estimates or their future value, which will impact optimization of the overall system.

System optimization also depends on the electric power demand distribution in the cumulative distribution and the time series history. Optimization based on the cumulative distribution alone does not account for the effects of power ramping or clustered peaking; nor does it account for the required periodic reactor refueling outage. Thus, rational optimization must be based on explicit time series and incorporate a model of standard operations.

¹For this discussion, *component* refers to the different power plants within the NHES rather than individual systems or subsystems within each power plant.

Besides economic evaluation, system optimization must include noneconomic performance figures of merit such as permissible ramping rates, power maneuvers, and component availability and reliability. When possible, these *noneconomic* figures of merit should be converted to cost figures, but this conversion can carry high uncertainty.

Preliminary analyses show that the optimization of the system component capacities—that is, the relative sizing of the nuclear power plant, the gas power plant, and the storage battery—are highly sensitive to gas prices and unmet demand costs. Increasing either gas prices or unmet demand costs (or both) also increases the attractiveness of nuclear power. The storage battery is beneficial to the system when unmet demand prices are sufficiently high, especially when coupled with a peaking gas plant. Optimization is also highly sensitive to uncertainty and volatility in the grid demand profile, whether considered from a cumulative demand function or from a time-series demand profile.

The physics-based performance assumptions used for the initial economic analysis (such as allowed ramping rates) are insufficient to analyze and compare system physical performance. The level of physical and operational detail within the model needed to contrast, compare, and optimize the system requires high fidelity, dynamic, multiphysics models to track physical phenomena through the integrated system. Ongoing and future work will develop and use more detailed physics-based models to more precisely describe system performance, providing feedback on the development of robust optimization results and operational requirements and heuristics.

1. INTRODUCTION AND BACKGROUND

Idaho National Laboratory, Argonne National Laboratory, and Oak Ridge National Laboratory are developing multiphysics-based models to evaluate a tightly coupled Nuclear Hybrid Energy System (NHES). An initial configuration with a nuclear power plant, a gas plant, a storage battery, and an industrial customer is being developed and tested (Harrison 2016).

One intention of NHES is to facilitate higher penetration of both nuclear power and renewable power onto the grid while maintaining grid stability, reliability, and affordability. Renewable power sources are intermittent and unpredictable by nature. This is particularly true for wind power. When renewable penetration is small, the grid can handle these fluctuations. However, as the amount of volatile power increases, grid stability becomes more difficult to maintain.

One way to increase stability and accommodate the volatility is to introduce a buffer to the grid. In current practice, hydropower and peaking gas plants handle the volatility. Hydropower is low-cost and dispatchable (within some operational constraints), but it is geographically limited to areas with sufficient available reservoirs and is subject to weather effects. Gas plants operate reliably, but they produce undesirable emissions. They also trade operational volatility for fuel price volatility.

Nuclear reactors can be operated in load following operation, reducing the need for gas plants, but this induces a performance decrement to the reactor. An alternative method for using a reactor as a grid buffer is to couple a nuclear reactor's thermal output to an intermediate system, or *thermal manifold*, allowing the reactor to shift thermal power between a power conversion system and a thermal customer.

Such a system must be economically competitive in order to be attractive to utilities and industry. The following sections develop the methodology for that economic analysis as applied to the reference NHES case.

2. NUCLEAR HYBRID ENERGY SYSTEM BASE CASE

2.1 THE POWER PLANTS

The NHES configuration includes nuclear and gas-fired power plants. The nuclear power plant is a generic light water reactor (LWR) operating at 32.6% thermal efficiency² for electric power conversion (U.S. Energy Information Administration 2015) and a 90% capacity factor (U.S. Energy Information Administration 2016). It is assumed that the nuclear power plant is optimized for continuous steady-state full-power operation, but it is also capable of load following.

Two types of gas-fired power plants are described herein. The first is a *conventional combined cycle plant* operating at 48.4% thermal efficiency (U.S. Energy Information Administration 2015) and 87% capacity factor (U.S. Energy Information Administration 2016). This is typical of baseload power installations. The second type is a *conventional combustion turbine* operating at 31.6% thermal efficiency (U.S. Energy Information Administration 2015) and 30% capacity factor (U.S. Energy Information Administration 2016), typical of a peaking power installation. Thus, gas-fired power plants may operate as either baseload (combined cycle) or on as needed peakers (combustion turbine). Both power plant types are described in the individual cost analysis discussion in Section 3.2.3 and are currently used for power generation. However, the base case analysis focuses on the combustion turbine to highlight the difference between the baseload nuclear plant and the peaking gas plant. The combined cycle gas plant will have better cost performance than the combustion turbine (see Section 3.2.3), but it is intended to operate as a baseload generator with a higher capacity. Since an integrated system would not include both a baseload natural gas plant and a baseload nuclear plant, the baseload gas plant is not included in the analysis.

2.2 THE BATTERY

A grid-scale battery is also included in the NHES. This is not a power plant *per se*, but rather it is energy storage that acts as a buffer during periods when power supply cannot meet demand. Multiple grid-scale battery storage systems are currently in development (Rastler 2010), and a representative system, specifically a lithium ion system, is used in this analysis. This analysis assumes an energy storage/transmission efficiency of 90%, a typical efficiency noted for grid-scale battery storage (Rastler 2010).

The lithium ion battery described by the Electric Power Research Institute (EPRI) scales up to 100 MWe³, with a discharge time of up to 1 hour. This implies an energy storage capacity of 100 MWh (Rastler 2010).

2.3 THE INDUSTRIAL CUSTOMER

For the preliminary analysis, the industrial customer is simply treated as a thermal power sink without regard for the required inlet temperature. The industrial customer in future work will include more specific temperature and absolute power requirements. Additionally, the end industrial product is not specified or tracked. The only economic effect the industrial customer provides is in the purchase of thermal power.

²The thermal efficiency is calculated based on the heat rate as given in BTU/kWh in the source document. The energy equivalence between BTU and kWh is 1 kWh = 3,412.142 BTU; thus, a heat rate of 10,479 BTU/kWh for nuclear power yields a thermal efficiency of $3,412.142/10,479 = 0.3256 = 32.6\%$.

³Power is given in *megawatt-electric* or *megawatt-thermal* and is abbreviated *MWe* or *MWt*, denoting electrical power or thermal power, respectively. Energy is given in *megawatt-electric-hours* or *megawatt-thermal-hours* and is abbreviated *MWh* or *MWth*, denoting electrical energy or thermal energy, respectively.

2.4 THE THERMAL MANIFOLD

The analysis includes a thermal manifold to direct thermal power between the power conversion system and the industrial customer. In its simplest terms, the thermal manifold acts as a distributor for hot steam from the heat exchanger outlet and a collector for subcooled water for the heat exchanger inlet.

3. FIGURE OF MERIT DEFINITION AND ANALYSIS METHODOLOGY

3.1 THE COST-BASED FIGURE OF MERIT

3.1.1 The Rationale for the Cost-Based Figure of Merit

In this analysis, the most universally applicable figure of merit for comparing performance is the total cost of the system when meeting a given set of performance requirements. Thus, for a given set of competing NHES configurations, the most attractive (optimal) configuration is the one requiring the minimum cost to successfully meet the performance requirement.

This statement of optimization is in some measures incomplete; in general economic analyses, the most attractive option is the one which maximizes the net present value or, equivalently, provides the greatest internal rate of return for the investment. The results obtained from more widely used statements of optimization do not necessarily disagree with the results obtained from cost minimization. Rather, they require additional information, such as the market price of any industrial product generated by the NHES. For example, the market for hydrogen, a potential industrial product, is well characterized and mature. While it may seem straightforward to include market prices for the industrial product, this introduces an additional set of optimization parameters such as storage and transportation. For the purposes of analyzing and optimizing a system architecture and configuration to demonstrate system compatibility, stability, and operability, these parameters are set aside for potential inclusion in future analyses.

3.1.2 Definition of Costs

The cost for each component⁴ of the NHES is summed from four general categories, but not all components will incur costs in all categories.

- Capital costs for the construction, which is converted into a capital recovery cost, given in \$/year⁵
- Fixed operation and maintenance (O&M) costs, given in \$/year⁶.
- Variable O&M costs given in \$/marginal unit. For power plants, this is \$/megawatt-hour, either thermal or electric (usually electric). For an industrial facility, this is \$/unit of material produced. External environmental costs, given in \$/marginal units, are similar to the variable operation and maintenance costs above. These costs would include carbon taxes or other emission costs.

⁴The reactor, gas plant, and battery are considered to be individual components. The thermal manifold is assumed to be part of the reactor, and the switchyard is assumed to be covered by the combination of the reactor, gas plant, and battery.

⁵Capital recovery costs are given in \$/year because the capital cost is essentially the mortgage for the construction costs, and the year is a standard period for integrating the energy produced to account for anticipated seasonal fluctuations. This allows a direct conversion to \$/MWeh for capital cost.

⁶Fixed O&M costs use \$/year for the same reason as the capital recovery costs.

3.1.3 Cost Estimation

3.1.3.1 Capital recovery cost

The capital recovery cost is a function of multiple parameters:

- total capital cost, including interest during construction – C ,
- interest⁷ rate charged during payback – r , and
- the number of periods of payback – n .

These parameters yield the payment⁸, A , as:

$$A = Cr \frac{(1+r)^n}{(1+r)^n - 1}.$$

For power plants, the capital cost C can be considered a function of the nameplate power P of the plant, such that $C = C(P)$. Assuming the interest rate and number of payback periods is insensitive to the nameplate power, the payment becomes:

$$A = C(P)r \frac{(1+r)^n}{(1+r)^n - 1}.$$

This function can thus be separated into two parts, one corresponding to the capital cost and one corresponding to the financial parameters. For example, with a capital cost of \$5,000/kWe, an annual interest rate of 5%, and a 40-year payback period, the annual capital recovery payment is then:

$$A = \frac{\$5000}{\text{kWe}} * 0.05 \frac{(1.05)^{40}}{(1.05)^{40} - 1} = \frac{\$291.4}{\text{kWe}} = \frac{\$291.4\text{k}}{\text{MWe}}.$$

Thus, for a 1,000 MWe nuclear power plant using these parameters, the annual capital recovery payment is \$291.4M. The annual capital recovery payment for other components on a per-kilowatt or other per-unit basis can be calculated similarly. Each year the U.S. Energy Information Administration (EIA) provides cost estimates for power plants (U.S. Energy Information Administration 2015), and EPRI provides cost estimates for battery storage (Rastler 2010). Costs for nuclear and gas turbine power plants and battery storage appear in Table 1. The table also includes annual capital recovery payments using the EIA assumption of 5.6% over 30 years.

Table 1. Capital costs for power plants

Power plant type	Capital cost (\$/kWe) ⁹	Annual capital recovery (\$/kWe/y)
Advanced nuclear	5,366	373.3
Conventional combined cycle	912	63.5
Conventional combustion turbine	968	67.3
Lithium ion battery storage	1,300 ¹⁰	90.4

In typical analyses, these costs are converted into \$/MWeh by calculating the total energy produced in a year based on the capacity factor of the power plant. For example, a 1,000 MWe nuclear power plant with

⁷For this analysis, the term *interest* includes the *cost of capital*.

⁸The annual capital recovery payment is a fixed amount following construction. Dividing the fixed payment amount by the total energy produced yields a cost (or payment amount) per unit of energy.

⁹The costs from EIA given in Table 4 and other related tables are indexed to 2013\$, and the costs given by EPRI are assumed to be in 2010\$. Converting 2013\$ and 2010\$ to 2016\$ requires an increase of ~3.6% and ~10% (Bureau of Labor and Statistics n.d.), respectively, which is within the expected uncertainty in actual capital costs. Thus, the costs are not escalated from the source document.

¹⁰The reference provides a range of \$1,085–\$1,550/kWe; \$1,300 was chosen as representative.

a capacity factor of 90% will produce approximately 7.89×10^6 MWeh annually. Spreading the \$373M annual payment over this produced energy yields a capital recovery cost of \$47.28/MWeh. This spreading of costs over the energy produced yields the levelized cost; this is the typical cost communicated and compared in power generation cost analyses.

3.1.3.2 Fixed O&M costs¹¹

Fixed O&M costs are incurred by a component regardless of the operational status. That is, the components incur the costs whether power (or another unit with value) is produced or not. These costs are typically scaled to per-kilowatt or other per-unit-capacity basis for a given period of time, usually per year. The EIA provides these estimates as well (U.S. Energy Information Administration 2015). EPRI assumes a fixed percentage¹² of the capital cost due to the small or nonexistent, experience based on actual O&M costs (Nuclear Energy Institute 2016). These appear in Table 2.

Table 2. Fixed O&M costs for power plants

Power plant type	Fixed O&M cost (\$/kWe/year)
Advanced nuclear	93.23
Conventional combined cycle	13.16
Conventional combustion turbine	7.34
Lithium ion battery storage	13.00

Similar to the capital recovery costs, fixed O&M costs are typically spread over the total power produced. For the 1,000 MWe nuclear power plant example, the \$93M annual cost yields a fixed O&M cost of \$11.81/MWeh. This also assumes linear scaling (see Section 3.1.3.6).

3.1.3.3 Variable O&M costs

The variable O&M costs are costs incurred by a component only during operation. That is, the components incur the costs only when power (or another unit with value) is produced. These costs are typically given on a per-megawatt-hour or per-unit basis. EIA provides these estimates for the nuclear and gas plants, as well (U.S. Energy Information Administration 2015). EPRI does not include variable O&M costs for battery storage in units of \$/MWeh since the design and operation of battery storage is dissimilar to that of power plants. As a placeholder, this analysis assumes a battery storage variable cost similar to that of the combustion turbine since both are dispatched less frequently than the baseload plants.¹³ These variable O&M costs appear in Table 3. Note that this does not include fuel costs.

Table 3. Variable O&M costs for power plants

Power plant type	Variable O&M cost (\$/MWeh)
Advanced nuclear	2.14
Conventional combined cycle	3.60
Conventional combustion turbine	15.44
Lithium ion battery storage	15.00

¹¹Fixed O&M costs can include safety-related inspections or maintenance, emergency staffing, or other costs associated with mandatory or regulatory activities.

¹²EPRI assumes a low-end estimate of 0.5% and a high-end estimate of 2%; this analysis uses 1%.

¹³The assumption of \$15/MWeh is an arbitrary assumption, and as such represents an area of uncertainty.

For comparison, the Nuclear Energy Institute (NEI) tracks total nonfuel O&M costs for the nuclear fleet (Nuclear Energy Institute 2016). The EIA-based example of the 1,000 MWe nuclear reactor as described above, having \$11.81/MWeh of fixed costs and \$2.14/MWeh of variable costs, yields an estimate of \$13.95/MWeh of total nonfuel O&M costs. NEI provides a recorded range of ~\$19-\$27/MWeh and an overall average of \$21/MWeh, a difference of ~\$7/MWeh or ~50% of the estimate. This is a fairly significant discrepancy; however, the NEI data include actual data from the existing US nuclear fleet, which includes multiple older, smaller reactors which may skew the overall average. The EIA uses existing data as a starting point, but we presume it makes some assumptions about increased efficiencies and cost savings in operations. For the purposes of this analysis, and to be consistent with the use of EIA estimates for the gas plants, it is assumed that the EIA value of ~\$14/MWeh is valid for new construction reactors.

The costs referenced above do not include fuel, but fuel costs for both nuclear and gas turbine power plants can be estimated from additional sources. For nuclear fuel, the NEI tracks fuel costs for the US nuclear reactor fleet (Nuclear Energy Institute 2016), while for natural gas, the recent market price in \$/cubic foot¹⁴ is tracked by EIA (U.S. Energy Information Administration 2016). The lithium ion battery storage does not have fuel cost since it draws electrical power. These costs appear in Table 4. Note that there is a range of fuel costs since it is tied directly to a commodity market with various degrees of volatility.

Table 4. Fuel costs for power plants

Fuel type	Fuel cost (\$/MWeh) assuming \$2-\$4/mcf	Use \$3/mcf
Advanced nuclear	6-8	
Conventional combined cycle	13.67-27.33	Use 20.50
Conventional combustion turbine	20.90-41.79	Use 31.35

This analysis assumes a constant or long-term average value of \$3/mcf for gas. This leads to a \$31.35/MWeh fuel cost for the combustion turbine.

3.1.3.4 External environmental costs

As with the variable O&M costs, external environmental costs are assumed to only be incurred during operation, specifically during the burning of fossil fuels that leads to the release of CO₂. There is no current carbon cost in the US, but a slack variable is included as a placeholder for future reference.

Carbon emission from natural gas is on the order of 53 kg/million British thermal units (BTUs) (U.S. Energy Information Administration n.d.), and the emission per kWeh depends on the thermal efficiency of the power cycle. Table 5 shows the carbon emission for the two types of gas-fired plants considered in both g/kWeh and MT/MWeh.

Table 5. CO₂ emissions for power plants

Plant type	Emission rate (MT/MWeh)
Conventional combined cycle	0.374
Conventional combustion turbine	0.572

¹⁴One cubic foot is equivalent to 1,032 BTUs, the heat rate for a conventional combined cycle plant is 7,050 BTU/kWeh, and for a conventional combustion turbine it is 10,783 BTU/kWeh (U.S. Energy Information Administration 2015). Thus, a conventional combined cycle plant requires 6,831 ft³ per MWeh, and a conventional combustion turbine requires 10448.6 ft³ per MWeh. Since prices are typically given in dollars × 1,000 cf (mcf), this is more usefully given as 6.8 mcf/MWeh and 10.4 mcf/MWeh.

Typical values of proposed carbon costs are on the order of tens of dollars per metric ton (MT) to hundreds of dollars per MT. For simplicity and clarity, the carbon cost can also be converted to an equivalent cost increment for natural gas. Since a combustion turbine emits 0.572 MT/MWeh and requires 10.4 mcf/MWeh, it emits 0.055 MT/mcf of natural gas consumption. With an example carbon cost of \$10/MT, this implies a \$0.55/mcf increase in natural gas prices. At a carbon cost of \$100/MT, this implies a \$5.50/mcf increase in natural gas prices. Alternatively, a \$1/mcf increase in natural gas prices is equivalent to a carbon cost increase of \$18.2/MT. Thus, from a cost perspective, there is no difference between \$3/mcf natural gas with an \$18.2/MT carbon cost, and \$4/mcf natural gas with no carbon cost.

3.1.3.5 Decommissioning and decontamination (D&D), capital upgrades, and other costs

D&D, upgrades, and other costs are implicitly included in capital recovery and O&M costs. For nuclear fuel, the cost of fuel storage and disposition is implicitly included in the fuel cost.

3.1.3.6 A caveat on cost scaling

The cost estimates presented above assume constant linear scaling, especially in the capital and O&M costs. For example, one assumption is that a reactor costs \$5,366/kWe, whether it is a 500 MWe or a 1,300 MWe reactor. This is likely a valid assumption for most commercial-scale reactor construction projects and their subsequent operation. However, moving from the current 500 MWe to 1,300 MWe operational experience toward small reactors on the order of 50 MWe each may invalidate that assumed overnight construction cost. For example, a 50 MWe reactor may cost \$10,000/kWe. This is not likely to impact the preliminary analysis of the base case, but it should be noted for future analyses.

3.2 EVALUATION OF INDIVIDUAL SYSTEM COSTS

3.2.1 Derivation of Generic Cost

The total cost for each component is the summation of the category costs:

$$C_c = A_c + O_c^F + O_c^V + F_c + E_c,$$

where the subscript c represents the generic component, and

C_c is the total cost,

A_c is the capital recovery cost,

O_c^F is the fixed O&M cost,

O_c^V is the variable O&M cost,

F_c is the fuel cost, and

E_c is the environmental cost.

As given, these represent the total costs over some time period, potentially over the full lifetime of the system. To convert this total cost to a levelized cost, the equation becomes:

$$c_c = \frac{A_c + O_c^F + O_c^V + F_c + E_c}{Q_c} = \frac{A_c + O_c^F}{Q_c} + o_c^V + f_c + e_c,$$

where for each component c ,

c_c is the total levelized cost,

Q_c is the total energy produced,

o_c^V is the levelized variable O&M cost,

f_c is the levelized fuel cost, and

e_C is the levelized environmental cost.

As discussed in Section 3.1.3.1, converting the capital recovery cost and the fixed O&M cost into estimated levelized costs requires an assumed capacity factor for *a priori* estimates. For continuous-operation baseload units such as the nuclear and combined cycle plants, this assumption is accurate. For the combustion turbine and battery, this assumption can be considered accurate when placed into uncoupled or unintegrated service. However, for a tightly integrated system, the assumed capacity factors may be inaccurate and will thus require explicit calculation. This will yield an effective levelized cost.

3.2.2 Total Nuclear Power Cost

For the nuclear reactor, the total cost is the summation of the category costs and is expressed as:

$$c_N = \frac{A_N + O_N^F + F_N}{Q_N} + O_N^V.$$

This formulation differs in two ways from the form given in Section 3.2.1. First, the environmental costs are zeroed. This is based on the assumption that environmental costs are a function of carbon emission only. Second, fuel costs are not strictly considered to be levelized costs. That is, the fuel cost is not only a function of the usage. This is due to the nature of the usage of nuclear fuel. Nuclear fuel is purchased in batches of discrete fuel units which are loaded and discharged from the reactor based on total energy extracted (burnup) and schedule (periodic outages). When discharged, the fuel has no salvage value, so any deviation from the expected energy value is a sunk cost. It is possible to account for this disparity in the purchase of the next batch of fuel, but introducing a highly variable operational regime (such as load following) may prevent the implementation of an effective purchasing strategy.

Assuming a typical \$7/MWeh levelized fuel cost and a 90% capacity factor will yield a fixed fuel cost of \$55.23/kWe/year. Using this value and other values from the tables above, the nuclear power cost is then:

$$c_N = P_N \frac{\$373.30 + \$93.23 + \$55.23}{Q_N \times kWe \times year} + \frac{\$2.14}{MWeh} = P_N \frac{\$521.76}{Q_N \times kWe \times year} + \frac{\$2.14}{MWeh},$$

where

P_N is the rated power (in kWe) of the nuclear power plant.

Thus, for a 10^6 kWe nuclear power plant with a 90% capacity factor, the Q_N is 7.89×10^6 MWeh/year, yielding:

$$c_N = \frac{\$521.76}{7.89 \text{ MWeh}} + \frac{\$2.14}{\text{MWeh}} = \frac{\$68.27}{\text{MWeh}}$$

However, the capacity factor may not be a single value based on the operational regime. For example, an operational regime that includes scheduled ramping for approximate broad-scale load following, such as for weekend versus weekday loads, would induce a lower capacity factor. Moving from a capacity factor of 0.9 to 0.7 would change the levelized cost to

$$c_N = \frac{\$521.76}{6.14 \text{ MWeh}} + \frac{\$2.14}{\text{MWeh}} = \frac{\$87.11}{\text{MWeh}}.$$

Thus, the levelized cost is a very strong function of the actual capacity factor. Generally, the levelized cost can be rewritten as¹⁵

¹⁵The 8766 used in the denominator refers to hours in a sidereal year of 365.25 days. This makes the analysis insensitive to accounting for leap years.

$$c_N = \frac{\$521.76}{8.766*k_N} + \frac{\$2.14}{\text{MWeh}},$$

where

k_N is the capacity factor defined as actual energy produced divided by potential energy produced.

From this perspective, the variable O&M cost of \$2.14/MWeh is essentially the marginal cost of nuclear power at a given capacity factor. In fact, the \$2.14/MWeh is the maximum cost to produce an additional MWeh of nuclear power since increasing the overall production decreases the levelized cost.

3.2.3 Total Gas Power Cost

The total gas cost is given by:

$$c_G = \frac{A_G + O_G^F}{Q_G} + o_G^V + f_G + e_G.$$

For the combined cycle plant, the cost is then

$$c_{GC} = \frac{\$63.50 + \$13.16}{Q_{GC}} + \frac{\$3.60}{\text{MWeh}} + \frac{\$20.50}{\text{MWeh}} + e_{GC} = \frac{\$76.66}{8.766*k_{GC}} + \frac{\$24.10}{\text{MWeh}} + e_{GC}.$$

Similarly, the cost for the combustion turbine plant is

$$c_{GT} = \frac{\$67.30 + \$7.34}{Q_{GT}} + \frac{\$15.44}{\text{MWeh}} + \frac{\$31.35}{\text{MWeh}} + e_{GT} = \frac{\$74.64}{8.766*k_{GT}} + \frac{\$46.79}{\text{MWeh}} + e_{GT}.$$

These two cost equations show that the combined cycle plant is at a lower cost than the combustion turbine plant. However, these two different types of gas power plants are intended for different purposes, as described in Section 2.1. The combined cycle is a baseload plant, and the combustion turbine is a peaking plant. This analysis assumes the use of the combustion turbine since the gas plant will be used as a peak power plant.

Marginal costs for gas plants also depend on the environmental costs. Assuming no environmental costs, the marginal costs are then \$24.10/MWeh for combined cycle and \$46.78/MWeh for combustion turbine. At a \$10/MT carbon cost, the environmental costs are an additional \$3.74/MWeh for combined cycle and \$5.72/MWeh for combustion turbine. Section 3.1.3.4 discusses the inclusion of environmental costs with gas prices.

3.2.4 Total Battery Cost

The total battery cost is given by

$$c_B = \frac{A_B + O_B^F}{Q_B} + o_B^V = \frac{\$90.40 + \$13.00}{Q_B} + \frac{\$15.00}{\text{MWeh}} = \frac{\$103.40}{Q_B} + \frac{\$15.00}{\text{MWeh}}.$$

Note that the capacity factor for the battery storage is not defined since it is not strictly a power production term.

3.2.5 Unmet Demand Cost

Unmet demand cost is included to account for deficits in power provided to the grid relative to the demand. The unmet demand cost is arbitrarily set at \$130/MWeh, which is the US average retail price of

electricity delivered to residential customers¹⁶ (U.S. Energy Information Administration n.d.). This cost may be adjusted to provide a forcing function to promote the prevention of unmet demand. While the cost of unmet demand is not tied directly to production costs, this analysis considers it a cost levied against the system for not meeting the demand on the system.

4. CASE ANALYSIS

4.1 SUMMARY OF THE PROGRESSION OF ANALYTICAL METHODS AND RESULTS

This section summarizes the progression of the analytical methods and results, starting with the simplest analysis in Section 9.1, and increasing in complexity through Section 9.6.

4.2 SIMPLE ESTIMATE

Section 9.1 introduces a coupled nuclear reactor and combustion turbine gas plant. The nuclear reactor is rated at 1,000 MWe with a 90% capacity factor, and the gas plant is rated at 250 MWe with a capacity factor of 40%. This yields a system average of 1,000 MWe and a levelized cost of \$68.26/MWeh. In theory, this is sufficient to meet a 1,000 MWe average demand. However, this simplistic analysis does not account for the variation in demand that real grid response must meet. Additionally, while this approach is valid when analyzing collections of individual power plants and describing their behavior as a whole, it breaks down when analyzing a discrete integrated system of a single reactor with a single gas power plant.

4.3 APPLICATION OF THE DEMAND PROFILE

Section 9.2 introduces the concept of treating an actual demand profile as a cumulative distribution of hourly demands. Using historical data for a full year of 8,760 hours, the example 1,000 MWe-average cumulative distribution is plotted in Fig. 8. The initial system proposed to meet the demand is the same 1,000 MWe reactor and 250 MWe gas plant as in Section 9.1. The demand is met by the dispatch logic given below:

- The reactor is only used for demand less than 1,000 MWe.
- The reactor and gas are used for demand between 1,000 and 1,250 MWe.
- At demands greater than 1,250 MWe, the difference is left unmet.

The energy balance for this case is detailed in Table 8. The reactor has a resulting capacity factor of 93% (potentially unrealistic for long-term operation), and the gas plant has a capacity factor of 27%, but 110,000 MWeh of demand is left unmet. Accounting only for production cost, the total levelized cost is \$67.31/MWeh. This is less than the simplistic analysis in Section 9.1 at \$68.25/MWeh because of the higher nuclear capacity factor. However, accounting for the 110,000 MWeh of unmet demand increases the total cost to \$68.92/MWeh.

4.4 INCLUDING THE BATTERY

To decrease the unmet demand, a 100 MWe battery is introduced into the system in Section 9.3. This creates a system with a peak supply of 1,350 MWe, which is sufficient to cover 95% of the demand distribution from Fig. 8. The demand is met by the dispatch logic shown below:

- The reactor is only used for demand less than 1,000 MWe.

¹⁶This analysis uses the average retail residential price for unmet demand since it is assumed that the system will be competing with other customers during periods of unmet demand, and the retail residential price is the highest price on the grid.

- The reactor and gas are used for demand between 1,000 and 1,250 MWe.
- The reactor, gas, and battery are used for demand between 1,250 and 1,350 MWe.
- At demands greater than 1,350, the difference is left unmet.

The energy balance for this case is detailed in Table 9. The reactor capacity factor remains at 93%. The battery has a capacity factor of 17%, but the gas plant capacity factor increases to 30%. The gas plant capacity factor increases due to the need to recharge the battery. In this case, only 40,000 MWeh are left unmet. Accounting only for production costs, the levelized cost is \$68.46/MWeh. When unmet demand costs are included, the levelized cost is \$69.05/MWeh. This implies that increasing nuclear, gas, or battery capacity to prevent unmet demand increases the total cost, especially with battery capacity. This is consistent with concerns regarding overbuilding baseload on the overall grid. Conversely, unmet demand decreases to a fraction of a percent of total demand, which implies increased grid stability.

4.5 SIMPLE OPTIMIZATION OF THE INTEGRATED ELECTRICITY SYSTEM

The capacities of the reactor, gas plant, and battery are optimized in Section 9.4, wherein their respective capacity factors are set to 90%/40%/40%, as illustrated in Fig. 11. Using these values as targets, the first iteration estimates capacities of 1,030/190/100 MWe for the reactor/gas plant/battery, respectively. However, applying these capacities to the demand distribution yields a levelized cost, including unmet demand, of \$70.04/MWeh. Further, the actual capacity factors are 91%/32%/22% rather than 90%/40%/40% as planned. The energy balance for this case is detailed in Table 10.

A second optimization step attempts to account for the steep slope in the distribution curve at 900 MWe as seen in Fig. 8. The estimated capacities of 900/300/100 MWe yield capacity factors of 97%/43%/24%, respectively, and a total cost of \$66.65/MWeh. However, the capacity factor for the nuclear plant (97%) is higher than reasonable, and the unmet demand increases relative to the first optimization attempt. The energy balance for this case is detailed in Table 11.

Using numerical methods to enforce capacity factors of 90% in the reactor and 40% in the gas plant, the next optimization attempt estimates capacities of 1,050/125/100 MWe for the reactor/gas plant/battery. This yields a total cost of \$71.02/MWeh, but the unmet demand again increases relative to the second attempt. The energy balance for this case is detailed in Table 12.

Using numerical methods with bounds on the capacities and capacity factors as given in Table 14, the cost-optimal solution is 1,012/193/100 MWe, with capacity factors of 92%/35%/26% for the reactor/gas plant/battery, respectively. The levelized cost is \$69.55/MWeh, which is higher than several previous cases, but it meets the requirements of the bounded capacity factors. Optimizing—instead of minimizing—unmet demand yields an identical solution since unmet demand is already more expensive than installing additional capacity. Changing the battery size limits while still minimizing unmet demand changes the solution to 1,012/200/200 MWe and increases the cost to \$70.06/MWeh. This explicitly trades increased battery capital cost and decreased battery capacity factor for decreased unmet demand.

Returning to the cost-optimization approach while retaining the 200 MWe limit for the battery, the optimized solution is 1,012/193/102 MWe for nuclear/gas/battery.

4.6 INTRODUCTION OF THE TIME SERIES

The work in Sections 9.2 through 9.4 consider the demand profile as a cumulative distribution, such that there is a probability of having demand less than or equal to some given value. Similar to the analysis in Section 9.1, this is a valid approach for analyzing large sets of power plants operating in a large grid, where aggregate demand and aggregate supply are sufficient to describe the overall system. However,

this is invalid for analyzing the immediate demand on a single power system. Instead, the real demand profile is a time series in which the current demand moves to a subsequent demand within some range; for the example demand profile, this is $\pm\sim 10\%$.

Section 9.5 thus uses the demand profile as a time series instead of a cumulative distribution; this is more representative of an actual physical system. It also introduces the concept of noneconomic figures of merit, specifically the number of power maneuvers required to meet demand, including the number of full discharges of the battery.

Analyzing the performance of the 1,012/193/102 MWe case through the time series, the nuclear capacity factor remains 92%. However, the gas capacity factor decreases to 28% (less than the target minimum of 35%) because the battery provides relatively little total power to the grid and thus requires less charging from the gas plant. The battery fully discharges 130 times and is unavailable for 15% of the year. The unmet demand increases, and the total cost increases to $\sim \$71/\text{MWeh}$.

This performance decrement is due to the clustering of power peaks as shown in Fig. 12. For this case, the battery discharges 130 times and is unavailable for $\sim 15\%$ of the year.

Optimizing the system by minimizing cost for the time series yields a solution of 1,007/100/38 MWe, with capacity factors of 92%/35%/4% for nuclear/gas/battery, respectively, with a cost of $\$72.77/\text{MWeh}$. This solution is greater than the $\$71/\text{MWeh}$ above, but it meets the operational constraint of having at least 35% capacity factor for the gas plant. Optimizing the system by minimizing unmet demand yields a 1,007/129/200 MWe system with a cost of $\$73.46/\text{MWeh}$.

The analysis so far has assumed that the reactor can change power with no limit on magnitude, rate, or frequency of power maneuvers, but this is an unrealistic assumption. The demand time series for the 1,007 MWe reactor requires 5,316 power maneuvers over 8,760 hours. Additionally, the hourly power demand change ranges from -10% to +13%. Assuming a 10%/hour limit on the reactor and optimizing for cost, the optimal solution is a 1,007/100/28 MWe system. This is a reasonable result since the -10% change is within the -10% limit allowed for the reactor, and any change over +10% is met by gas or battery, or it is left unmet.

Imposing a 5%/hour ramp limit on the reactor changes the cost-optimized system to a 998/100/0 MWe nuclear/gas/battery system, with a cost of $\$72.65/\text{MWeh}$. However, the imposition of the ramping limit creates excess energy if demand changes more negative than -5%/hour. This excess energy—270,000 MWeh in this case—is essentially wasted since the grid demand must be exactly balanced by supply.

4.7 INTRODUCTION OF THE THERMAL POWER CUSTOMER

Section 9.6 introduces an alternate customer for thermal power from the reactor. By directly coupling the customer to the reactor output, thermal power that is not necessary for electricity production can be diverted for the customer's use. This alternate customer allows the reactor to run at steady-state without performing power maneuvers. For this analysis, this tight coupling is assumed to have no inefficiencies.

Using the thermal efficiency of 32.6%, 3 MWth can be sent to the customer in exchange for 1 MWeh that is not sent to the grid. Thus, the 27,000 MWeh of excess electrical energy is equivalent to 81,000 MWth for the industrial customer use. At a nominal cost of $\sim \$10/\text{MWth}$ for gas-produced heat, this is an annual cost savings of $\sim \$800\text{k}$.

Changing the reactor's operational profile from load following to full-power steady-state implies a 100% capacity factor. Including a 36-day refueling outage brings the capacity factor back to ~90%. The cost-optimized solution for the system shown in Fig. 14 is a 919/300/0 MWe nuclear/gas/battery system with capacity factors of 90% and 44%, and it has a cost of \$79.31/MWeh.

4.8 TRADE STUDIES

Section 9.7 examines the impact of changing gas and unmet demand prices. The base analysis assumes a gas price of \$3/mcf. Taking the 919/300/0 MWe nuclear/gas/battery system with a cost of \$79.31/MWeh and perturbing the gas price demonstrates the gas price impact on system optimization. Decreasing the gas price to \$2/mcf pushes the capacity factor for the gas plant from 44% up to the maximum constraint of 45% and yields a levelized cost of \$78.11. The increased gas capacity factor displaces some nuclear capacity, decreasing the reactor from 919 MWe to 915 MWe. Further decreasing the cost of gas to \$1/mcf does not change the power plant capacities, but it does decrease the levelized cost to \$76.91/MWeh.

Conversely, increasing the cost of gas (which may include a carbon cost) to \$5/mcf pushes the gas capacity factor to its minimum constraint of 35%, increases the reactor capacity to 987 MWe, and results in a levelized cost of \$80.91/MWeh. Further increasing the cost of gas to \$6/mcf only impacts the levelized cost, increasing it to \$81.48/MWeh.

Thus, at the given set of capital and O&M costs and operational requirements (such as capacity factors), the interval of gas prices which impact the optimization of the system is \$2/mcf to \$5/mcf. Below or above these costs, the system is bound by the operational requirements and the only impact is on the overall levelized cost.

Changing the gas price does not impact the use of an electric battery. Instead, the electric battery is impacted by the cost of unmet demand. The base analysis assumes a \$130/MWeh unmet demand cost, and the optimized system does not include a battery. However, increasing this to \$200/MWeh does not increase demand for the battery; instead, it increases the nuclear capacity to 961 MWe and decreases the gas capacity factor to 38%, yielding a levelized cost of \$84.44/MWeh. This trend holds to an unmet demand cost of \$800/MWeh; this requires 988/300/16 MWe nuclear/gas/battery, and the levelized cost is \$125.18/MWeh. The battery does not reach its maximum constraint of 200 MWe until the unmet demand reaches \$1500/MWeh; this system has a levelized cost of \$171.44/MWeh.

Thus, the battery is an attractive addition to the system only when the cost of unmet demand far exceeds the cost of production.

4.9 SOURCES AND IMPACTS OF UNCERTAINTY IN THE MODELING AND ANALYSIS

There are multiple sources of uncertainty in the cost modeling, most of them in the costs themselves. The capital costs, O&M costs, fuel costs, and unmet demand costs are subject to various degrees of uncertainty and/or volatility. However, there is a fundamental difference between uncertainty and volatility.

4.9.1 Cost uncertainty

Capital costs are subject mainly to uncertainty. This implies that the costs can be estimated, including contracting with an architect/engineering firm for the construction of the plant. In particular, nuclear power plant construction cost is highly uncertain. Actual costs for current construction, referencing the Summer and Vogtle plants, range from ~\$4,500–\$6,500/kWe. These are two very similar plants in

adjacent states, but this effectively gives a mean of \$5,500/kWe and a range of ~20%. Conversely, the capital costs of existing gas power plants, either combined cycle or combustion turbine, are less uncertain.

The impact of uncertainty is that the initial costs, specifically the capital costs, are in doubt, but once they are fixed, the uncertainty is permanently removed from that factor. For example, after the construction of the power plant, the uncertainty in the capital recovery payment has been completely eliminated, assuming fixed financing.

Additionally, the capital and O&M costs of the storage battery are highly uncertain given the current state of the technology. The actual performance of the storage battery is highly uncertain as well, which must be accounted for in a more detailed model, such as the one proposed in Section 5.

4.9.2 Cost volatility in addition to uncertainty

O&M, fuel, and unmet demand costs carry uncertainty but potentially high volatility. The O&M costs likely have low uncertainty and low volatility since they represent mature market services for well-known, well-established practices. Not only can services be procured through a mature, operating market from multiple competitors, but the anticipated change in service costs for future procurement is relatively low.

Fuel, especially natural gas, carries low point uncertainty because there is a mature and functional market for the commodity. However, the price is subject to the effects of supply shocks, demand shocks, market speculation, and regulatory intervention. Thus the recurring costs are subject to high uncertainty when attempting to optimize the system for future market impacts.

For this analysis, the gas cost was considered constant through the full time series, which is not necessarily a valid assumption. This simplification is akin to using a long-term average or assuming a contractually guaranteed price. Moving beyond a single calendar year would require accounting for multi-year variation in the gas prices.

Unmet demand costs have similar behavior. These are subject to both contractual obligations and external market influences. Thus, optimizing a system based on assumptions about the costs of unmet demand carry uncertainty throughout the lifetime of the system.

Another important source of uncertainty and volatility is the demand profile itself. The analysis and optimization examples in this work assume a demand profile that includes hourly ramps and expected seasonal, weekly, and daily fluctuations. While the demand profile is based on actual demand data, as experienced by the system, it is subject to multiple external factors. An important source of uncertainty in the profile is the impact of increasing renewables, especially those which coincide with power peaks or power valleys. The shape and time series of that demand distribution are important factors for optimizing the system, and the amount by which they vary through time will have tremendous impact on the economic performance of the system.

Finally, the cost of emissions represents an additional uncertainty and/or volatility in the optimization. The cost of emissions was not explicitly modeled, but the impacts can be inferred from the analysis of gas prices. As demonstrated in Section 9.7, as gas prices increase, nuclear power becomes more attractive relative to gas power.

4.10 ANALYTICAL SUMMARY

Meeting instantaneous electric demand requires executing power maneuvers in the reactor, gas power plant, and/or battery from one hour to the next. The solution for minimizing the system cost while meeting the instantaneous electric demand depends on the treatment of the demand profile. Using only a statistical treatment (cumulative distribution) ignores the hourly variation. Using the time series and minimizing cost by simultaneously optimizing the capacities and capacity factors of the reactor, gas power plant, and battery requires assumptions on the operational capabilities and constraints of each component. Increasing the physical fidelity of the model leads to an increase in the expected leveled cost of the system due to the hourly power maneuvers, which must accommodate swings of $\pm 10\%$. The optimal solution also depends on the costs of gas (including carbon costs) and unmet demand.

5. THE DYNAMIC MODEL

The progression of analyses performed in Section 4 demonstrates that the optimization results depend on the set of assumptions for component performance. As that set of assumptions increases in physical fidelity, the optimization space becomes limited, and the noneconomic figures of merit are more sensitive to increasing fidelity than the total system cost. For example, the cost difference among several NHES arrangements may be on the order of 1%, as demonstrated in Table 13. Valve actuation, thermal cycling, feedback propagation, and other physical phenomena are not captured using broad performance assumptions. The performance data necessary for accurate performance analysis must come from a set of detailed, dynamic, multiphysics models.

The detailed, dynamic, multiphysics modeling of an NHES is a multidomain problem requiring translation of complex physical problems such as those dealing with electrical, thermal hydraulic, and control systems. Dynamic models under development attempt to capture an appropriate level of physical detail of each system to properly inform an economic cost optimization study. The reference case study under development is the same tightly coupled system. A tightly coupled system thermally couples a nuclear reactor, balance of plant, and industrial process via an energy manifold along with electrical coupling of the balance of plant, industrial process, a secondary energy supply, an energy storage system, switch yard, and an electrical grid.

All physical model activities are performed using the open source equation-based Modelica programming language within the commercial Dymola development environment. Developing all models using Modelica allows key benefits, such as direct compatibility of independently developed models. No additional software interfaces or other manipulations are required. See (Harrison 2016) for additional discussion of the dynamic models and Modelica.

5.1 THE TIGHTLY COUPLED NHES

Fig. 1 represents the current NHES under consideration including the various connections between each of the components. Blue lines indicate fluid streams (e.g., steam/water), red lines indicate electricity, and yellow are control/sensor signals. Idaho National Laboratory is working on a model for hydrogen production through high temperature steam electrolysis, as well as the model of the gas power plant; Argonne National Laboratory is working on a battery model; and Oak Ridge National Laboratory is working on the reactor model, thermal manifold model, switchyard model, and the overall system layout and model integration. These models will be used to simulate subsystem actuation, power production, thermal cycling, and overall technical performance. Table 6 further identifies each of the modeled components.




Fig. 1. Tightly coupled hybrid energy system.

Table 6. Identification and brief description of a tightly coupled NHES

Identifier	Component	Description	Example
1	Primary heat system	Provides baseload heat and power	Nuclear reactor
2	Energy manifold	Diverts thermal energy between subsystems	Steam distribution
3	Balance of plant	Serves as primary electricity supply from energy not used in other subsystems.	Turbine and condenser
4	Industrial process	Generates high value product using heat from the energy manifold/secondary energy supply and electricity from the switch yard.	Steam electrolysis or desalination
5	Energy storage	Serves as energy buffer to increase overall system robustness.	Batteries and firebrick
6	Secondary energy supply	Delivers small amounts of topping heat required by industrial process.	Gas turbine make-up
7	Switch yard	Distributes electrical load between subsystems.	Electricity distribution
8	Electrical grid	Sets the behavior of the grid connected to the NHES	Large grid behavior (not influenced by NHES)
9	Control system center	Additional systems are required to provide proper system control, test scenarios, etc.	Control/supervisory systems and event drivers

One of the more challenging aspects of dynamic modeling is the ability to properly specify the appropriate temperatures, pressures, flow rates, etc., that will enable the models to reach a steady state condition. This steady state condition is then used as the initialization point for subsequent dynamic studies of interest from which dynamic inputs to the model can be added.

To use the dynamic system model for the economic cost evaluation it is necessary to use a steady state nominal condition at time zero and then follow the appropriate demand profile of interest. The resulting

behavior of the dynamic system can then be integrated into an economic evaluation. Although various aspects of several systems are still under development to handle load following requirements, a modified overall system was generated to demonstrate the eventual load following capability of the overall hybrid system.

The system shown in Fig. 2 was used to simulate 10 hours of dynamic turbine power operation based on a demand profile. The results are shown in Fig. 3. The steam turbine load following example highlights the important aspect of unmet demand discussed previously. The power changes are accomplished via manipulation of actuators such as the turbine control valve position. At approximately hour three the power set point is above the deliverable power. Situations such as this are tracked to inform the economic evaluation.




Fig. 2. Modified tightly coupled energy system.




Fig. 3. The normalized power set point and steam turbine output.

6. CONTINUING AND FUTURE WORK

In addition to dynamic system modeling, instrumentation and control systems and the system supervisory logic control systems are under development. These systems will define the operation for the different power sources, including the priority for meeting industry versus grid demand and the priority order (nuclear before gas, or vice versa) for power plant dispatch.

The output from the system models are used to generate the economic and noneconomic figures of merit for a given demand profile. This performance score is returned to an optimization engine to generate a new set of parameters and control logic. This analysis flow for the optimization is shown in Fig. 4.




Fig. 4. NHES model analysis and optimization (Harrison 2016).

The dynamic analysis will become operational in FY17.

7. SUMMARY

Preliminary analyses show that the optimization of the system must be performed in a discrete time series rather than as a statistical distribution. The statistical distribution approach is valid for analyses in which the average behavior of a large set of power plants is sufficient to describe the overall system performance. NHES analysis requires tracking the performance of single power plants meeting definite demands.

Further, component capacities—that is, the relative sizing of the nuclear power plant, the gas power plant, and the storage battery—are highly sensitive to gas prices and unmet demand costs. Increasing either gas prices or unmet demand costs (or both) also increases the attractiveness of nuclear power. The storage battery is beneficial to the system when unmet demand prices are sufficiently high, especially when coupled with a peaking gas plant, but is otherwise unnecessary in this system architecture.

The work on nuclear hybrid energy systems shows that the nuclear hybrid systems have potential attractive application, especially in gas price regimes higher than current prices, but lower than historic highs. Development of dynamic multiphysics models to capture important system behavior while attempting to meet specific demand profiles is well under way. These models will provide a more realistic simulation of a power system and will inform the portions of the cost evaluations that economics alone cannot. Future work will integrate the behavior of the dynamic models into a cost optimization methodology and examine the impact of market forces on the industrial customer’s outputs.

8. WORKS CITED

- Bureau of Labor and Statistics. *CPI Inflation Calculator*. n.d.
http://www.bls.gov/data/inflation_calculator.htm (accessed November 2, 2016).
- Harrison, T. Jay. "Nuclear Hybrid Energy System FY16 Modeling Efforts at ORNL." Oak Ridge National Laboratory, 2016.
- Nuclear Energy Agency. "Technical and Economic Aspects of Load Following with Nuclear Power Plants." 2011.
- Nuclear Energy Institute. "Nuclear Costs In Context." 2016.
- . *US Nuclear Capacity Factors*. n.d. <http://www.nei.org/Knowledge-Center/Nuclear-Statistics/US-Nuclear-Power-Plants/US-Nuclear-Capacity-Factors> (accessed November 7, 2016).
- . *US Nuclear Refueling Outage Days*. n.d. <http://www.nei.org/Knowledge-Center/Nuclear-Statistics/US-Nuclear-Power-Plants/US-Nuclear-Refueling-Outage-Days> (accessed November 10, 2016).
- PJM. *PJM - Estimated Hourly Load*. n.d. <http://www.pjm.com/markets-and-operations/energy/real-time/loadhryr.aspx> (accessed November 4, 2016).
- Rastler, D. "Electricity Energy Storage Technology Options." 2010.
- U.S. Energy Information Administration. "Assumptions to the Annual Energy Outlook 2015." 2015.
- . *EIA-Electricity Data*. n.d. https://www.eia.gov/electricity/monthly/epm_table_grapher.cfm?t=epmt_5_6_a (accessed November 3, 2016).
- . *Electric Energy Dispatch*. n.d. <http://www.eia.gov/todayinenergy/detail.php?id=7590#> (accessed November 8, 2016).
- . *Environment*. n.d. https://www.eia.gov/environment/emissions/co2_vol_mass.cfm (accessed November 2, 2016).
- U.S. Energy Information Administration. "Levelized Cost and Levelized Avoided Cost of New Generation Resources in the Annual Energy Outlook 2016." 2016.
- U.S. Energy Information Administration. "Natural Gas Monthly." 2016.

9. APPENDIX

9.1 SIMPLE ADDITIVE COST ESTIMATE

The EIA analysis assumes a typical or nominal capacity factor as described in Section 2.1. This capacity factor determines the levelized cost as described in Section 3.2. However, the EIA analysis assumes that a large number of independent, identical units all arrive at an average value of that capacity factor while operating to meet an aggregate grid demand. The architecture of the nuclear hybrid energy system has a single unit of each type operating to meet a specific grid demand at a single point. Thus, the actual capacity factor for a unit in the nuclear hybrid energy system will not necessarily reflect that expectation of the fleet average.

The levelized costs as a function of capacity factor for nuclear and gas plants, with no emissions cost, are shown in Fig. 5.




Fig. 5. Levelized cost of nuclear and gas as a function of capacity factor (emissions cost = \$0/MT).

The orange line in the figure shows that the levelized cost of nuclear operating at a 90% capacity factor (~\$68/MWh) is approximately equal to a gas turbine plant (green line) operating at 40% capacity factor, or to a combined cycle plant (red line) operating at 20% capacity factor. Assuming that fuel prices, especially gas prices, remain constant, this implies that for a system composed of a nuclear reactor and a gas turbine plant, an operating regime that results in a 90% capacity factor for the nuclear power plant and a 40% capacity factor for the gas turbine would have a total levelized cost of ~\$68/MWh.

The 90% capacity factor is assumed to be a long-term maximum for the nuclear reactor based on fleet history. Individual reactors can exceed 90% for a given year or for multiple consecutive years, but the overall capacity factor tends to remain near 90% (Nuclear Energy Institute n.d.).

As a specific example, a given system includes a 1,000 MWe (1×10^6 kWe) LWR and a 250 MWe (0.25×10^6 kWe) gas turbine plant. This system has an average of 900 MWe nuclear and 100 MWe gas for a total of 1,000 MWe.

At a 90% capacity factor, the nuclear energy production is 7.889×10^6 MWeh/year, and the total annual cost is

$$C_N = \$521.76 \times 1 \times 10^6 + \$2.14 * 7.889 \times 10^6 = \$538.64 \times 10^6.$$

In this equation, 1×10^6 is the power in kWe. This translates to a nuclear levelized cost of $\$538.64/7.889$ MWeh = $\$68.28/\text{MWeh}$.

At a 40% capacity factor, the gas power production is 0.876×10^6 MWeh/year, and the total annual cost is:

$$C_{GT} = \$74.64 \times 0.25 \times 10^6 + \$46.79 \times 0.876 \times 10^6 = \$59.65 \times 10^6$$

In this equation, 0.25×10^6 is the power in kWe. This yields a gas levelized cost of $\$59.65/0.876$ MWeh = $\$68.09/\text{MWeh}$.

The total energy production for this 1,000 MWe average system is 8.765×10^6 MWeh, and the total cost is $\$598.29\text{M}$; the levelized system cost is thus $\$68.26/\text{MWeh}$, which is approximately equal to the nuclear cost of $\$68.28/\text{MWeh}$.

9.2 EVALUATION OF TOTAL SYSTEM COST—REACTOR AND GAS TURBINE SYSTEM

The notional image of the integration of a nuclear reactor and a gas turbine with a common connection to the grid appears in Fig. 6.




Fig. 6. Reactor and gas turbine with common connection to the grid.

The figure above shows that the total power generated by the reactor and the gas turbine must sum to meet the grid demand.

In the first example from Section 9.1, the average supply was ~ 1000 MWe, but the total capacity built was 1,250 MWe, leading to a 250 MWe surplus. This implies a system capacity factor of $\sim 80\%$. This also implies a maximum power production capacity of 1,250 MWe when not coupled to a battery storage

system, which in turn implies a ratio of the maximum available power to the average power of $1250/1000 = 1.25$.

The actual ratio of maximum demand to average demand for the existing power grid shows some regional variation. PJM, a regional transmission organization named for the Pennsylvania-New Jersey-Maryland interconnection, serves 61 million customers in multiple states in the Eastern Interconnection. PJM provides hourly demand data in MWeh per hour (effectively MWe)¹⁷ from 2015 for 10 regions (PJM n.d.); the data are shown in Table 7.

Table 7. Power peaking by region

Region	Demand (MWe)			Max/mean	Mean/min
	Max	Mean	Min		
PJM Mid-Atlantic Region	55,129	31,709	19,450	1.74	1.63
Allegheny Power	9,594	5,621	3,526	1.71	1.59
Commonwealth Edison Company	20,162	11,179	7,376	1.80	1.52
Dayton Power & Light Company	3,269	1,990	1,186	1.64	1.68
American Electric Power	24,739	14,869	9,662	1.66	1.54
Duquesne Light Company	2,804	1,634	1,014	1.72	1.61
Dominion Virginia Power	21,651	11,150	6,694	1.94	1.67
American Transmission Systems, Inc.	12,356	7,764	4,915	1.59	1.58
Duke Energy Ohio & Kentucky	5,123	3,105	1,896	1.65	1.64
East Kentucky Power Cooperative	3,490	1,423	752	2.45	1.89
Total hourly sum ¹⁸	143,698	90,443	57,111	1.59	1.58
Overall maximum				2.45	1.89
Overall Minimum				1.59	1.52

The table shows that the maximum regional max/mean ratio and mean/min ratio occurred in the East Kentucky Power Cooperative at 2.45 and 1.89, respectively. Using this range for the example system of 1,000 MWe, the 1,000 MWe mean demand would correspond to a ~2,450 MWe maximum demand and a ~529 MWe minimum demand. This would exceed the aggregate supply by 1,200 MWe at the maximum demand and leave 721 MWe idle at the minimum demand.

The minimum regional max/mean ratio occurred in American Transmission Systems, Inc., at 1.59, while the minimum regional mean/min ratio occurred in Commonwealth Edison Company at 1.52. Applying these values to the example system, the maximum demand is ~1,590 MWe—a 340 MWe deficit—and the minimum demand is ~658 MWe—a 592 MWe surplus.

Using the full system hourly aggregate demand, or *total hourly sum* as the basis for the peaking range, the max/mean is 1.59, and the mean/min is 1.58. This again implies a 340 MWe deficit, as well as a 618 MWe surplus.

However, the max/mean and mean/min values do not convey a complete set of information. The demand is a quasi-stochastic variable, meaning that its approximate value can be estimated *a priori*, but the actual value is a function of multiple external stochastic variables such as weather events. Therefore, the demand is more appropriately analyzed through statistical methods.

One method is the use of a cumulative distribution plot. Fig. 7 shows the cumulative density of the ratio of demand to the mean for the total hourly sum from the PJM data.

¹⁷The demand is provided in one-hour segments, with integrated demand in MWeh. Thus, this is effectively the average power demand in MWe.

¹⁸This is the total hourly demand across all regions.




Fig. 7. Cumulative density demand/mean demand.

The figure shows that the median value (50%) occurs at ~0.97, while the mean (1.00) has a cumulative density value of 55%.

Fig. 8 converts this into a demand density using the 1,000 MWe average demand example from above.




Fig. 8. Cumulative density din MWe.

Fig. 8 shows that the system has a median demand of ~970 MWe. Examining the cumulative density gives a power range of ~1000 MWe at the 56% cumulative density and ~1250 MWe at the 88%

cumulative density. This implies that the 1,000 MWe reactor and 250 MWe gas turbine can cover 88% of expected demand and that the 1,000 MWe reactor alone can cover 56% of the expected demand.

The presumption that the 1,000 MWe reactor would cover the demand up to 1,000 MWe and continue to operate leads to the construction of a dispatch curve. Fig. 9 shows an example dispatch curve.




Fig. 9. Example dispatch curve (U.S. Energy Information Administration n.d.).

In this case, as in most general electricity market cases, the two power plants are dispatched in a preferential order based on the marginal cost of production. For the nuclear power plant, the marginal cost is \$2.14/MWeh, and for the gas turbine, it is \$46.79/MWeh. Therefore, the nuclear power plant would be called upon first.

Converting the demand distribution of data in Fig. 8 into MWeh yields the following:

- $\sim 8.80 \times 10^6$ MWeh total over 8,760 hours¹⁹
- $\sim 4.27 \times 10^6$ MWeh at less than 1000 MWe over 4,918 hours²⁰
- $\sim 3.15 \times 10^6$ MWeh between 1000 MWe and 1250 MWe over 2,823 hours
- $\sim 1.38 \times 10^6$ MWeh at greater than 1250 MWe over 1,019 hours

Assuming the reactor provides its full power for all demands over 1,000 MWe, this yields 3,842 hours of operation, giving a capacity factor of 0.44 with 3.84×10^6 MWeh. This is split with 2.823×10^6 MWeh between 1,000 MWe and 1,250 MWe, and 1.019×10^6 MWeh over 1,250 MWe. Allowing the reactor to act as a load follower and provide power for the demands at less than 1,000 MWe, with a minimum demand of ~ 630 MWe, adds 4.27×10^6 MWeh to yield a total of 8.11×10^6 MWeh. The 8.11×10^6 MWeh produced over the year of operation corresponds to a nuclear capacity factor to 0.93. This capacity factor is approximately equal to the goal of 0.90 as described in Section 9.1.

¹⁹This yields an average demand of 1,004 MWe; this is a result of the binning and rounding of the distribution. Additionally, the 8,760 hours differs from the 8,766 above because it is a set of data from a non-leap-year.

²⁰1,000 MWe is at the $\sim 55\%$ cumulative density point in Fig. 8, meaning $\sim 4,800$ hours have demand less than or equal to 1,000 MWe. The 4,918 value is taken from the underlying data.

The gas turbine provides 250 MWe for all hours with demand greater than 1250 MWe, yielding 0.254×10^6 MWeh; it also provides 0.327×10^6 MWeh between 1000 MWe and 1250 MWe. This total production of 0.581×10^6 MWeh gives a capacity factor of 0.27. This is less than the goal capacity factor to match the cost of nuclear power.

These values are broken out in more detail in Table 8.

Table 8. Power production in a nuclear/gas system

	Demand	Nuclear	Gas turbine	Total	Deficit
Energy @ <1000 MWe (10^6 MWeh)	4.27	4.27	0	4.27	0
Energy @ 1000–1250 MWe (10^6 MWeh)	3.15	2.823	0.327	3.15	0
Energy @ >1250 MWe (10^6 MWeh)	1.38	1.019	0.254	1.27	0.11
Total energy (10^6 MWeh)	8.80	8.11	0.581	8.70	0.11
Capacity factor		0.926	0.265		

The total costs for this system are as follows:

- $C_N = \$521.76 \times 10^6 + \$2.14 \times 8.11 \times 10^6 = \539.11×10^6
- $C_{GT} = \$74.64 \times 0.25 \times 10^6 + \$46.79 \times 0.581 \times 10^6 = \45.84×10^6
- Total cost of $\$584.95 \times 10^6$ and total energy production of 8.691×10^6 MWeh

This gives levelized costs of $\$539.11/8.11$ MWeh = $\$66.47/\text{MWeh}$ for the nuclear and $\$45.84/0.581$ MWeh = $\$78.90/\text{MWeh}$ for the gas turbine. The total average is $\$584.95/8.691$ MWeh = $\$67.31/\text{MWeh}$.

However, this yields a deficit of $\sim 110,000$ MWeh (0.11×10^6 MWeh) for demands greater than 1,250 MWe. Assuming the cost of $\$130/\text{MWeh}$ for unmet demand, this increases the system cost by $\sim \$14\text{M}$, which in turn increases the total system cost to $\$68.92/\text{MWeh}$ produced. The system can thus benefit from dispatchable battery storage to meet peaking demand at greater than 1,250 MWe.

9.3 EVALUATION OF TOTAL SYSTEM COST: REACTOR, GAS TURBINE, AND BATTERY SYSTEM

The power deficit for these hours of demand reaches a maximum of ~ 340 MWe, but it averages ~ 75 MWe. Adding a battery, as shown in Fig. 10, can help in both increasing the capacity factor of the gas turbine and decreasing the total unmet demand. The battery will charge from the gas turbine at demands less than 1,250 MWe and discharge at demands greater than 1,250 MWe.




Fig. 10. Reactor, gas turbine, and battery with common connection to the grid.

The battery is rated at 100 MWe with a 90% efficiency, so for example, it requires one hour of charging at 100 MWe to provide 90 MWeh of energy. The maximum annual energy the battery can provide through discharge is 0.394×10^6 MWeh, requiring 0.438×10^6 MWeh to charge since it charges and discharges at the same power.

Adding the 100 MWe battery to the 1,000 MWe reactor and the 250 MWe gas turbine increases the maximum available power to 1,350 MWe. Referring to Fig. 8, this is now sufficient to meet 95% of the total demand.

This changes the energy production balance provided to the grid to:

- $\sim 8.80 \times 10^6$ MWeh total over 8,760 hours
- $\sim 4.27 \times 10^6$ MWeh at less than 1,000 MWe over 4,918 hours
- $\sim 3.15 \times 10^6$ MWeh between 1,000 MWe and 1,250 MWe over 2,823 hours
- $\sim 0.76 \times 10^6$ MWeh between 1,250 MWe and 1,350 MWe over 582 hours
- $\sim 0.63 \times 10^6$ MWeh at greater than 1,350 MWe over 437 hours

The battery produces 0.029×10^6 MWeh in the demand regime between 1250 MWe and 1350 MWe, an average of 50 MWe. It also produces 100 MWe over the 437 hours of operation at demand greater than 1,350 MWe for an additional 0.044×10^6 MWeh. Thus, the battery produces a total of 0.073×10^6 MWeh over 1,019 hours, an average of ~ 72 MWe when in operation. This gives it an effective capacity factor of 0.19. This 0.073×10^6 MWeh requires 0.081×10^6 MWeh of additional gas turbine power produced during operation at less than 1,250 MWe demand. The new balance appears in Table 9.

Table 9. Power production in a nuclear/gas/battery system

Power range and energy produced	Demand	Nuclear	Gas turbine	Battery	Total	Deficit
<1000 MWe (10 ⁶ MWeh)	4.27	4.27	0	0	4.27	0
1000–1250 MWe (10 ⁶ MWeh)	3.15	2.823	0.327	0	3.15	0
1250–1350 MWe (10 ⁶ MWeh)	0.76	0.582	0.146	0.032	0.76	0
>1350 MWe (10 ⁶ MWeh)	0.63	0.437	0.109	0.044	0.59	0.04
Energy for storage			0.084			
Total energy (10 ⁶ MWeh)	8.80	8.11	0.666	0.076	8.77	0.03
Capacity factor		0.926	0.304	0.173		

The nuclear power produced remains the same at 8.11×10^6 MWeh. The gas turbine power increases to 0.663×10^6 MWeh, a capacity factor of 0.30; however, the power to the grid from the gas turbine remains 0.581×10^6 MWeh. The battery sends 0.073×10^6 MWeh to the grid, for a system total of 8.764×10^6 MWeh against a demand of 8.8×10^6 MWeh; this leaves $\sim 40,000^{21}$ MWeh as unmet demand.

Given the values above, the mean power supplied to the grid is 926 MWe from nuclear, 66 MWe from gas, and 9 MWe from the battery, for a total of 1,001 MWe. The mean power produced is 926 MWe from nuclear and 76 MWe from gas, for a total of 1,002 MWe, with that minor difference coming from the 90% conversion efficiency in the battery.

The total costs for this system are:

- $C_N = \$521.76 \times 10^6 + \$2.14 \times 8.11 \times 10^6 = \539.11×10^6
- $C_{GT} = \$74.64 \times 0.25 \times 10^6 + \$46.79 \times 0.666 \times 10^6 = \49.82×10^6
- $C_B = \$103.4 \times 0.10 \times 10^6 + \$15.00 \times 0.076 \times 10^6 = \11.48×10^6

This gives levelized costs of \$66.47/MWeh for nuclear (as earlier), and \$93.16/MWeh for the gas/battery combination. The system cost is \$68.46/MWeh, which reflects the fact that nuclear provides 92.5% of the total energy. Including the unmet demand cost of \$130/MWeh over 40,000 MWeh, the system cost is \$69.05/MWeh; this is calculated as \$600.41M for the energy provided, \$5.2M for the unmet demand, and 8.77×10^6 MWeh provided. The cost of \$69.05/MWeh is marginally higher than the battery-free system cost of \$68.92. However, an advantage of including the battery in the system is that it decreases the exposure to volatility in the unmet demand costs.

9.4 OPTIMIZATION OF THE REACTOR, GAS, AND BATTERY SYSTEM

The *a priori* example sizing is not likely an optimal arrangement of the overall system. For this analysis, the optimization of the system is the minimization of the levelized cost, which can be achieved through the maximization of the capacity factor of the constituent components based on an ordered dispatching of sources. Fig. 11 shows the levelized costs as functions of capacity factors, including battery storage.

²¹ Values are rounded in the tables.




Fig. 11. Levelized cost of nuclear and gas as a function of capacity factor (emissions cost = \$0/MT).

The figure shows that the levelized cost for nuclear at the 0.9 capacity factor corresponds to the costs for the capacity factors of ~0.4 for both gas turbine and battery. Thus, assuming a maximum 0.9 capacity factor for nuclear, the maximization goal from the capacity factor perspective is 0.4 for both gas and battery.

The current nuclear capacity factor is higher than expected for a nuclear system; decreasing the capacity factor means increasing its power output. For the current capacity factor of 0.926 and 926 MWe average output, the new size to achieve a 0.9 capacity factor is 1,030 MWe.

Increasing the capacity factor while producing the same total power requires decreasing the size of the plant. The current capacity factor of 0.303 and average output of 76 MWe for the gas turbine implies a new size of 190 MWe rather than 250 MWe.

Using these two new power plant sizes with the existing 100 MWe battery in the power demand distribution gives a maximum power of 1,320 MWe rather than 1,350 MWe. The average expected power is 1,021 MWe ($0.9 \times 1030 + 0.4 \times 190 + 0.4 \times 90 \times 0.5^{22}$).

This changes the energy production balance provided to the grid to:

- $\sim 8.80 \times 10^6$ MWeh total over 8,760 hours
- $\sim 4.77 \times 10^6$ MWeh at less than 1,030 MWe over 5,405 hours
- $\sim 2.22 \times 10^6$ MWeh between 1,030 MWe and 1,220 MWe over 1,988 hours
- $\sim 0.99 \times 10^6$ MWeh between 1,220 MWe and 1,320 MWe over 780 hours
- $\sim 0.83 \times 10^6$ MWeh at greater than 1,320 MWe over 587 hours

²²The battery must charge at 100 MWe for one hour to provide one hour at 90 MWe. Conversely, it must charge at one hour at 100 MWe to provide 54 minutes at 100 MWe. This reflects that inefficiency, and then it is halved to account for the fact that the battery must spend equal time charging and discharging.

Table 10 shows the first attempt to optimize the system based on the assumption of equalizing capacity factors.

Table 10. Power production in a nuclear/gas/battery system—Optimization Step 1

Power range and energy produced	Demand	Nuclear	Gas turbine	Battery	Total	Deficit
<1,030 MWe (10 ⁶ MWeh)	4.77	4.77	0	0	4.77	0
1,030–1,220 MWe (10 ⁶ MWeh)	2.22	2.048	0.172	0	2.22	0
1,220–1,320 MWe (10 ⁶ MWeh)	0.99	0.803	0.148	0.039	0.99	0
>1,320 MWe (10 ⁶ MWeh)	0.83	0.605	0.112	0.059	0.776	0.054
Energy for storage			0.108			
Total energy (10 ⁶ MWeh)	8.80	8.226	0.540	0.098	8.756	0.054
Capacity factor		0.912	0.324	0.224		

The total costs for this system are:

- $C_N = \$521.76 \times 1.03 \times 10^6 + \$2.14 \times 8.226 \times 10^6 = \555.02×10^6
- $C_{GT} = \$74.64 \times 0.19 \times 10^6 + \$46.79 \times 0.540 \times 10^6 = \39.45×10^6
- $C_B = \$103.4 \times 0.10 \times 10^6 + \$15.00 \times 0.098 \times 10^6 = \11.81×10^6
- $C_U = \$130 \times 54000 = \7.02×10^6

Thus, the levelized cost is \$70.04/MWeh, including the unmet demand costs; this is approximately 1.4% greater than the original base case sizing. However, the point of optimization is to decrease the cost, and this has increased the cost. This is due in part to the increase in the nuclear levelized power, from \$66.47/MWeh to \$67.47/MWeh, a 1.5% increase. This comes from both a decrease in the capacity factor and an increase in the total capital cost.

The gas/battery power cost increased 3.8% from \$93.16/MWeh to \$96.72/MWeh. Further, the unmet power increased 35% from 40,000 MWeh to 54,000 MWeh. Ignoring the unmet demand costs shows that the system costs increased from \$68.46/MWeh to \$69.24/MWeh, a 1.1% increase.

Additionally, the average power provided actually decreased to 939 MWe nuclear, 49 MWe gas, and 11 battery for a total of 999 MWe. The increase in nuclear power was more than offset by decreases in gas and battery power, demonstrating that the nuclear reactor displaced the other power sources.

Thus, a second attempt at optimization must account for these effects. One of the strongest effects is the steep ascent in the cumulative demand curve at ~900 MWe illustrated in Fig. 8. This steep ascent indicates frequent operation, which translates directly into an increased capacity factor for power plants operating in that regime.

For this attempt at optimization, the nuclear reactor capacity is set at 900 MWe, and the gas turbine capacity is increased to 300 MWe. The battery remains at 100 MWe. The *a priori* capacity factor expectation is set at 0.9 for nuclear and 0.4 for both gas and battery, for an average power of 948 MWe. The maximum power is 1,300 MWe.

This changes the energy production balance provided to the grid to:

- $\sim 8.80 \times 10^6$ MWeh total over 8,760 hours
- $\sim 2.15 \times 10^6$ MWeh at less than 900 MWe over 2,686 hours
- $\sim 4.62 \times 10^6$ MWeh between 900 MWe and 1,200 MWe over 4,527 hours
- $\sim 1.06 \times 10^6$ MWeh between 1,200 MWe and 1,300 MWe over 854 hours
- $\sim 0.97 \times 10^6$ MWeh at greater than 1,300 MWe over 693 hours

Table 11 shows the second attempt to optimize the system based on the assumption of maximizing gas exposure to steep cumulative effects.

Table 11. Power production in a nuclear/gas/battery system—Optimization Step 2

Power range and energy produced	Demand	Nuclear	Gas turbine	Battery	Total	Deficit
<900 MWe (10 ⁶ MWeh)	2.15	2.15	0	0	2.15	0
900-1200 MWe (10 ⁶ MWeh)	4.62	4.074	0.546	0	4.62	0
1200-1300 MWe (10 ⁶ MWeh)	1.06	0.769	0.256	0.035	1.06	0
>1300 MWe (10 ⁶ MWeh)	0.97	0.624	0.208	0.069	0.90	0.069
Energy for storage			0.116			
Total energy (10 ⁶ MWeh)	8.80	7.617	1.126	0.104	8.73	0.069
Capacity factor		0.966	0.429	0.237		

The total costs for this system are:

- $C_N = \$521.76 \times 0.9 \times 10^6 + \$2.14 \times 7.617 \times 10^6 = \485.88×10^6
- $C_{GT} = \$74.64 \times 0.3 \times 10^6 + \$46.79 \times 1.126 \times 10^6 = \75.08×10^6
- $C_B = \$103.4 \times 0.10 \times 10^6 + \$15.00 \times 0.104 \times 10^6 = \11.9×10^6
- $C_U = \$130 \times 69000 = \8.97×10^6

The total system cost, including unmet demand, is \$66.65/MWeh, a 5% decrease in total cost relative to Step 1. However, the unmet demand increased by 28% over Step 1 to 0.8% of total demand, further increasing the total exposure to uncertainty in that cost. Additionally, while emissions costs have been excluded thus far, the gas turbine power generation increased by 109% from Step 1. This exposes the system to uncertainty in both fuel costs and emissions costs. For this case, the average power provided is 996 MWe: 869 MWe nuclear, 115 MWe gas, and 12 MWe battery. As in the previous cases, the actual production is 869 MWe nuclear and 128 MWe gas.

The capacity factor of 0.966 for the nuclear power plant is much higher than reasonable because it is not sustainable over multiple years of operation. Thus, the next step in the optimization is to develop a better rule set to decrease the nuclear capacity factor while decreasing the exposure to uncertainty in both the unmet demand and the gas and emissions costs.

A more exact method for reaching the target capacity factor is to determine the power level at which the nuclear power plant would operate with a 90% capacity factor and then the power levels at which the gas plant and battery would operate at an integrated 40% capacity factor.

Using numerical optimization methods within Microsoft Excel, the solution yields a nuclear reactor at 1,050 MWe, a gas power plant at 125 MWe, and the battery at 100 MWe²³.

Table 12 shows the third attempt to optimize the system based on the assumption of maximizing gas exposure to steep cumulative effects.

²³The EPRI report gives 100 MWe as the maximum available capacity (Rastler 2010). This limit will be relaxed in Section 9.4.

Table 12. Power production in a nuclear/gas/battery system—Optimization Step 3

Power range and energy produced	Demand	Nuclear	Gas Turbine	Battery	Total	Deficit
<1,050 MWe (10 ⁶ MWeh)	5.04	5.04	0	0	5.04	0
1,050–1,175 MWe (10 ⁶ MWeh)	1.51	1.43	0.08	0	1.51	0
1,175–1,275 MWe (10 ⁶ MWeh)	1.04	0.89	0.11	0.04	1.04	0
>1,275 MWe (10 ⁶ MWeh)	1.21	0.93	0.11	0.09	1.13	0.08
Energy for storage			0.14			
Total Energy (10 ⁶ MWeh)	8.80	8.29	0.44	0.13	8.72	0.08
Capacity Factor		0.901	0.405	0.329		

The total costs for this system are:

- $C_N = \$565.58 \times 10^6$
- $C_{GT} = \$30.09 \times 10^6$
- $C_B = \$12.29 \times 10^6$
- $C_U = \$11.16 \times 10^6$

The total system cost, including unmet demand, is \$71.02/MWeh. The nuclear cost is \$68.24/MWeh, which is the expected result at a capacity factor of 90%. The gas cost is \$67.81/MWeh, which is the expected result at a capacity factor of ~40%. The integrated gas and battery cost is \$98.56/MWeh.

The unmet demand again increased, this time to 86,000 MWeh. This again increases the overall cost. Table 13 gives a summary of the case analyses thus far.

Table 13. Summary of case analyses

Source	Parameter	Base 1	Base 2	Opt 1	Opt 2	Opt 3
Nuclear	Power (MWe)	1,000	1,000	1,030	900	1,050
	CF	0.926	0.926	0.911	0.966	0.901
	Energy Provided (10 ⁶ MWeh)	8.11	8.11	8.222	7.614	8.287
	Cost (\$M)	539	539	555	486	566
	Cost (\$/MWeh)	66	66	68	64	68
Gas	Power (MWe)	250	250	190	300	125
	CF	0.265	0.302	0.323	0.431	0.405
	Energy Provided (10 ⁶ MWeh)	0.58	0.58	0.434	1.013	0.300
	Energy Produced (10 ⁶ MWeh)	0	0.66	0.538	1.134	0.444
	Cost (\$M)	46	75	73	67	30
Battery	Power (MWe)	0	100	100	100	100
	CF	--	0.185	0.236	0.276	0.329
	Energy Provided (10 ⁶ MWeh)	0	0.073	0.093	0.109	0.086
	Cost (\$M)	0	11	12	12	12
Unmet	Energy (10 ⁶ MWeh)	0.110	0.037	0.053	0.066	0.086
	Cost (\$M)	14	5	7	9	11
Total	Energy Provided (10 ⁶ MWeh)	8.692	8.765	8.749	8.736	8.717
	Cost (\$M)	599	605	613	582	619
	Cost (\$/MWeh)	69	69	70	67	71

The cost-optimal solution for the PJM total hourly sum distribution can be found using a bounded numerical search. The constraints placed on the optimization and the optimized results are presented in Table 14.

Table 14. Cost-optimized parameters

Parameter	Minimum	Maximum	Optimal
Nuclear capacity (MWe)	500	1,100	1,012
Gas capacity (MWe)	100	300	193
Battery capacity (MWe)	0	100	100
Nuclear capacity Factor	0.88	0.92	0.92
Gas capacity factor	0.35	0.45	0.35
Battery capacity factor	0	0.45	0.26

Using these values leads to 62,000 MWeh of unmet demand and a total cost of \$69.55/MWeh.

An alternative approach to optimization requires the sizing of the power plants to avoid any unmet demand. While the unmet demand figure of merit can be converted directly to an economic figure of merit by applying a cost, as done thus far in the analysis, this cost can carry much greater uncertainty than the other economic figures. However, the maximum power available using the constraints given in Table 14 is 1,500 MWe; the maximum demand as shown in Fig. 8 is nearly 1,600 MWe.

Seeking the unmet-demand-optimized solution using the same constraints yields an identical solution since the cost of unmet demand is already set much higher than the cost of any other power source. Two of the optimized parameters that are at the limit of their constraints are the nuclear and gas capacity factors. Doubling the allowed battery capacity to 200 MWe changes the optimal solution to 1,012/210/200 MWe and capacity factors 0.92/0.35/0.16 for nuclear/gas/battery. This decreases the unmet demand to 14,000 MWeh but increases the total cost to \$70.06/MWeh. This implies that increasing the battery capacity to meet the highest peak demand requires decreasing its overall capacity factor, which offsets any cost differential from decreased unmet demand.

Reverting to a cost-optimized solution using that same revised 200 MWe limit actually approaches the original solution at 1,012/193/102 MWe for nuclear/gas/battery. This indicates that building additional battery capacity is economically unattractive compared to paying the assumed cost penalty for unmet demand.

9.5 NONECONOMIC FIGURES OF MERIT

The cost-optimized parameters given in Section 9.4 rely on the analysis of a cumulative density function for an example set of demands. Analysis of unmet demand demonstrates the utility in the conversion of noneconomic factors (such as the amount of unmet demand, an energy-based figure of merit) to an economic value. However, noneconomic figures of merit cannot always be directly converted for case comparison. The most immediate noneconomic figure of merit is tied to power maneuvers.

The analysis thus far has used a cumulative distribution with no time-based element. Using the actual hour-by-hour demand profile yields additional insight, specifically with respect to power maneuvers. Additionally, the hourly demand profile yields insight into the frequency of the full discharge of the storage battery; this induces wear and fatigue on the battery itself while increasing the actual amount of unmet demand.

The actual power demand and generation is shown in Fig. 12 and is based on the 1,012/193/102 MWe capacities from above. The demand profile is generated from the total hourly sum data described in Table 7.




Fig. 12. Power generation time series by type, unoptimized and unconstrained.

The time series methodology assumed that the demand was met by:

- nuclear up to its capacity (1,012 MWe), then
- gas up to its capacity (193 MWe, total of 1,205 MWe), then
- battery up to its capacity (102 MWe, total of 1,307 MWe), and then
- unmet demand.

The difference is that the battery usage is concentrated within specific demand peaks. The battery is not a purely dispatchable source; rather, it must be charged before discharge. The analysis assumes a total available storage capacity of 1 hour at its peak power, which in this case is 102 MWeh.

For example, assuming the battery has a full charge of 102 MWeh, if the total demand over the hour is 1,250 MWe, then the battery discharges 45 MWeh, leaving 57 MWeh in the battery. If the next hour demand is less than 1,205 MWe, the gas plant can charge the battery. However, if the next hour demand increases to 1,300 MWe, the total energy available from the battery is 57 MWeh, leaving a 38 MWeh deficit, even though the total demand is less than the total peak power of the system. This is a problem since peak demands tend to cluster in time. This means that the battery is unavailable for large periods of time at peak power once it has fully discharged. In fact, the battery fully discharges 130 times in this time series and is unavailable for 1,271 hours, or approximately 15% of the year.

Due to these performance decrements, the results from the time series analysis shows that the nuclear capacity factor remains ~0.92, but the gas capacity factor decreases to ~0.28 because the actual battery provision to the grid is 0.014 MWeh rather than the 0.105 MWeh predicted from the cumulative density estimate. This indicates that the total energy required to the battery decreases, as well. This lower capacity factor is outside the constraint range as defined in Table 14. As a result, the unmet demand increases from 60,000 MWeh to 144,000 MWeh, and the total cost increases to ~\$71/MWeh.

Cost-optimizing this system using the same constraints as the cumulative density estimate yields a solution of 1,007/100/38 MWe for nuclear/gas/battery, with capacity factors of 0.92/0.35/0.044. The

unmet demand increased to 339,000 MWeh, and the total system cost is \$72.77/MWeh. This cost is greater than the \$71/MWeh quoted above, but this meets the requirements of a gas capacity factor of at least 0.35.

Fig. 13 shows the updated time series to reflect this constrained solution.




Fig. 13. Power generation time series by type, first optimization with constraints.

Data presented in Fig. 13 show more frequent battery charging at lower power and an increased unmet demand versus the data presented in Fig. 12. In this case, the battery discharged fully 172 times and was unavailable for 2,329 hours, or 27% of the year.

Choosing instead to minimize the unmet demand yields a solution of 1,007/129/200 MWe for the nuclear/gas/battery, with capacity factors of 0.92/0.35/0.037. However, the battery still discharges fully 136 times and is unavailable for ~20% of the year (1,808 hours), and the unmet demand is still 253,000 MWeh. This leads to a cost of \$73.46/MWeh. It should be noted that there is relatively little movement in the overall cost, even with relatively large shifts in power capacities. This implies that the notion of optimization may have large solution spaces with slim margins of cost improvement among different configurations, especially when including uncertainties.

Another power maneuver factor is in the actual operation of the nuclear power plant. The analysis so far has assumed that the nuclear power plant can change its power from hour to hour without any limit. However, using the time series demonstrates the wide range of power swings. For example, the 1,007 MWe nuclear power plant from the current example state of optimization performs 5,319 power maneuvers over the 8,760 hours of operation, or 61% of the hours of operation.²⁴ This is obviously

²⁴The reactor ramps up or down when demand is less than the rated power. At demands greater than the rated power, the reactor operates at steady state. When the reactor moves from a demand less than the rated power to one greater than the rated power, the reactor ramps up or down, or vice versa. Thus, even though 1,007 MWe is approximately 58% of the cumulative distribution shown in Fig. 8 (~5,081 hours), there are hours of transition between those operating regimes that also count toward the number of power maneuvers.

undesirable. Further, the hourly power maneuvers range in magnitude from -10% to +13%; this again is undesirable. French experience shows that load following (up to 5%/minute) is acceptable (Nuclear Energy Agency 2011), but there is an assumption that frequent power maneuvers should be minimized.

As an initial requirement, it can be assumed that the nuclear power plant may not ramp more than an absolute magnitude of more than 10%/hour. For example, when operating at 800 MWe, the power in the next hour can be between 880 MWe and 720 MWe. A demand of 900 MWe, although within the rated power of the reactor, cannot be achieved by the reactor and must be met by gas. Conversely, a demand of 700 cannot be exactly met by the reactor and the excess power must therefore be diverted to another sink.

Implementing this requirement on top of the existing 1,007/100/38 MWe capacities causes little change in the overall performance. The number of power maneuvers was essentially constant at 5,319, and the cost remained \$72.77/MWeh. Since the power swing range is between -10% and +13%, this is a reasonable result since the gas plant can be brought online to meet the +3% demand change.

Optimizing the system with constraints yields capacities of 1,007/100/28 MWe for nuclear/gas/battery and a total cost of \$72.68/MWeh, with 5,319 power maneuvers and 26.8% unavailability in the battery. This also has 341,000 MWeh of unmet demand.

Optimizing with a 5% ramp limitation yields 998/100/0 MWe for nuclear/gas/battery. The cost decreases to \$72.65/MWeh, but the unmet demand is 368,000 MWeh, and the excess production is 26,600 MWeh. Additionally, this requires 5,358 power maneuvers.

9.6 INTRODUCTION OF THE INDUSTRY CUSTOMER

An alternate approach to minimizing power maneuvers while maximizing capacity factor in the nuclear power plant is to find another customer for the power. In this case, the customer is a thermal power customer. This is shown in Fig. 14.




Fig. 14. Industry customer integration.

In practice, the thermal power from the reactor would need to go through a thermal routing system, sending the power to either the power conversion system or the industrial customer. This has been referred to as a *thermal manifold* (Harrison 2016). For the purposes of this preliminary analysis, the thermal manifold is assumed to have no associated cost²⁵ or inefficiencies.

For this analysis, the industry customer is assumed to use a fixed amount of thermal power, and it is further assumed that the customer uses direct thermal power from the reactor rather than converting electrical power back to thermal power. For the LWR, a standard thermal efficiency of 32.6% is assumed.²⁶ Thus, 1 MWe can be traded for ~3 MWt at the industry customer. Finally, it is assumed that any thermal power not provided by the reactor is made up by a natural gas source. When the industrial system does not receive thermal power from the reactor, the industrial system draws natural gas, providing 1,032 BTU/cubic foot, or $\sim 3 \times 10^{-4}$ MWth/cubic foot. At ~\$3/mcf, the cost of gas heat is ~\$10/MWth.

The configuration of 998/100/0 MWe, and a 5% maximum ramp yields a maximum excess power of ~82 MWe, which yields ~246 MWt for industrial processes. For the noncoupled system, the costs are:

- $C_N = \$537.98 \times 10^6$
- $C_{GT} = \$23.80 \times 10^6$
- $C_B = \$0 \times 10^6$
- $C_U = \$47.8810^6$

²⁵The thermal manifold costs are assumed to be included with the nuclear power plant costs.

²⁶See Section 2.1.

The electricity cost is $\$609.67 \times 10^6$, which translates to $\$72.65/\text{MWeh}$.

Adding the industrial thermal energy costs requires

$$C_I = 246 \text{ MWt} \times 8760 \text{ h} \times \frac{\$10}{\text{MWth}} = \$21.55 \times 10^6.$$

Thus for a noncoupled system, the total cost is $\$631.31\text{M}$, with a total useful power output of 8.39×10^6 MWeh, an industrial consumption of 2.15×10^6 MWth, an unmet demand of 0.37×10^6 MWeh, and an unused excess of 0.027×10^6 MWeh. Allowing the reactor to meet some of the thermal demand of the industrial customer decreases the industrial consumption by 0.08×10^6 MWth, which is an $\$800,000$ annual savings.

The most direct way to account for this cost benefit is to accrue the savings in the cost of the electrical power system. Thus, the cost for the electricity is $\$72.57/\text{MWeh}$; this is a minimal benefit.

However, this assumes the reactor still works in load following mode. Instead, the reactor operates at full power except for a 36-day²⁷ refueling outage. The 36 days will be chosen as the 864 consecutive hours with the least total demand from the total hourly sum distribution, with a 24-hour linear startup and shutdown on either side of the outage.

The cost-optimized solution for a reactor operating at full power steady state supplying thermal power to an industrial process has a 919 MWe reactor and a 300 MWe gas plant without a storage battery. These have capacity factors of 0.90 and 0.44, respectively; the nuclear capacity factor is fixed based on the required operating profile. The industry partner is allowed to vary up to 1,000 MWt demand, and the optimal solution is 1,000 MWt. The nuclear reactor provides 0.808×10^6 MWth to industry, for a savings of $\$8.1\text{M}$. This provides the total electricity cost of $\$79.31/\text{MWeh}$. This much higher total cost is due to the greatly increased unmet demand of 627,000 MWeh, an incurred cost of $\$81.5\text{M}$.

9.7 TRADE STUDIES IN GAS AND UNMET DEMAND COSTS

Following the analyses in Section 9.6, the cost-optimized solution starts to rely on gas power in both the electricity and industry partner as the primary leverage. Allowing the gas power plant to have a capacity of 500 MWe and a capacity factor of 0.65 makes the optimal solution a nuclear power plant at 739 MWe and a gas plant at 500 MWe, still without a battery. The gas plant has a capacity factor of 0.58. The industry partner still requires 1,000 MWt, and the levelized cost of electricity, including the savings accrued from displacing natural gas, is $\$73.03$.

Allowing the natural gas plant to grow larger with a higher capacity factor indicates that the use of a baseload gas plant, such as a combined cycle plant, rather than a peaking plant, is more appropriate. It also indicates that low gas prices tend to cause gas to displace nuclear power when optimizing the system.

To demonstrate this displacement effect, doubling the cost of gas to $\$6$ per thousand cubic foot (mcf) changes the optimal solution to a 907 MWe reactor and a 500 MWe gas plant at 0.90 and 0.35 capacity factors, respectively, with a levelized cost of $\$79.80$.

Returning to optimization with a peaking plant and using the same optimization ranges as those in Table 14, the impacts of increasing gas prices are shown in Table 15.

²⁷The typical outage in the US lasts 36 days (Nuclear Energy Institute n.d.).

Table 15. Impact of gas prices on system optimization

Optimized Parameter	Gas Price (\$/mcf)					
	1	2	3 (base)	4	5	6
Nuclear (MWe)	915		919	962	987	
Gas (MWe/cap. fac.)	300/0.45		300/0.44	300/0.38	300/0.35	
Battery (MWe)	0					
Unmet (10 ⁶ MWeh)	631		626	577	556	
Industry (MWt)	1,000					
Cost (\$/MWeh)	76.91	78.11	79.31	80.29	80.91	81.48

The gas price range that impacts plant capacity is \$2/mcf to \$5/mcf. The gas plant operates at maximum capacity factor for prices less than \$2/mcf and at minimum capacity factor for prices greater than \$5/mcf. However, this range is highly dependent on constraining the capacity of the gas power plant between 100 and 300 MWe and capacity factor between 0.35 and 0.45. Relaxing either of those constraints will change the gas price impact range and the set of optimized capacities. For reference, increasing the cost of natural gas from \$3/mcf to \$5/mcf is also equivalent to introducing a \$36/MT carbon cost.

The other effect is that the battery is unnecessary at any gas price for the given cost of unmet demand. The optimized system has essentially found that paying a penalty for unmet demand is more attractive than paying for a low-capacity factor, relatively high-cost battery. This is primarily due to the nuclear plant outage period, which has an average demand of 852 MWe. This means that a 100 MWeh total capacity battery is insignificant.

Varying the price of unmet electricity illustrates the cost ranges of attractiveness for the battery, as shown in Table 16.

Table 16. Impact of unmet demand prices on system optimization

Optimized parameter	Unmet demand price (\$/MWeh)								
	130 (base)	200	400	600	800	1,000	1,200	1,400	1,500
Nuclear (MWe)	915	961	987		988	990	992		
Gas (MWe/cap. fac.)	300/0.45	300/0.38				300/0.35			
Battery (MWe)	0								
Unmet (10 ⁶ MWeh)	631	578	556	556	554	546	540	538	536
Industry (MWt)	1,000								
Cost (\$/MWeh)	79.31	84.44	98.08	111.63	125.18	138.58	151.80	164.91	171.44

Table 16 shows that increasing the cost of unmet demand initially increases the amount of nuclear power necessary to increase the overall power available, but battery storage is still not preferred. After reaching \$600/MWeh for unmet demand, the battery becomes an attractive option. However, it does not reach full capacity (200 MWe) until unmet demand prices are ~\$1,500/MWeh. This lack of demand is a result of the intense clustering of the peaks. The battery is fully discharged rapidly and often. This can be overcome by increasing the power and capacity factor of the gas plant (again more closely resembling a baseload combined cycle plant), but this may displace the need for a battery altogether.